

**RÉPONSE DU TRANSPORTEUR À L'ENGAGEMENT 9
(DEMANDÉ PAR EBMI)**

Engagement 9

(demandé par EBMI, notes sténographiques, 7 février 2011, volume 8, page 244)

Fournir l'information concernant les bandes 1 et 2.

R9 : Réponse du Dr Ren Orans :

In response to Q.258 in the transcript above, I have provided a summary of BPA's Energy Imbalance Services' Band 1 and Band 2. The rate schedule, BPA 2010 Transmission and Ancillary Service Rate Schedules (approved 10/01/09) is located at:

http://transmission.bpa.gov/business/rates/documents/2010_Rate_Schedules_10_01_09.pdf

Page 47 starts the description of the Energy Imbalance service.

Band 1

Deviations that are less than or equal to: i) $\pm 1.5\%$ of the scheduled amount of energy, or ii) ± 2 MW, whichever is larger in absolute value. BPA-TS will maintain deviation accounts showing the net Energy Imbalance (the sum of positive and negative deviations from schedule for each hour) for Heavy Load Hour (HLH) and Light Load Hour (LLH) periods.

Positive imbalances (overgeneration) are credited at BPA's incremental cost based on the applicable HLH and LLH incremental cost for the month and negative imbalances (undergeneration) are charged at the applicable HLH and LLH incremental cost for the month.

Band 2

Deviations that are greater than $\pm 1.5\%$ of the scheduled amount of energy or ± 2 MW, whichever is larger in absolute value, ii) up to and including $\pm 7.5\%$ of the scheduled amount of energy or ± 10 MW, whichever is larger in absolute value.

