

GAZIFÈRE INC.
SUIVI DE LA DÉCISION D-2014-114 – PROCESSUS DE MESURAGE AVEC
NIAGARA GAS TRANSMISSION
CAUSE TARIFAIRE 2015 (PHASE 3)

1 In order to respond to the Régie's request in its decision D-2014-114, Gazifère has taken the
2 necessary steps with Niagara Gas Transmission and was informed of the following.

3
4 Measurement Canada requires Custody transfer to be 1.0% or better. The meters in question
5 have been tested and certified to be accurate within 0.3%. The calibration certificates show the
6 accuracy results ranging from 0.2% to 0.3%. The official calibration certificates are filed as
7 exhibit GI-16, document 7.1. The meters are calibrated at the time of installation and are re-
8 calibrated on a 7 year cycle, in accordance with Measurement Canada requirements.