

**Norme de fiabilité PRC-024-3 et son annexe
Québec (version anglaise)**

A. Introduction

1. **Title:** **Frequency and Voltage Protection Settings** for Generating Resources
2. **Number:** PRC-024-3
3. **Purpose:** To set protection such that generating resource(s) remain connected during defined frequency and voltage excursions in support of the Bulk Electric System (BES).
4. **Applicability:**
 - 4.1. **Functional Entities:**
 - 4.1.1 Generator Owners that apply protection listed in Section 4.2.1.
 - 4.1.2 Transmission Owners (in the Quebec Interconnection only) that own a BES generator step-up (GSU) transformer or main power transformer (MPT)¹ and apply protection listed in Section 4.2.1.
 - 4.1.3 Planning Coordinators (in the Quebec Interconnection only)
 - 4.2. **Facilities²:**
 - 4.2.1 Frequency, voltage, and volts per hertz protection (whether provided by relaying or functions within associated control systems) that respond to electrical signals and: (i) directly trip the generating resource(s); or (ii) provide signals to the generating resource(s) to either trip or cease injecting current; and are applied to the following:
 - 4.2.1.1 BES generating resource(s).
 - 4.2.1.2 BES GSU transformer(s).
 - 4.2.1.3 High side of the generator-connected unit auxiliary transformer³ (UAT) installed on BES generating resource(s).
 - 4.2.1.4 Individual dispersed power producing resource(s) identified in the BES Definition, Inclusion I4.
 - 4.2.1.5 Elements that are designed primarily for the delivery of capacity from the individual dispersed power producing resources identified in the BES Definition, Inclusion I4, to the point where those resources aggregate to greater than 75 MVA.

¹ For the purpose of this standard, the MPT is the power transformer that steps up voltage from the collection system voltage to the nominal transmission/interconnecting system voltage for dispersed power producing resources.

² It is not required to install or activate the protections described in Facilities Section 4.2.

³ These transformers are variably referred to as station power UAT, or station service transformer(s) used to provide overall auxiliary power to the generating resource(s). This UAT is the transformer connected on the generator bus between the low side of the GSU and the generator terminal.

4.2.1.6 MPT⁴ of resource(s) identified in the BES Definition, Inclusion I4.

4.2.2 Exemptions: Protection on all auxiliary equipment within the generating Facility.

5. Effective Date: See the Implementation Plan for PRC-024-3.

⁴ For the purpose of this standard, the MPT is the power transformer that steps up voltage from the collection system voltage to the nominal transmission/interconnecting system voltage for dispersed power producing resources

B. Requirements and Measures

- R1.** Each Generator Owner shall set its applicable frequency protection⁵ in accordance with PRC-024 Attachment 1 such that the applicable protection does not cause the generating resource to trip or cease injecting current within the “no trip zone” during a frequency excursion with the following exceptions: *[Violation Risk Factor: Medium]* *[Time Horizon: Long-term Planning]*
- Applicable frequency protection may be set to trip or cease injecting current within a portion of the “no trip zone” for documented and communicated regulatory or equipment limitations in accordance with Requirement R3.
- M1.** Each Generator Owner shall have evidence that the applicable frequency protection has been set in accordance with Requirement R1, such as dated setting sheets, calibration sheets, calculations, or other documentation.
- R2.** Each Generator Owner shall set its applicable voltage protection⁵ in accordance with PRC-024 Attachment 2, such that the applicable protection does not cause the generating resource to trip or cease injecting current within the “no trip zone” during a voltage excursion at the high side of the GSU or MPT, subject to the following exceptions: *[Violation Risk Factor: Medium]* *[Time Horizon: Long-term Planning]*
- If the Transmission Planner allows less stringent voltage protection settings than those required to meet PRC-024 Attachment 2, then the Generator Owner may set its protection within the voltage recovery characteristics of a location-specific Transmission Planner’s study.
 - Applicable voltage protection may be set to trip or cease injecting current during a voltage excursion within a portion of the “no trip zone” for documented and communicated regulatory or equipment limitations in accordance with Requirement R3.
- M2.** Each Generator Owner shall have evidence that applicable voltage protection has been set in accordance with Requirement R2, such as dated setting sheets, voltage-time boundaries, calibration sheets, coordination plots, dynamic simulation studies, calculations, or other documentation.

⁵ Frequency, voltage, and volts per hertz protection (whether provided by relaying or functions within associated control systems) that respond to electrical signals and: (i) directly trip the generating resource(s); or (ii) provide signals to the generating resource(s) to either trip or cease injecting current.

- R3.** Each Generator Owner shall document each known regulatory or equipment limitation⁶ that prevents an applicable generating resource(s) with frequency or voltage protection from meeting the protection setting criteria in Requirements R1 or R2, including (but not limited to) study results, experience from an actual event, or manufacturer's advice.
[Violation Risk Factor: Lower] [Time Horizon: Long-term Planning]
- 3.1.** The Generator Owner shall communicate the documented regulatory or equipment limitation, or the removal of a previously documented regulatory or equipment limitation, to its Planning Coordinator and Transmission Planner within 30 calendar days of any of the following:
- Identification of a regulatory or equipment limitation.
 - Repair of the equipment causing the limitation that removes the limitation.
 - Replacement of the equipment causing the limitation with equipment that removes the limitation.
 - Creation or adjustment of an equipment limitation caused by consumption of the cumulative turbine life-time frequency excursion allowance.
- M3.** Each Generator Owner shall have evidence that it has documented and communicated any known regulatory or equipment limitations that resulted in an exception to Requirements R1 or R2 in accordance with Requirement R3, such as a dated email or letter that contains such documentation as study results, experience from an actual event, or manufacturer's advice.
- R4.** Each Generator Owner shall provide its applicable protection settings associated with Requirements R1 and R2 to the Planning Coordinator or Transmission Planner that models the associated generating resource(s) within 60 calendar days of receipt of a written request for the data and within 60 calendar days of any change to those previously requested settings unless directed by the requesting Planning Coordinator or Transmission Planner that the reporting of protection setting changes is not required.
[Violation Risk Factor: Lower] [Time Horizon: Operations Planning]
- M4.** Each Generator Owner shall have evidence that it communicated applicable protection settings in accordance with Requirement R4, such as dated e-mails, correspondence or other evidence and copies of any requests it has received for that information.

⁶ Excludes limitations caused by the setting capability of the frequency, voltage, and volts per hertz protective relays for the generating resource(s). This does not exclude limitations originating in the equipment protected by the relay. This also does not exclude limitations of frequency, voltage, and volts per hertz protection embedded in control systems.

C. Compliance

1. Compliance Monitoring Process

1.1. Compliance Enforcement Authority: “Compliance Enforcement Authority” means NERC or the Regional Entity, or any entity as otherwise designated by an Applicable Governmental Authority, in their respective roles of monitoring and/or enforcing compliance with mandatory and enforceable Reliability Standards in their respective jurisdictions.

1.2. Evidence Retention: The following evidence retention period(s) identify the period of time an entity is required to retain specific evidence to demonstrate compliance. For instances where the evidence retention period specified below is shorter than the time since the last audit, the Compliance Enforcement Authority may ask an entity to provide other evidence to show that it was compliant for the full-time period since the last audit.

The applicable entity shall keep data or evidence to show compliance as identified below unless directed by its Compliance Enforcement Authority to retain specific evidence for a longer period of time as part of an investigation.

- The Generator Owner shall keep data or evidence Requirement R1 through R4; for 3 years or until the next audit, whichever is longer.
- If a Generator Owner is found non-compliant, the Generator Owner or Transmission Owner shall keep information related to the non-compliance until mitigation is complete and approved for the time period specified above, whichever is longer.

1.3. Compliance Monitoring and Assessment Program: As defined in the NERC Rules of Procedure, “Compliance Monitoring and Enforcement Program” refers to the identification of the processes that will be used to evaluate data or information for the purpose of assessing performance or outcomes with the associated Reliability Standard.

Violation Severity Levels

| R # | Violation Severity Levels | | | |
|------------|--|---|---|--|
| | Lower VSL | Moderate VSL | High VSL | Severe VSL |
| R1. | N/A | N/A | N/A | The Generator Owner failed to set its applicable frequency protection so that it does not trip or cease injecting current according to Requirement R1. |
| R2. | N/A | N/A | N/A | The Generator Owner failed to set its applicable voltage protection so that it does not trip or cease injecting current according to Requirement R2. |
| R3. | The Generator Owner documented the known non-protection system equipment limitation that prevented it from meeting the criteria in Requirement R1 or R2 and communicated the documented limitation to its Planning Coordinator and Transmission Planner more than 30 calendar days but less than or equal to 60 calendar | The Generator Owner documented the known non-protection system equipment limitation that prevented it from meeting the criteria in Requirement R1 or R2 and communicated the documented limitation to its Planning Coordinator and Transmission Planner more than 60 calendar days but less than or equal | The Generator Owner documented the known non-protection system equipment limitation that prevented it from meeting the criteria in Requirement R1 or R2 and communicated the documented limitation to its Planning Coordinator and Transmission Planner more than 90 calendar | <p>The Generator Owner failed to document any known non-protection system equipment limitation that prevented it from meeting the criteria in Requirement R1 or R2.</p> <p>OR</p> <p>The Generator Owner failed to communicate the</p> |

| R # | Violation Severity Levels | | | |
|------------|--|--|--|--|
| | Lower VSL | Moderate VSL | High VSL | Severe VSL |
| | days of identifying the limitation. | to 90 calendar days of identifying the limitation. | days but less than or equal to 120 calendar days of identifying the limitation. | documented limitation to its Planning Coordinator and Transmission Planner within 120 calendar days of identifying the limitation. |
| R4. | <p>The Generator Owner provided its protection settings more than 60 calendar days but less than or equal to 90 calendar days of any change to those settings.</p> <p>OR</p> <p>The Generator Owner provided protection settings more than 60 calendar days but less than or equal to 90 calendar days of a written request.</p> | <p>The Generator Owner provided its protection settings more than 90 calendar days but less than or equal to 120 calendar days of any change to those settings.</p> <p>OR</p> <p>The Generator Owner provided protection settings more than 90 calendar days but less than or equal to 120 calendar days of a written request.</p> | <p>The Generator Owner provided its protection settings more than 120 calendar days but less than or equal to 150 calendar days of any change to those settings.</p> <p>OR</p> <p>The Generator Owner provided protection settings more than 120 calendar days but less than or equal to 150 calendar days of a written request.</p> | <p>The Generator Owner failed to provide its protection settings within 150 calendar days of any change to those settings.</p> <p>OR</p> <p>The Generator Owner failed to provide protection settings within 150 calendar days of a written request.</p> |

D. Regional Variances

D.A. Variance for the Quebec Interconnection

This Variance extends the applicability of Requirements R1, R3, and R4 to Transmission Owners in the Quebec Interconnection that own a BES GSU or MPT and apply protection listed in Section 4.2.1, Facilities. This Variance also replaces Requirement R2 of the continent-wide standard in its entirety and adds a new requirement, Requirement D.A.5., applicable to Planning Coordinators in the Quebec Interconnection.

In Requirements R1, R3, and R4, all references to “Generator Owner” are replaced with “Generator Owner and Transmission Owner.”

This Variance replaces continent-wide Requirement R2 in its entirety with the following:

- D.A.2.** Each Generator Owner and Transmission Owner shall set its applicable voltage protection⁵ in accordance with PRC-024 Attachment 2a, such that the applicable protection does not cause the generating resource to trip or cease injecting current during a voltage excursion within the “no trip zone” at the high side of the GSU or MPT, subject to the following exceptions: *[Violation Risk Factor: Medium] [Time Horizon: Long-term Planning]*
- For newly designated strategic power plants, applicable protections must comply with the high voltage durations for such plants within 48 calendar months of the notification made pursuant to Requirement D.A.5. During this transition period, voltage protections must at least comply with the high voltage durations for “all power plants”.
 - The generating resource(s) are permitted to be set to trip or to cease injecting current during a voltage excursion bounded by the “no trip zone” of PRC-024 Attachment 2a for documented and communicated regulatory or equipment limitations in accordance with Requirement R3.
 - If the Transmission Planner allows less stringent voltage protection settings than those required to meet PRC-024 Attachment 2a, then the Generator Owner or Transmission Owner may set its protection within the voltage recovery characteristics of a location-specific Transmission Planner’s study.
 - Inverter-based resources voltage protection settings may be set to cease injecting current momentarily during a voltage excursion at the high side of the MPT, bounded by the “no trip zone” of PRC-024 Attachment 2a, under the following conditions:

- After a minimum delay of 0.022 s, when the positive-sequence voltage exceeds 1.25 per unit (p.u.) Normal operation must resume once the voltage drops back below 1.25 p.u at the high side of the MPT.
- After a minimum delay of 0.022 s, when the phase-to-ground root mean square (RMS) voltages exceeds 1.4 p.u., as measured at generator terminals, on one or multiple phases. Normal operation must resume once the positive-sequence voltage drops back below the 1.25 p.u. at the high side of the MPT.

M.D.A.2. Each Generator Owner and Transmission Owner shall have evidence that applicable voltage protection has been set in accordance with Requirement R2, such as dated setting sheets, voltage-time boundaries, calibration sheets, coordination plots, dynamic simulation studies, calculations, or other documentation.

This Variance adds the following Requirement:

D.A.5 Each Planning Coordinator shall designate, at least once every five calendar years, the strategic power plants that must comply with Attachment 2a and notify, within 30 calendar days of its designation, each Generator Owner or Transmission Owner that owns facilities⁷ in the strategic power plants. *[Violation Risk Factor: Medium] [Time Horizon: Long-term planning]*

M.D.A.5 Each Planning Coordinator shall have evidence that it designated, at least once every five calendar years, strategic power plants in accordance with Requirement D.A.5, Part 5 and shall have dated evidence that each Generator Owner or Transmission Owner has been notified in accordance with Requirement D.A.5, part 5.2. Evidence may include, but is not limited to: letters, emails, electronic files, or hard copy records demonstrating transmittal of information.

⁷ Facilities in the strategic power plants include facilities from the generator up to and including the MPT or GSU.

Violation Severity Levels

This Variance adds a VSL for D.A.5 and modifies the VSL for R2 as follows:

| R # | Violation Severity Levels | | | |
|---------------|---------------------------|--|--|---|
| | Lower VSL | Moderate VSL | High VSL | Severe VSL |
| D.A.2. | N/A | N/A | N/A | <p>The Generator Owner or Transmission Owner failed to set its applicable voltage protection so that it does not trip or cease injecting current in accordance with Requirement D.A.2.</p> <p>OR</p> <p>The Generator Owner or Transmission Owner set its applicable voltage protection in accordance with Requirement D.A.2 but, for strategic power plants, failed to do so within 48 months of notification.</p> |
| D.A.5. | N/A | The Planning Coordinator designated strategic power plants at least once every five calendar years but notified each Generator Owner or Transmission Owner that owns | The Planning Coordinator designated strategic power plants at least once every five calendar years but notified each Generator Owner or Transmission Owner that owns | The Planning Coordinator failed to designate, at least once every five years, the strategic power plants that must comply with Attachment 2a. |

| R # | Violation Severity Levels | | | |
|-----|---------------------------|---|---|---|
| | Lower VSL | Moderate VSL | High VSL | Severe VSL |
| | | facilities in the strategic power plants between 31 days and 45 days after its designation. | facilities in the strategic power plants between 46 days and 60 days after its designation. | <p>OR</p> <p>The Planning Coordinator failed to notify, each Generator Owner or Transmission Owner that owns facilities in the strategic power plants or notified them more than 60 days after the its designation.</p> |

E. Associated Documents

Implementation Plan

Version History

| Version | Date | Action | Change Tracking |
|---------|-------------------|---|--|
| 1 | May 9, 2013 | Adopted by the NERC Board of Trustees | |
| 1 | March 20, 2014 | FERC Order issued approving PRC-024-1. (Order becomes effective on 7/1/16.) | |
| 2 | February 12, 2015 | Adopted by the NERC Board of Trustees | Standard revised in Project 2014-01: Applicability revised to clarify application of requirements to BES dispersed power producing resources |
| 2 | May 29, 2015 | FERC Letter Order in Docket No. RD15-3-000 approving PRC-024-2 | Modifications to adjust the applicability to owners of dispersed generation resources. |
| 3 | February 6, 2020 | Adopted by the NERC Board of Trustees | Standard revised in Project 2018-04 |
| 3 | July 9, 2020 | FERC Letter Order approved PRC-024-3. Docket No. RD20-7-000 | |

Attachment 1

(Frequency No Trip Boundaries by Interconnection⁸)




Figure 1

** The area outside the "No Trip Zone" is not a "Must Trip Zone."*

Frequency Boundary Data Points - Eastern Interconnection

| High Frequency Duration | | Low Frequency Duration | |
|-------------------------|----------------------------|------------------------|----------------------------|
| Frequency (Hz) | Minimum Time (Sec) | Frequency (Hz) | Minimum Time (sec) |
| ≥61.8 | Instantaneous ⁹ | ≤57.8 | Instantaneous ⁹ |
| ≥60.5 | $10^{(90.935-1.45713*f)}$ | ≤59.5 | $10^{(1.7373*f-100.116)}$ |
| <60.5 | Continuous operation | > 59.5 | Continuous operation |

Table 1

⁸ The figures do not visually represent the "no trip zone" boundaries before 0.1 seconds and after 10,000 seconds. The Frequency Boundary Data Points Table defines the entirety of the "no trip zone" boundaries.

⁹ Frequency is calculated over a window of time. While the frequency boundaries include the option to trip instantaneously for frequencies outside the specified range, this calculation should occur over a time window. Typical window/filtering lengths are three to six cycles (50 – 100 milliseconds). Instantaneous trip settings based on instantaneously calculated frequency measurement is not permissible.




Figure 2

* The area outside the "No Trip Zone" is not a "Must Trip Zone."

Frequency Boundary Data Points –Western Interconnection

| High Frequency Duration | | Low Frequency Duration | |
|-------------------------|----------------------------|------------------------|----------------------------|
| Frequency (Hz) | Minimum Time (Sec) | Frequency (Hz) | Minimum Time (sec) |
| ≥61.7 | Instantaneous ⁹ | ≤57.0 | Instantaneous ⁹ |
| ≥61.6 | 30 | ≤57.3 | 0.75 |
| ≥60.6 | 180 | ≤57.8 | 7.5 |
| <60.6 | Continuous operation | ≤58.4 | 30 |
| | | ≤59.4 | 180 |
| | | >59.4 | Continuous operation |

Table 2




Figure 3

** The area outside the "No Trip Zone" is not a "Must Trip Zone."*

Frequency Boundary Data Points – Quebec Interconnection

| High Frequency Duration | | Low Frequency Duration | |
|-------------------------|----------------------------|------------------------|----------------------------|
| Frequency (Hz) | Minimum Time (Sec) | Frequency (Hz) | Minimum Time (Sec) |
| >66.0 | Instantaneous ⁹ | <55.5 | Instantaneous ⁹ |
| ≥63.0 | 5 | ≤56.5 | 0.35 |
| ≥61.5 | 90 | ≤57.0 | 2 |
| ≥60.6 | 660 | ≤57.5 | 10 |
| <60.6 | Continuous operation | ≤58.5 | 90 |
| | | ≤59.4 | 660 |
| | | >59.4 | Continuous operation |

Table 3




Figure 4

* The area outside the "No Trip Zone" is not a "Must Trip Zone."

Frequency Boundary Data Points – ERCOT Interconnection

| High Frequency Duration | | Low Frequency Duration | |
|-------------------------|----------------------------|------------------------|----------------------------|
| Frequency (Hz) | Minimum Time (Sec) | Frequency (Hz) | Minimum Time (sec) |
| ≥ 61.8 | Instantaneous ⁹ | ≤ 57.5 | Instantaneous ⁹ |
| ≥ 61.6 | 30 | ≤ 58.0 | 2 |
| ≥ 60.6 | 540 | ≤ 58.4 | 30 |
| < 60.6 | Continuous operation | ≤ 59.4 | 540 |
| | | > 59.4 | Continuous operation |

Table 4

PRC-024 — Attachment 2

(Voltage No-Trip Boundaries – Eastern, Western, and ERCOT Interconnections)




Figure 1

** The area outside the "No Trip Zone" is not a "Must Trip Zone."*

Voltage Boundary Data Points

| High Voltage Duration | | Low Voltage Duration | |
|-----------------------|--------------------|----------------------|--------------------|
| Voltage (pu) | Minimum Time (sec) | Voltage (pu) | Minimum Time (sec) |
| ≥1.200 | 0.00 | <0.45 | 0.15 |
| ≥1.175 | 0.20 | <0.65 | 0.30 |
| ≥1.15 | 0.50 | <0.75 | 2.00 |
| ≥1.10 | 1.00 | <0.90 | 3.00 |
| <1.10 | 4.00 | ≥ 0.90 | 4.00 |

Table 1

¹⁰Voltage at the high-side of the GSU or MPT.

Attachment 2: Voltage Boundary Clarifications – Eastern, Western, and ERCOT Interconnections

Boundary Details:

1. Unless otherwise specified by the Transmission Planner, the per unit voltage base for these boundaries is the nominal transmission system voltage (e.g., 100 kV, 115 kV, 138 kV, 161 kV, 230 kV, 345 kV, 400 kV, 500 kV, 765 kV, etc.).
2. The values in the table represent the minimum time durations allowed for specified voltage excursion thresholds.
3. When evaluating volts per hertz protection, either assume a system frequency of 60 Hertz or the magnitude of the high voltage boundary can be adjusted in proportion to deviations of frequency below 60 Hertz.
4. Voltages in the boundaries assume RMS fundamental frequency phase-to-ground or phase-to-phase per unit voltage.
5. For applicability to PRC-024, the “no trip zone” ends at 4 seconds.

Evaluating Protection Settings:

The voltage values in the Attachment 2 voltage boundaries are voltages at the high side of the GSU/MPT. For generating resources with multiple stages of step up to reach interconnecting voltage, this is the high side of the transformer with a low side below 100kV and a high side 100kV or above. When evaluating protection settings, consider the voltage differences between where the protection is measuring voltage and the high side of the GSU/MPT. A steady state calculation or dynamic simulation may be used.

If using a steady state calculation or dynamic simulation, use the following conditions when evaluating protection settings:

- a. The most probable real and reactive loading conditions for the unit under study.
- b. All installed generating plant reactive support (e.g., static VAR compensators, synchronous condensers, capacitors) equipment is available and operating normally.
- c. Account for the actual tap settings of transformers between the generator terminals and the high side of the GSU/MPT.
- d. For dynamic simulations, the automatic voltage regulator is in automatic voltage control mode with associated limiters in service.

PRC-024— Attachment 2a (Voltage No-Trip Boundaries – Quebec Interconnection)




Figure 1

*** The area outside the "No Trip Zone" is not a "Must Trip Zone."**

Voltage Boundary Data Points – Quebec Interconnection

| High Voltage Duration for all Power Plants | | High Voltage Duration for strategic Power Plants | |
|--|--------------------|--|--------------------|
| Voltage (pu) | Minimum Time (sec) | Voltage (pu) | Minimum Time (sec) |
| --- | --- | >1.50 | 0.033 |
| >1.40 | 0.033 | >1.40 | 0.10 |
| >1.25 | 0.10 | >1.25 | 2.50 |
| >1.20 | 2.00 | >1.20 | 5.00 |
| >1.15 | 30 | >1.15 | 30 |
| >1.10 | 300 | >1.10 | 300 |
| ≤1.10 | continuous | ≤1.10 | continuous |

Table 1
Voltage Boundary Data Points – Quebec Interconnection

| Low Voltage Duration for all Power Plants | | Low Voltage Duration for Inverter-Based Resources | |
|---|--------------------|---|-----------------------------|
| Voltage (pu) | Minimum Time (sec) | Voltage (pu) | Minimum Time (sec) |
| <0.25 | 0.15 | <0.25 | $3.4 * V(\text{pu}) + 0.15$ |
| <0.75 | 1.00 | <0.75 | 1.00 |
| <0.85 | 2.00 | <0.85 | 2.00 |
| <0.90 | 30 | <0.90 | 30 |
| ≥0.90 | continuous | ≥0.90 | continuous |

Table 2

Attachment 2a: Voltage Boundary Clarifications – Quebec Interconnection

Boundary Details:

1. The per unit voltage base for these boundaries is the nominal operating voltage (e.g., 120 kV, 161 kV, 230 kV, 315 kV, 735 kV, etc.).
2. The values in the table represent the minimum time durations allowed for specified voltage excursion thresholds.
3. When evaluating volts per hertz protection, either assume a system frequency of 60 Hertz or the magnitude of the high voltage boundary can be adjusted in proportion to deviations of frequency below 60 Hertz.
4. Voltages in the Quebec Interconnection boundaries assume positive-sequence values.

Evaluating Protection Settings:

The voltage values in the Attachment 2a voltage boundaries are voltages at the high side of the GSU/MPT. For generating resources with multiple stages of step up to reach interconnecting voltage, this is the high side of the transformer that connects to the interconnecting voltage. When evaluating protection settings, consider the voltage differences between where the protection is measuring voltage and the high side of the GSU/MPT. A steady state calculation or dynamic simulation may be used.

If using a steady state calculation or dynamic simulation, use the following conditions when evaluating protection settings:

- a. The most probable real and reactive loading conditions for the unit under study.
- b. All installed generating plant reactive support (e.g., static VAR compensators, synchronous condensers, capacitors) equipment is available and operating normally.
- c. Account for the actual tap settings of transformers between the generator terminals and the high side of the GSU/MPT.
- d. For dynamic simulations, the automatic voltage regulator is in automatic voltage control mode with associated limiters in service.

Appendix PRC-024-3-QC-1

Specific provisions applicable in Québec for standard PRC-024-3 – Frequency and Voltage Protection Settings for Generating Resources

This appendix establishes specific provisions for the application of the standard in Québec. Provisions of the standard and of this appendix must be read jointly for comprehension and interpretation purposes. Where the standard and appendix differ, the appendix shall prevail.

A. Introduction

Title: No specific provisions.

Number: No specific provisions.

Purpose: No specific provisions.

Applicability:

1.1. Functional Entities

No specific provisions.

1.2. Facilities

The Facilities subject to this standard are the Facilities of the Main Transmission System (RTP).

Replace all references to Bulk Electric System (BES) with Main Transmission System (RTP).

Effective date:

1.3. Adoption of the standard by the Régie de l'énergie: December 21, 2021

1.4. Adoption of this appendix by the Régie de l'énergie: December 21, 2021

1.5. Effective date of the standard and
of this appendix in Québec: July 1, 2025

For Facilities already subject to PRC-024-1, the requirements will be implemented on the following dates:

| Requirements | Applicability | Implementation dates in Québec |
|--------------|---|--------------------------------|
| R1 to R4 | At least 40% of its applicable Facilities | October 1, 2018 |
| | At least 60% of its applicable Facilities | October 1, 2019 |
| | At least 80% of its applicable Facilities | October 1, 2020 |
| | 100% of its applicable Facilities | October 1, 2021 |

Appendix PRC-024-3-QC-1

Specific provisions applicable in Québec for standard PRC-024-3 – Frequency and Voltage Protection Settings for Generating Resources

For Facilities already subject to PRC-024-2, the requirements will be implemented on the following dates:

| Requirements | Applicability | Implementation dates in Québec |
|--------------|---|--------------------------------|
| R1 to R4 | At least 40% of its applicable Facilities | July 1, 2022 |
| | At least 60% of its applicable Facilities | July 1, 2023 |
| | At least 80% of its applicable Facilities | July 1, 2024 |
| | 100% of its applicable Facilities | July 1, 2025 |

For Facilities subject to PRC-024-3, the requirements will be implemented on the following dates:

| Requirements | Applicability | Implementation dates in Québec |
|---|---|--------------------------------|
| All requirements (R1 to R4, D.A.5) except requirement D.A.2 | 100% of its applicable Facilities | July 1, 2025 |
| D.A.2 | At least 50% of its applicable Facilities | July 1, 2025 |
| | At least 70% of its applicable Facilities | July 1, 2027 |
| | 100% of its applicable Facilities | July 1, 2030 |

B. Requirements and Measures

Specific provision regarding Requirement R1:

Inverter-based resources, thermal generating stations, as well as generating stations equipped with asynchronous generators, shall adhere to the curves in Appendix 1, as specified by Requirement R1, except that they may be tripped at a frequency of ≥ 61.7 Hz.

C. Compliance

1. Compliance Monitoring Process

1.1. Compliance Enforcement Authority

In Québec, “Compliance Enforcement Authority” means the Régie de l’énergie in its roles of monitoring and enforcing compliance with respect to the Reliability Standard and to this appendix.

Appendix PRC-024-3-QC-1

Specific provisions applicable in Québec for standard PRC-024-3 – Frequency and Voltage Protection Settings for Generating Resources

1.2. Evidence Retention

No specific provisions.

1.3. Compliance Monitoring and Assessment Program

The Régie de l'énergie establishes the monitoring processes used to evaluate data or information for the purpose of determining compliance or non-compliance with the Reliability Standard and with this appendix.

Violation Severity Levels

No specific provisions.

D. Regional Variances

Replace all references to Bulk Electric System (BES) with Main Transmission System (RTP).

Violation Severity Levels

No specific provisions.

E. Associated Documents

No specific provisions.

PRC-024 — Attachment 1

No specific provisions.

PRC-024-2 — Attachment 2

No specific provisions.

PRC-024 – Attachment 2a

Specific provision regarding boundary details:

It is acceptable to use a measurement of the Root Mean Square (RMS) value of the overvoltage or undervoltage (phase-to-phase or phase-to-ground) provided that the trip associated with these protections occurs only when this overvoltage or undervoltage is present simultaneously on the three phases.

Appendix PRC-024-3-QC-1

Specific provisions applicable in Québec for standard PRC-024-3 – Frequency and Voltage Protection Settings for Generating Resources

Version history

| Version | Date | Action | Change tracking |
|---------|-------------------|---|-----------------|
| 1 | December 21, 2021 | New appendix as per decision D-2021-168 . | New |