

Coordonnateur de la fiabilité

Demande R-4203-2022

Normes de fiabilité et leur annexe Québec en suivi de la décision D-2023-040 (version anglaise)



Coordonnateur de la fiabilité

Demande R-4203-2022

# A. Introduction

- 1. Title: Emergency Preparedness and Operations
- 2. Number: EOP-011-2
- **3. Purpose:** To address the effects of operating emergencies by ensuring each Transmission Operator, Balancing Authority, and Generator Owner has developed plan(s) to mitigate operating Emergencies and that those plans are implemented and coordinated within the Reliability Coordinator Area as specified within the requirements.
- 4. Applicability:
  - 4.1. Functional Entities:
    - 4.1.1 Balancing Authority
    - 4.1.2 Reliability Coordinator
    - 4.1.3 Transmission Operator
    - 3.1.4 Generator Owner
    - **3.1.5** Generator Operator
  - 4.2. Facilities
    - **4.2.1** For the purpose of this standard, the term "generating unit" means all Bulk Electric System generators.
- 5. Effective Date: See Implementation Plan for Project 2019-06.

# **B.** Requirements and Measures

- **R1.** Each Transmission Operator shall develop, maintain, and implement one or more Reliability Coordinator-reviewed Operating Plan(s) to mitigate operating Emergencies in its Transmission Operator Area. The Operating Plan(s) shall include the following, as applicable: [Violation Risk Factor: High] [Time Horizon: Real-Time Operations, Operations Planning, Long-term Planning]
  - 1.1. Roles and responsibilities for activating the Operating Plan(s);
  - **1.2.** Processes to prepare for and mitigate Emergencies including:
    - **1.2.1.** Notification to its Reliability Coordinator, to include current and projected conditions, when experiencing an operating Emergency;
    - **1.2.2.** Cancellation or recall of Transmission and generation outages;
    - **1.2.3.** Transmission system reconfiguration;
    - **1.2.4.** Redispatch of generation request;
    - **1.2.5.** Provisions for operator-controlled manual Load shedding that minimizes the overlap with automatic Load shedding and are capable of being implemented in a timeframe adequate for mitigating the Emergency; and

- **1.2.6.** Provisions to determine reliability impacts of:
  - **1.2.6.1.** cold weather conditions; and
  - **1.2.6.2.** extreme weather conditions.
- M1. Each Transmission Operator will have a dated Operating Plan(s) developed in accordance with Requirement R1 and reviewed by its Reliability Coordinator; evidence such as a review or revision history to indicate that the Operating Plan(s) has been maintained; and will have as evidence, such as operator logs or other operating documentation, voice recordings or other communication documentation to show that its Operating Plan(s) was implemented for times when an Emergency has occurred, in accordance with Requirement R1.
- R2. Each Balancing Authority shall develop, maintain, and implement one or more Reliability Coordinator-reviewed Operating Plan(s) to mitigate Capacity Emergencies and Energy Emergencies within its Balancing Authority Area. The Operating Plan(s) shall include the following, as applicable: [Violation Risk Factor: High] [Time Horizon: Real-Time Operations, Operations Planning, Long-term Planning]
  - 2.1. Roles and responsibilities for activating the Operating Plan(s);
  - 2.2. Processes to prepare for and mitigate Emergencies including:
    - **2.2.1.** Notification to its Reliability Coordinator, to include current and projected conditions when experiencing a Capacity Emergency or Energy Emergency;
    - 2.2.2. Requesting an Energy Emergency Alert, per Attachment 1;
    - **2.2.3.** Managing generating resources in its Balancing Authority Area to address:
      - **2.2.3.1.** capability and availability;
      - **2.2.3.2.** fuel supply and inventory concerns;
      - 2.2.3.3. fuel switching capabilities; and
      - **2.2.3.4.** environmental constraints.
    - 2.2.4. Public appeals for voluntary Load reductions;
    - **2.2.5.** Requests to government agencies to implement their programs to achieve necessary energy reductions;
    - 2.2.6. Reduction of internal utility energy use;
    - **2.2.7.** Use of Interruptible Load, curtailable Load and demand response;
    - **2.2.8.** Provisions for operator-controlled manual Load shedding that minimizes the overlap with automatic Load shedding and are capable of being implemented in a timeframe adequate for mitigating the Emergency; and
    - 2.2.9. Provisions to determine reliability impacts of:

- **2.2.9.1.** cold weather conditions; and
- **2.2.9.2.** extreme weather conditions.
- M2. Each Balancing Authority will have a dated Operating Plan(s) developed in accordance with Requirement R2 and reviewed by its Reliability Coordinator; evidence such as a review or revision history to indicate that the Operating Plan(s) has been maintained; and will have as evidence, such as operator logs or other operating documentation, voice recordings, or other communication documentation to show that its Operating Plan(s) was implemented for times when an Emergency has occurred, in accordance with Requirement R2.
- **R3.** The Reliability Coordinator shall review the Operating Plan(s) to mitigate operating Emergencies submitted by a Transmission Operator or a Balancing Authority regarding any reliability risks that are identified between Operating Plans. [Violation Risk Factor: High] [Time Horizon: Operations Planning]
  - **3.1.** Within 30 calendar days of receipt, the Reliability Coordinator shall:
    - **3.1.1.** Review each submitted Operating Plan(s) on the basis of compatibility and inter-dependency with other Balancing Authorities' and Transmission Operators' Operating Plans;
    - **3.1.2.** Review each submitted Operating Plan(s) for coordination to avoid risk to Wide Area reliability; and
    - **3.1.3.** Notify each Balancing Authority and Transmission Operator of the results of its review, specifying any time frame for resubmittal of its Operating Plan(s) if revisions are identified.
- M3. The Reliability Coordinator will have documentation, such as dated e-mails or other correspondences that it reviewed Transmission Operator and Balancing Authority Operating Plans within 30 calendar days of submittal in accordance with Requirement R3.
- **R4.** Each Transmission Operator and Balancing Authority shall address any reliability risks identified by its Reliability Coordinator pursuant to Requirement R3 and resubmit its Operating Plan(s) to its Reliability Coordinator within a time period specified by its Reliability Coordinator. [Violation Risk Factor: High] [Time Horizon: Operation Planning]
- M4. The Transmission Operator and Balancing Authority will have documentation, such as dated emails or other correspondence, with an Operating Plan(s) version history showing that it responded and updated the Operating Plan(s) within the timeframe identified by its Reliability Coordinator in accordance with Requirement R4.
- **R5.** Each Reliability Coordinator that receives an Emergency notification from a Transmission Operator or Balancing Authority within its Reliability Coordinator Area shall notify, within 30 minutes from the time of receiving notification, other Balancing Authorities and Transmission Operators in its Reliability Coordinator Area, and

neighboring Reliability Coordinators. [Violation Risk Factor: High] [Time Horizon: Real-Time Operations]

- **M5.** Each Reliability Coordinator that receives an Emergency notification from a Balancing Authority or Transmission Operator within its Reliability Coordinator Area will have, and provide upon request, evidence that could include, but is not limited to, operator logs, voice recordings or transcripts of voice recordings, electronic communications, or equivalent evidence that will be used to determine if the Reliability Coordinator communicated, in accordance with Requirement R5, with other Balancing Authorities and Transmission Operators in its Reliability Coordinator Area, and neighboring Reliability Coordinators.
- **R6.** Each Reliability Coordinator that has a Balancing Authority experiencing a potential or actual Energy Emergency within its Reliability Coordinator Area shall declare an Energy Emergency Alert, as detailed in Attachment 1. [Violation Risk Factor: High] [Time Horizon: Real-Time Operations]
- M6. Each Reliability Coordinator, with a Balancing Authority experiencing a potential or actual Energy Emergency within its Reliability Coordinator Area, will have, and provide upon request, evidence that could include, but is not limited to, operator logs, voice recordings or transcripts of voice recordings, electronic communications, or equivalent evidence that it declared an Energy Emergency Alert, as detailed in Attachment 1, in accordance with Requirement R6.
- **R7.** Each Generator Owner shall implement and maintain one or more cold weather preparedness plan(s) for its generating units. The cold weather preparedness plan(s) shall include the following, at a minimum: [*Violation Risk Factor: High*] [*Time Horizon: Operations Planning and Real-Time Operations*]
  - **7.1.** Generating unit(s) freeze protection measures based on geographical location and plant configuration;
  - **7.2.** Annual inspection and maintenance of generating unit(s) freeze protection measures;
  - **7.3.** Generating unit(s) cold weather data, to include:
    - **7.3.1.** Generating unit(s) operating limitations in cold weather to include:
      - 7.3.1.1. capability and availability;
      - 7.3.1.2. fuel supply and inventory concerns;
      - 7.3.1.3. fuel switching capabilities; and
      - 7.3.1.4. environmental constraints.
    - 7.3.2. Generating unit(s) minimum:
      - 7.3.2.1. design temperature; or
      - 7.3.2.2. historical operating temperature; or

- **7.3.1.3.** current cold weather performance temperature determined by an engineering analysis.
- M7. Each Generator Owner will have evidence documenting that its cold weather preparedness plan(s) was implemented and maintained in accordance with Requirement R7.
- **R8.** Each Generator Owner in conjunction with its Generator Operator shall identify the entity responsible for providing the generating unit-specific training, and that identified entity shall provide the training to its maintenance or operations personnel responsible for implementing cold weather preparedness plan(s) developed pursuant to Requirement R7. [Violation Risk Factor: Medium] [Time Horizon: Long-term Planning, Operations Planning]
- **M8.** Each Generator Operator or Generator Owner will have documented evidence that the applicable personnel completed training of the Generator Owner's cold weather preparedness plan(s). This evidence may include, but is not limited to, documents such as personnel training records, training materials, date of training, agendas or learning objectives, attendance at pre-work briefings, review of work order tasks, tailboards, attendance logs for classroom training, and completion records for computer-based training in fulfillment of Requirement R8.

# **C.** Compliance

## 1. Compliance Monitoring Process

## 1.1. Compliance Enforcement Authority

"Compliance Enforcement Authority" (CEA) means NERC or the Regional Entity, or any entity as otherwise designated by an Applicable Governmental Authority, in their respective roles of monitoring and/or enforcing compliance with the mandatory and enforceable Reliability Standards in their respective jurisdictions.

## 1.2. Evidence Retention

The following evidence retention period(s) identify the period of time an entity is required to retain specific evidence to demonstrate compliance. For instances where the evidence retention period specified below is shorter than the time since the last audit, the Compliance Enforcement Authority may ask an entity to provide other evidence to show that it was compliant for the full-time period since the last audit.

The applicable entity shall keep data or evidence to show compliance as identified below unless directed by its Compliance Enforcement Authority to retain specific evidence for a longer period of time as part of an investigation.

- The Transmission Operator shall retain the current Operating Plan(s), evidence of review or revision history plus each version issued since the last audit and evidence of compliance since the last audit for Requirements R1 and R4 and Measures M1 and M4.
- The Balancing Authority shall retain the current Operating Plan(s), evidence of review or revision history plus each version issued since the last audit and

evidence of compliance since the last audit for Requirements R2 and R4, and Measures M2 and M4.

- The Reliability Coordinator shall maintain evidence of compliance since the last audit for Requirements R3, R5, and R6 and Measures M3, M5, and M6.
- The Generator Owner shall retain the cold weather preparedness plan(s), evidence of review or revision history plus each version issued since the last audit and evidence of compliance since the last audit for Requirement R7 and Measure M7.
- 1.3. The Generator Owner or Generator Operator shall keep data or evidence to show compliance for three years or since its last compliance audit, whichever timeframe is greater, unless directed by its Compliance Enforcement Authority to retain specific evidence for a longer period of time as part of an investigation, for Requirement R8 and Measure M8. Compliance Monitoring and Enforcement Program:

As defined in the NERC Rules of Procedure; "Compliance Monitoring and Enforcement Program" refers to the identification of the processes that will be used to evaluate data or information for the purpose of assessing performance or outcomes with the associated Reliability Standard.

# Violation Severity Levels

D #	<b></b>			Violation Sev	tion Severity Levels		
R #	Time Horizon	VRF	Lower VSL	Moderate VSL	High VSL	Severe VSL	
R1	Real-time Operations, Operations Planning, Long- term Planning	High	N/A	The Transmission Operator developed a Reliability Coordinator- reviewed Operating Plan(s) to mitigate operating Emergencies in its Transmission Operator Area but failed to maintain it.	The Transmission Operator developed an Operating Plan(s) to mitigate operating Emergencies in its Transmission Operator Area but failed to have it reviewed by its Reliability Coordinator.	The Transmission Operator failed to develop an Operating Plan(s) to mitigate operating Emergencies in its Transmission Operator Area. OR The Transmission Operator developed a Reliability Coordinator- reviewed Operating Plan(s) to mitigate operating Emergencies in its Transmission s Operator Area but failed to implement it.	
R2	Real-time Operations, Operations	High	N/A	The Balancing Authority developed a Reliability Coordinator-	The Balancing Authority developed an Operating Plan(s) to mitigate operating	The Balancing Authority failed to develop an	

- "				Violation Se	everity Levels	
R #	Time Horizon	VRF	Lower VSL	Moderate VSL	High VSL	Severe VSL
	Planning, Long- term Planning			reviewed Operating Plan(s) to mitigate operating Emergencies within its Balancing Authority Area but failed to maintain it.	Emergencies within its Balancing Authority Area but failed to have it reviewed by its Reliability Coordinator.	Operating Plan(s) to mitigate operating Emergencies within its Balancing Authority Area. OR The Balancing Authority developed a Reliability Coordinator- reviewed Operating Plan(s) to mitigate operating Emergencies within its Balancing Authority Area but failed to implement it.
R3	Operations Planning	High	N/A	N/A	The Reliability Coordinator identified a reliability risk but failed to notify the Balancing Authority or Transmission	The Reliability Coordinator identified a reliability risk but failed to notify the Balancing Authority or Transmission Operator.

			Violation Severity Levels				
R #	Time Horizon	VRF	Lower VSL	Moderate VSL	High VSL	Severe VSL	
					Operator within 30 calendar days.		
R4	Operations Planning	High	N/A	N/A	The Transmission Operator or Balancing Authority failed to update and resubmit tis Operating Plan(s) to its Reliability Coordinator within the timeframe specified by its Reliability Coordinator.	The Transmission Operator or Balancing Authority failed to update and resubmit its Operating Plan(s) to its Reliability Coordinator.	
R5	Real-time Operations	High	N/A	N/A	The Reliability Coordinator that received an Emergency notification from a Transmission Operator or Balancing Authority did notify neighboring Reliability Coordinators, Balancing Authorities	The Reliability Coordinator that received an Emergency notification from a Transmission Operator or Balancing Authority failed to notify neighboring Reliability Coordinators, Balancing Authorities	

- "	_		Violation Severity Levels				
R #	Time Horizon	VRF	Lower VSL	Moderate VSL	High VSL	Severe VSL	
					and Transmission Operators but failed to notify within 30 minutes from the time of receiving notification.	and Transmission Operators.	
R6	Real-time Operations	High	N/A	N/A	N/A	The Reliability Coordinator that had a Balancing Authority experiencing a potential or actual Energy Emergency within its Reliability Coordinator Area failed to declare an Energy Emergency Alert.	
R7	Operations Planning and Real-time Operations	High	The Generator Owner implemented a cold weather preparedness plan(s) but failed to maintain it.	The Generator Owner's cold weather preparedness plan failed to include one of the applicable requirement Parts within Requirement R7.	The Generator Owner had and maintained a cold weather preparedness plan(s) but failed to fully implement it. OR	The Generator Owner does not have a cold weather preparedness plan. OR The Generator Owner has a cold	

- "			Violation Severity Levels				
R #	Time Horizon	VRF	Lower VSL	Moderate VSL	High VSL	Severe VSL	
					The Generator Owner's cold weather preparedness plan failed to include two of the applicable requirement Parts within Requirement R7.	weather preparedness plan, but failed to include any of the applicable requirement Parts within Requirement R7.	
R8	Operations Planning and Real-time Operations	Medium	<ul> <li>The Generator Owner or Generator</li> <li>Operator failed to provide generating unit-specific training as described in</li> <li>Requirement R8 to the greater of:</li> <li>one applicable personnel at a single generating unit; or</li> <li>5% or less of its total applicable personnel.</li> </ul>	<ul> <li>The Generator Owner or Generator</li> <li>Operator failed to provide generating unit-specific training as described in</li> <li>Requirement R8 to the greater of:</li> <li>two applicable personnel at a single generating unit; or</li> <li>more than 5% or less than or equal to 10% of its total applicable personnel.</li> </ul>	<ul> <li>The Generator Owner or Generator</li> <li>Operator failed to provide generating unit-specific training as described in</li> <li>Requirement R8 to the greater of:</li> <li>three applicable personnel at a single generating unit; or</li> <li>more than 10% or less than or equal to 15% of its total applicable personnel.</li> </ul>	<ul> <li>The Generator</li> <li>Owner or Generator</li> <li>Operator failed to</li> <li>provide generating</li> <li>unit-specific training</li> <li>as described in</li> <li>Requirement R8 to</li> <li>the greater of:</li> <li>four applicable</li> <li>personnel at a</li> <li>single generating</li> <li>unit; or</li> <li>more than 15% of</li> <li>its total applicable</li> <li>personnel.</li> </ul>	

# **D. Regional Variances**

None.

# **E.** Interpretations

None.

# **F. Associated Documents**

None.

# **Version History**

Version	Date	Action	Change Tracking
1	November 13, 2014	Adopted by Board of Trustees	Merged EOP-001-2.1b, EOP- 002-3.1 and EOP-003-2.
1	November 19, 2015	FERC approved EOP-011-1. Docket Nos. RM15-7-000, RM15-12-000, and RM15-13- 000. Order No. 818	
2	June 11,2021	Adopted by the Board of Trustees	Revised under Project 2019- 06
2	August 24,2021	FERC approved EOP- 011-2. Docket Number RD21-5-000	
2	August 24,2021	April 1, 2023	Effective Date

# Attachment 1-EOP-011-2 Energy Emergency Alerts

### Introduction

This Attachment provides the process and descriptions of the levels used by the Reliability Coordinator in which it communicates the condition of a Balancing Authority which is experiencing an Energy Emergency.

### A. General Responsibilities

- **1. Initiation by Reliability Coordinator.** An Energy Emergency Alert (EEA) may be initiated only by a Reliability Coordinator at 1) the Reliability Coordinator's own request, or 2) upon the request of an energy deficient Balancing Authority.
- 2. Notification. A Reliability Coordinator who declares an EEA shall notify all Balancing Authorities and Transmission Operators in its Reliability Coordinator Area. The Reliability Coordinator shall also notify all neighboring Reliability Coordinators.

### **B. EEA Levels**

### Introduction

To ensure that all Reliability Coordinators clearly understand potential and actual Energy Emergencies in the Interconnection, NERC has established three levels of EEAs. The Reliability Coordinators will use these terms when communicating Energy Emergencies to each other. An EEA is an Emergency procedure, not a daily operating practice, and is not intended as an alternative to compliance with NERC Reliability Standards.

The Reliability Coordinator may declare whatever alert level is necessary, and need not proceed through the alerts sequentially.

### **1.** EEA 1 — All available generation resources in use.

### **Circumstances:**

- The Balancing Authority is experiencing conditions where all available generation resources are committed to meet firm Load, firm transactions, and reserve commitments, and is concerned about sustaining its required Contingency Reserves.
- Non-firm wholesale energy sales (other than those that are recallable to meet reserve requirements) have been curtailed.

### 2. EEA 2 — Load management procedures in effect.

### Circumstances:

- The Balancing Authority is no longer able to provide its expected energy requirements and is an energy deficient Balancing Authority.
- An energy deficient Balancing Authority has implemented its Operating Plan(s) to mitigate Emergencies.

• An energy deficient Balancing Authority is still able to maintain minimum Contingency Reserve requirements.

During EEA 2, Reliability Coordinators and energy deficient Balancing Authorities have the following responsibilities:

- **2.1 Notifying other** Balancing Authorities **and market participants**. The energy deficient Balancing Authority shall communicate its needs to other Balancing Authorities and market participants. Upon request from the energy deficient Balancing Authority, the respective Reliability Coordinator shall post the declaration of the alert level, along with the name of the energy deficient Balancing Authority on the RCIS website.
- **2.2 Declaration period.** The energy deficient Balancing Authority shall update its Reliability Coordinator of the situation at a minimum of every hour until the EEA 2 is terminated. The Reliability Coordinator shall update the energy deficiency information posted on the RCIS website as changes occur and pass this information on to the neighboring Reliability Coordinators, Balancing Authorities and Transmission Operators.
- **2.3 Sharing information on resource availability.** Other Reliability Coordinators of Balancing Authorities with available resources shall coordinate, as appropriate, with the Reliability Coordinator that has an energy deficient Balancing Authority.
- **2.4 Evaluating and mitigating Transmission limitations**. The Reliability Coordinator shall review Transmission outages and work with the Transmission Operator(s) to see if it's possible to return to service any Transmission Elements that may relieve the loading on System Operating Limits (SOLs) or Interconnection Reliability Operating Limits (IROLs).
- **2.5 Requesting Balancing Authority actions.** Before requesting an EEA 3, the energy deficient Balancing Authority must make use of all available resources; this includes, but is not limited to:
  - **2.5.1** All available generation units are on line. All generation capable of being on line in the time frame of the Emergency is on line.
  - **2.5.2 Demand-Side Management**. Activate Demand-Side Management within provisions of any applicable agreements.
- **3.** EEA 3 Firm Load interruption is imminent or in progress.

### **Circumstances:**

• The energy deficient Balancing Authority is unable to meet minimum Contingency Reserve requirements.

During EEA 3, Reliability Coordinators and Balancing Authorities have the following responsibilities:

**3.1 Continue actions from EEA 2**. The Reliability Coordinators and the energy deficient Balancing Authority shall continue to take all actions initiated during EEA 2.

- **3.2 Declaration Period.** The energy deficient Balancing Authority shall update its Reliability Coordinator of the situation at a minimum of every hour until the EEA 3 is terminated. The Reliability Coordinator shall update the energy deficiency information posted on the RCIS website as changes occur and pass this information on to the neighboring Reliability Coordinators, Balancing Authorities, and Transmission Operators.
- **3.3 Reevaluating and revising SOLs and IROLs.** The Reliability Coordinator shall evaluate the risks of revising SOLs and IROLs for the possibility of delivery of energy to the energy deficient Balancing Authority. Reevaluation of SOLs and IROLs shall be coordinated with other Reliability Coordinators and only with the agreement of the Transmission Operator whose Transmission Owner (TO) equipment would be affected. SOLs and IROLs shall only be revised as long as an EEA 3 condition exists, or as allowed by the Transmission Owner whose equipment is at risk. The following are minimum requirements that must be met before SOLs or IROLs are revised:
  - **3.3.1 Energy deficient Balancing Authority obligations.** The energy deficient Balancing Authority, upon notification from its Reliability Coordinator of the situation, it will immediately take whatever actions are necessary to mitigate any undue risk to the Interconnection. These actions may include Load shedding.
- **3.4 Returning to pre-Emergency conditions.** Whenever energy is made available to an energy deficient Balancing Authority such that the Systems can be returned to its pre-Emergency SOLs or IROLs condition, the energy deficient Balancing Authority shall request the Reliability Coordinator to downgrade the alert level.
  - **3.4.1** Notification of other parties. Upon notification from the energy deficient Balancing Authority that an alert has been downgraded, the Reliability Coordinator shall notify the neighboring Reliability Coordinators (via the RCIS), Balancing Authorities and Transmission Operators that its Systems can be returned to its normal limits.

**Alert 0 - Termination.** When the energy deficient Balancing Authority is able to meet its Load and Operating Reserve requirements, it shall request its Reliability Coordinator to terminate the EEA.

**3.4.2** Notification. The Reliability Coordinator shall notify all other Reliability Coordinators via the RCIS of the termination. The Reliability Coordinator shall also notify the neighboring Balancing Authorities and Transmission Operators.

### Appendix QC-EOP-011-2 Specific provisions applicable in Québec for standard EOP-011-2 Standard EOP-011-2 — Emergency Preparedness and Operations

This appendix establishes specific provisions for the application of the standard in Québec. Provisions of the standard and of its appendix must be read together for the purposes of understanding and interpretation. Where the standard and appendix differ, the appendix shall prevail.

### A. Introduction

- **1. Title:** No specific provisions.
- **2.** Number: No specific provisions.
- **3. Purpose:** No specific provisions.

### 4. Applicability:

### 4.1. Functions:

No specific provisions.

### 4.2. Facilities:

For the purpose of this standard, the term "generating unit" means all Main Transmission System (RTP) generators.

### 5. Effective Date:

5.1.	Adoption of the standard by the Régie de l'énergie:	March 30 , 2023

- **5.2.** Adoption of the appendix by the Régie de l'énergie: March 30, 2023
- **5.3.** Effective date of the standard and its appendix in Québec: October 1, 2024

### B. Requirements and Measures

No specific provisions.

### **C.** Compliance

### 1. Compliance Monitoring Process

### **1.1.** Compliance Enforcement Authority

The Régie de l'énergie is responsible, in Québec, for compliance monitoring with respect to the Reliability Standard and its appendix that it adopts.

### **1.2.** Evidence Retention

Erratum correction: In addition to the information detailed in this subsection of the Reliability Standard, the following data or evidence shall also be kept: The Generator Owner or Generator Operator shall keep data or evidence to show compliance for three years or since its last compliance audit, whichever timeframe is greater, unless directed by its Compliance Enforcement Authority to retain specific evidence for a longer period of time as part of an investigation, for Requirement R8 and Measure M8.

### **1.3.** Compliance Monitoring and Enforcement Program

The Régie de l'énergie establishes the monitoring processes used to evaluate data or information for the purpose of determining compliance or non-compliance with the Reliability Standard and with this appendix.

Erratum correction: The first sentence of this section in the Reliability Standard should be removed as it refers to data or evidence to be kept in subsection C1.2 "Evidence Retention".

### **Violation Severity Levels**

No specific provisions.

### **D.** Regional Differences

No specific provisions.

### E. Interpretation

No specific provisions.

## F. Associated Documents

No specific provisions.

### Attachment 1 -EOP-011-2

No specific provisions.

### **Revision History**

Version	Date	Action	Change Tracking
1	March 30 , 2023	New appendix as per decision D-2023-040.	New

# **A. Introduction**

- 1. Title: Reliability Coordinator Data Specification and Collection
- **2. Number:** IRO-010-4
- 3. Purpose: To prevent instability, uncontrolled separation, or Cascading outages that adversely impact reliability, by ensuring the Reliability Coordinator has the data it needs to monitor and assess the operation of its Reliability Coordinator Area.
- 4. Applicability
  - 4.1. Reliability Coordinator
  - 4.2. Balancing Authority
  - 4.3. Generator Owner
  - 4.4. Generator Operator
  - 4.5. Transmission Operator
  - 4.6. Transmission Owner
  - 4.7. Distribution Provider
- 5. Effective Date: See Implementation Plan for Project 2019-06.

## **B. Requirements**

- R1. The Reliability Coordinator shall maintain a documented specification for the data necessary for it to perform its Operational Planning Analyses, Real-time monitoring, and Real-time Assessments. The data specification shall include but not be limited to: (Violation Risk Factor: Low) (Time Horizon: Operations Planning)
  - **1.1.** A list of data and information needed by the Reliability Coordinator to support its Operational Planning Analyses, Real-time monitoring, and Real-time Assessments including non-BES data and external network data, as deemed necessary by the Reliability Coordinator.
  - **1.2.** Provisions for notification of current Protection System and Remedial Action Scheme (RAS) status or degradation that impacts System reliability.
  - **1.3.** Provisions for notification of BES generating unit(s) during local forecasted cold weather to include:
    - 1.3.1 Operating limitations based on:
      - 1.3.1.1. capability and availability;
      - 1.3.1.2. fuel supply and inventory concerns;
      - **1.3.1.3.** fuel switching capabilities; and
      - 1.3.1.4. environmental constraints

- **1.3.2.** Generating unit(s) minimum:
  - 1.3.2.1. design temperature; or
  - **1.3.2.2.** historical operating temperature; or

**1.3.2.3.** current cold weather performance temperature determined by an engineering analysis.

- **1.4.** A periodicity for providing data.
- **1.5.** The deadline by which the respondent is to provide the indicated data.
- M1. The Reliability Coordinator shall make available its dated, current, in force documented specification for data.
- **R2.** The Reliability Coordinator shall distribute its data specification to entities that have data required by the Reliability Coordinator's Operational Planning Analyses, Real-time monitoring, and Real-time Assessments. (*Violation Risk Factor: Low*) (*Time Horizon: Operations Planning*)
- M2. The Reliability Coordinator shall make available evidence that it has distributed its data specification to entities that have data required by the Reliability Coordinator's Operational Planning Analyses, Real-time monitoring, and Real-time Assessments. This evidence could include but is not limited to web postings with an electronic notice of the posting, dated operator logs, voice recordings, postal receipts showing the recipient, date and contents, or e-mail records.
- **R3.** Each Reliability Coordinator, Balancing Authority, Generator Owner, Generator Operator, Transmission Operator, Transmission Owner, and Distribution Provider receiving a data specification in Requirement R2 shall satisfy the obligations of the documented specifications using: (*Violation Risk Factor: Medium*) (*Time Horizon: Operations Planning, Same-Day Operations, Real-time Operations*)
  - 3.1. A mutually agreeable format
  - 3.2. A mutually agreeable process for resolving data conflicts
  - 3.3. A mutually agreeable security protocol
- M3. The Reliability Coordinator, Balancing Authority, Generator Owner, Generator Operator, Reliability Coordinator, Transmission Operator, Transmission Owner, and Distribution Provider receiving a data specification in Requirement R2 shall make available evidence that it satisfied the obligations of the documented specification using the specified criteria. Such evidence could include but is not limited to electronic or hard copies of data transmittals or attestations of receiving entities.

# **C.** Compliance

### 1. Compliance Monitoring Process

- **1.1. Compliance Enforcement Authority:** "Compliance Enforcement Authority" (CEA) means NERC or the Regional Entity, or any entity as otherwise designated by an Applicable Governmental Authority, in their respective roles of monitoring and/or enforcing compliance with the mandatory and enforceable Reliability Standards in their respective jurisdictions.
- **1.2.** Evidence Retention: The following evidence retention period(s) identify the period of time an entity is required to retain specific evidence to demonstrate compliance. For instances where the evidence retention period specified below is shorter than the time since the last audit, the CEA may ask an entity to provide other evidence to show that it was compliant for the full-time period since the last audit.

The Reliability Coordinator, Balancing Authority, Generator Owner, Generator Operator, Transmission Operator, Transmission Owner, and Distribution Provider shall each keep data or evidence to show compliance as identified below unless directed by its Compliance Enforcement Authority to retain specific evidence for a longer period of time as part of an investigation:

The Reliability Coordinator shall retain its dated, current, in force documented specification for the data necessary for it to perform its Operational Planning Analyses, Real-time monitoring, and Real-time Assessments for Requirement R1, Measure M1 as well as any documents in force since the last compliance audit.

The Reliability Coordinator shall keep evidence for three calendar years that it has distributed its data specification to entities that have data required by the Reliability Coordinator's Operational Planning Analyses, Real-time monitoring, and Real-time Assessments for Requirement R2, Measure M2.

Each Reliability Coordinator, Balancing Authority, Generator Owner, Generator Operator, Transmission Operator, Transmission Owner, and Distribution Provider receiving a data specification shall retain evidence for the most recent 90-calendar days that it has satisfied the obligations of the documented specifications in accordance with Requirement R3 and Measurement M3.

### **1.3.** Compliance Monitoring and Enforcement Program:

As defined in the NERC Rules of Procedure, "Compliance Monitoring and Enforcement Program" refers to the identification of the processes that will be used to evaluate data or information for the purpose of assessing performance or outcomes with the associated reliability standard.

# **Violation Severity Levels**

R#	Time	VRF		Violation Seve	rity Levels	
	Horizon		Lower	Moderate	High	Severe
R1	Operations Planning	Low	The Reliability Coordinator did not include two or fewer of the parts (Part 1.1 through Part 1.5) of the documented specification for the data necessary for it to perform its Operational Planning Analyses, Real-time monitoring, and Real- time Assessments.	The Reliability Coordinator did not include three of the parts (Part 1.1 through Part 1.5) of the documented specification for the data necessary for it to perform its Operational Planning Analyses, Real-time monitoring, and Real-time Assessments.	The Reliability Coordinator did not include four of the parts (Part 1.1 through Part 1.5) of the documented specification for the data necessary for it to perform its Operational Planning Analyses, Real-time monitoring, and Real-time Assessments.	The Reliability Coordinator did not include any of the parts (Part 1.1 through Part 1.5) of the documented specification for the data necessary for it to perform its Operational Planning Analyses, Real-time monitoring, and Real-time Assessments. OR, The Reliability Coordinator did not have a documented specification for the data necessary for it to perform its
						Operational Planning Analyses, Real-time

R#	Time	VRF		Violation Severity Levels				
	Horizon		Lower	Moderate	High	Severe		
						monitoring, and Real-time Assessments.		
left u	ntil you find th	e situation th	ly, the intent of the SDT is to nat fits. In this manner, the N y to inform, the intent is tha	/SL will not be discrimina	itory by size of entity.			
R2	Operations Planning	Low	The Reliability Coordinator did not distribute its data specification as developed in Requirement R1 to one entity, or 5% or less of the entities, whichever is greater, that have data required by the Reliability Coordinator's Operational Planning Analyses, Real-time monitoring, and Real- time Assessments.	The Reliability Coordinator did not distribute its data specification as developed in Requirement R1 to two entities, or more than 5% and less than or equal to 10% of the reliability entities, whichever is greater, that have data required by the Reliability Coordinator's Operational Planning Analyses, and Real- time monitoring, and	The Reliability Coordinator did not distribute its data specification as developed in Requirement R1 to three entities, or more than 10% and less than or equal to 15% of the reliability entities, whichever is greater, that have data required by the Reliability Coordinator's Operational Planning Analyses, Real-time	The Reliability Coordinator did not distribute its data specification as developed in Requirement R1 to four or more entities, or more than 15% of the entities, whichever is greater, that have data required by the Reliability Coordinator's Operational Planning Analyses, Real-time monitoring, and		

R#	Time	VRF	Violation Severity Levels			
	Horizon		Lower	Moderate	High	Severe
				Real-time Assessments.	Real-time Assessments.	Real-time Assessments.
R3	Operations Planning, Same-Day Operations, Real-time Operations	Medium	The responsible entity receiving a data specification in Requirement R2 satisfied the obligations of the documented specifications for data but failed to follow one of the criteria shown in Parts 3.1 – 3.3.	The responsible entity receiving a data specification in Requirement R2 satisfied the obligations of the documented specifications for data but failed to follow two of the criteria shown in Parts 3.1 – 3.3.	The responsible entity receiving a data specification in Requirement R2 satisfied the obligations of the documented specifications for data but failed to follow any of the criteria shown in Parts 3.1 – 3.3.	The responsible entity receiving a data specification in Requirement R2 did not satisfy the obligations of the documented specifications for data.

# **D. Regional Variances**

None

**E.** Interpretations

None

# F. Associated Documents

None

# **Version History**

Version	Date	Action	Change Tracking
1	October 17, 2008	Adopted by Board of Trustees	New
1a	August 5, 2009	Added Appendix 1: Interpretation of R1.2 and R3 as approved by Board of Trustees	Addition
1a	March 17, 2011	Order issued by FERC approving IRO- 010-1a (approval effective 5/23/11)	
1a	November 19, 2013	Updated VRFs based on June 24, 2013 approval	
2	April 2014	Revisions pursuant to Project 2014-03	
2	November 13, 2014	Adopted by NERC Board of Trustees	Revisions under Project 2014-03
2	November 19, 2015	FERC approved IRO-010-2. Docket No. RM15-16-000	
3	February 6, 2020	Adopted by NERC Board of Trustees	Revisions under Project 2017-07
4	TBD	Adopted by NERC Board of Trustees	Revisions under Project 2019-06 Cold Weather
3	October 30, 2020	FERC approved IRO-010-2. Docket No. RD20-4-000	
4	June 11, 2021	Adopted by NERC Board of Trustees	Revisions under Project 2019-06
4	August 24,2021	FERC approved IRO-010-4 Docket No. RD21-5-000	
4	August 24, 2021	Effective Date	4/1/2023

## Appendix IRO-010-4-QC-1 Specific provisions applicable in Québec for standard IRO-010-4 IRO-010-4 Reliability Coordinator Data Specification and Collection

This appendix establishes specific provisions for the application of the standard in Québec. Provisions of the standard and of this appendix must be read jointly for the comprehension and interpretation purposes. Where the standard and appendix differ, the appendix shall prevail.

## A. Introduction

- 1. Title: No specific provision.
- **2. Number:** No specific provision.
- **3. Purpose:** No specific provision.
- 4. Applicability :

### **Functional Entities**

No specific provision.

### Facilities

This standard applies to the facilities of the Main Transmission System (RTP) and, for requirement R1, to the facilities designated under this requirement.

- 5. Effective Date :
  - **5.1.** Adoption of the standard by the Régie de l'énergie: March 30, 2023
  - **5.2.** Adoption of the appendix by the Régie de l'énergie: March 30, 2023
  - 5.3. Effective date of the standard and of its appendix in Québec: October 1, 2024

### **B.** Requirements

**Specific provision applicable to requirement R1 (1.1):** The expression "non BES" is replaced by "non RTP".

### Specific provisions applicable to requirement R1 (1.3):

The expression "BES" is replaced by "RTP".

### **C.** Compliance

### 1. Compliance Monitoring Process

### 1.1. Compliance Enforcement Authority

In Québec, "Compliance Enforcement Authority" means the Régie de l'énergie in its roles of monitoring and enforcing compliance with respect to the Reliability Standard and to this appendix.

### **1.2.** Evidence Retention

No specific provision

## **1.3.** Compliance Monitoring and Enforcement Program:

The Régie de l'énergie establishes the monitoring processes used to evaluate data or information for the purpose of determining compliance or non-compliance with the Reliability Standard and with this appendix.

### Appendix IRO-010-4-QC-1 Specific provisions applicable in Québec for standard IRO-010-4 IRO-010-4 Reliability Coordinator Data Specification and Collection

## **Violation Severity Levels**

No specific provision.

## **D.** Regional Variances

No specific provision.

## E. Interpretations

No specific provision.

# F. Associated Documents

No specific provision.

### **Version History**

Revision Date		Action	Change Tracking
1	March 30, 2023	New appendix as per decision D-2023-040.	New

# **A.** Introduction

- 1. Title: Operational Reliability Data
- 2. Number: TOP-003-5
- **3. Purpose:** To ensure that the Transmission Operator and Balancing Authority have data needed to fulfill their operational and planning responsibilities.
- 4. Applicability:
  - 4.1. Transmission Operator
  - 4.2. Balancing Authority
  - 4.3. Generator Owner
  - **4.4.** Generator Operator
  - 4.5. Transmission Owner
  - **4.6.** Distribution Provider
- 5. Effective Date: See Implementation Plan for Project 2019-06.

## **B.** Requirements and Measures

- **R1.** Each Transmission Operator shall maintain a documented specification for the data necessary for it to perform its Operational Planning Analyses, Real-time monitoring, and Real-time Assessments. The data specification shall include, but not be limited to: [Violation Risk Factor: Lower] [Time Horizon: Operations Planning]
  - **1.1.** A list of data and information needed by the Transmission Operator to support its Operational Planning Analyses, Real-time monitoring, and Real-time Assessments including non-BES data and external network data as deemed necessary by the Transmission Operator.
  - **1.2.** Provisions for notification of current Protection System and Remedial Action Scheme (RAS) status or degradation that impacts System reliability.
  - **1.3.** Provisions for notification of BES generating unit(s) during local forecasted cold weather to include:
    - **1.3.1.** Operating limitations based on:
      - **1.3.1.1.** capability and availability;
      - **1.3.1.2.** fuel supply and inventory concerns;
      - **1.3.1.3.** fuel switching capabilities; and
      - **1.3.1.4.** environmental constraints
    - **1.3.2.** Generating unit(s) minimum:
      - **1.3.2.1.** design temperature; or

- **1.3.2.2.** historical operating temperature; or
- **1.3.2.3.** current cold weather performance temperature determined by an engineering analysis.
- **1.4.** A periodicity for providing data.
- **1.5.** The deadline by which the respondent is to provide the indicated data.
- **M1.** Each Transmission Operator shall make available its dated, current, in force documented specification for data.
- **R2.** Each Balancing Authority shall maintain a documented specification for the data necessary for it to perform its analysis functions and Real-time monitoring. The data specification shall include, but not be limited to: [Violation Risk Factor: Lower] [Time Horizon: Operations Planning]
  - **2.1.** A list of data and information needed by the Balancing Authority to support its analysis functions and Real-time monitoring.
  - **2.2.** Provisions for notification of current Protection System and Remedial Action Scheme status or degradation that impacts System reliability.
  - **2.3.** Provisions for notification of BES generating unit(s) status during local forecasted cold weather to include:
    - **2.3.1.** Operating limitations based on:
      - **2.3.1.1.** capability and availability;
      - **2.3.1.2.** fuel supply and inventory concerns;
      - 2.3.1.3. fuel switching capabilities; and
      - **2.3.1.4.** environmental constraints.
    - **2.3.2.** Generating unit(s) minimum:
      - **2.3.2.1.** design temperature; or
      - **2.3.2.2.** historical operating temperature; or
      - **2.3.2.3.** current cold weather performance temperature determined by an engineering analysis.
  - **2.4.** A periodicity for providing data.
  - **2.5.** The deadline by which the respondent is to provide the indicated data.
- **M2.** Each Balancing Authority shall make available its dated, current, in force documented specification for data.
- **R3.** Each Transmission Operator shall distribute its data specification to entities that have data required by the Transmission Operator's Operational Planning Analyses, Real-time monitoring, and Real-time Assessments. [Violation Risk Factor: Lower] [Time Horizon: Operations Planning]

- M3. Each Transmission Operator shall make available evidence that it has distributed its data specification to entities that have data required by the Transmission Operator's Operational Planning Analyses, Real-time monitoring, and Real-time Assessments. Such evidence could include but is not limited to web postings with an electronic notice of the posting, dated operator logs, voice recordings, postal receipts showing the recipient, date and contents, or e-mail records.
- **R4.** Each Balancing Authority shall distribute its data specification to entities that have data required by the Balancing Authority's analysis functions and Real-time monitoring. [*Violation Risk Factor: Lower*] [*Time Horizon: Operations Planning*]
- M4. Each Balancing Authority shall make available evidence that it has distributed its data specification to entities that have data required by the Balancing Authority's analysis functions and Real-time monitoring. Such evidence could include but is not limited to web postings with an electronic notice of the posting, dated operator logs, voice recordings, postal receipts showing the recipient, or e-mail records.
- **R5.** Each Transmission Operator, Balancing Authority, Generator Owner, Generator Operator, Transmission Owner, and Distribution Provider receiving a data specification in Requirement R3 or R4 shall satisfy the obligations of the documented specifications using: [Violation Risk Factor: Medium] [Time Horizon: Operations Planning, Same-Day Operations, Real-time Operations]
  - 5.1. A mutually agreeable format
  - 5.2. A mutually agreeable process for resolving data conflicts
  - 5.3. A mutually agreeable security protocol
- **M5.** Each Transmission Operator, Balancing Authority, Generator Owner, Generator Operator, Transmission Owner, and Distribution Provider receiving a data specification in Requirement R3 or R4 shall make available evidence that it has satisfied the obligations of the documented specifications. Such evidence could include, but is not limited to, electronic or hard copies of data transmittals or attestations of receiving entities.

# **C.** Compliance

- 1. Compliance Monitoring Process
  - **1.1. Compliance Enforcement Authority:** "Compliance Enforcement Authority" (CEA) means NERC or the Regional Entity, or any entity as otherwise designated by an Applicable Governmental Authority, in their respective roles of monitoring and/or enforcing compliance with mandatory and enforceable Reliability Standards in their respective jurisdictions.
  - **1.2.** Evidence Retention: The following evidence retention period(s) identify the period of time an entity is required to retain specific evidence to demonstrate compliance. For instances where the evidence retention period specified below is shorter than the time since the last audit, the Compliance Enforcement Authority may ask an entity to provide other evidence to show that it was compliant for the full time period since the last audit.

Each responsible entity shall keep data or evidence to show compliance as identified below unless directed by its Compliance Enforcement Authority to retain specific evidence for a longer period of time as part of an investigation:

Each Transmission Operator shall retain its dated, current, in force, documented specification for the data necessary for it to perform its Operational Planning Analyses, Real-time monitoring, and Real-time Assessments in accordance with Requirement R1 and Measurement M1 as well as any documents in force since the last compliance audit.

Each Balancing Authority shall retain its dated, current, in force, documented specification for the data necessary for it to perform its analysis functions and Real-time monitoring in accordance with Requirement R2 and Measurement M2 as well as any documents in force since the last compliance audit.

Each Transmission Operator shall retain evidence for three calendar years that it has distributed its data specification to entities that have data required by the Transmission Operator's Operational Planning Analyses, Real-time monitoring, and Real-time Assessments in accordance with Requirement R3 and Measurement M3.

Each Balancing Authority shall retain evidence for three calendar years that it has distributed its data specification to entities that have data required by the Balancing Authority's analysis functions and Real-time monitoring in accordance with Requirement R4 and Measurement M4.

Each Balancing Authority, Generator Owner, Generator Operator, Transmission Operator, Transmission Owner, and Distribution Provider receiving a data specification in Requirement R3 or R4 shall retain evidence for the most recent 90-calendar days that it has satisfied the obligations of the documented specifications in accordance with Requirement R5 and Measurement M5. **1.3.** Compliance Monitoring and Enforcement Program: As defined in the NERC Rules of Procedure, "Compliance Monitoring and Enforcement Program" refers to the identification of the processes that will be used to evaluate data or information for the purpose of assessing performance or outcomes with the associated reliability standard.

# **Violation Severity Levels**

R # Time Horizor		VRF	Violation Severity Levels			
			Lower VSL	Moderate VSL	High VSL	Severe VSL
R1	Operations Planning	Lower	The Transmission Operator did not include two or fewer of the parts (Part 1.1 through Part 1.5) of the documented specification for the data necessary for it to perform its Operational Planning Analyses, Real-time monitoring, and Real- time Assessments.	The Transmission Operator did not include three of the parts (Part 1.1 through Part 1.5) of the documented specification for the data necessary for it to perform its Operational Planning Analyses, Real-time monitoring, and Real- time Assessments.	The Transmission Operator did not include four of the parts (Part 1.1 through Part 1.5) of the documented specification for the data necessary for it to perform its Operational Planning Analyses, Real-time monitoring, and Real- time Assessments.	The Transmission Operator did not include any of the parts (Part 1.1 through Part 1.5) of the documented specification for the data necessary for it to perform its Operational Planning Analyses, Real-time monitoring, and Real- time Assessments. OR,

R #	Time Horizon	VRF	Violation Severity Levels				
			Lower VSL	Moderate VSL	High VSL	Severe VSL	
R2	Operations Planning	Lower	The Balancing Authority did not include two or fewer of the parts (Part 2.1 through Part 2.5) of the documented specification for the data necessary for it to perform its analysis functions and Real- time monitoring.	The Balancing Authority did not include three of the parts (Part 2.1 through Part 2.5) of the documented specification for the data necessary for it to perform its analysis functions and Real- time monitoring.	The Balancing Authority did not include four of the parts (Part 2.1 through Part 2.5) of the documented specification for the data necessary for it to perform its analysis functions and Real- time monitoring.	The Balancing Authority did not include any of the parts (Part 2.1 through Part 2.5) of the documented specification for the data necessary for it to perform its analysis functions and Real- time monitoring. OR, The Balancing Authority did not have a documented specification for the data necessary for it to perform its analysis functions and Real- time monitoring.	
For the Requirement R3 and R4 VSLs only, the intent of the SDT is to start with the Severe VSL first and then to work your way the left until you find the situation that fits. In this manner, the VSL will not be discriminatory by size of entity. If a small entity has just one affected reliability entity to inform, the intent is that that situation would be a Severe violation.							
R3	Operations Planning	Lower	The Transmission Operator did not distribute its data	The Transmission Operator did not distribute its data	The Transmission Operator did not distribute its data	The Transmission Operator did not distribute its data	

R #	Time Horizon	VRF	Violation Severity Levels			
			Lower VSL	Moderate VSL	High VSL	Severe VSL
			specification to one entity, or 5% or less of the entities, whichever is greater, that have data required by the Transmission Operator's Operational Planning Analyses, Real-time monitoring, and Real- time Assessments.	specification to two entities, or more than 5% and less than or equal to10% of the reliability entities, whichever is greater, that have data required by the Transmission Operator's Operational Planning Analyses, Real-time monitoring, and Real- time Assessments.	specification to three entities, or more than 10% and less than or equal to 15% of the reliability entities, whichever is greater, that have data required by the Transmission Operator's Operational Planning Analyses, Real-time monitoring, and Real- time Assessments.	specification to four or more entities, or more than 15% of the entities that have data required by the Transmission Operator's Operational Planning Analyses, Real-time monitoring, and Real- time Assessments.
R4	Operations Planning	Lower	The Balancing Authority did not distribute its data specification to one entity, or 5% or less of the entities, whichever is greater, that have data required by the Balancing Authority's analysis functions and Real-time monitoring.	The Balancing Authority did not distribute its data specification to two entities, or more than 5% and less than or equal to 10% of the entities, whichever is greater, that have data required by the Balancing Authority's analysis functions and Real-time monitoring.	The Balancing Authority did not distribute its data specification to three entities, or more than 10% and less than or equal to 15% of the entities, whichever is greater, that have data required by the Balancing Authority's analysis functions and Real-time monitoring.	The Balancing Authority did not distribute its data specification to four or more entities, or more than 15% of the entities that have data required by the Balancing Authority's analysis functions and Real-time monitoring.

R #	Time Horizon	VRF		Violation Severity Levels			
			Lower VSL	Moderate VSL	High VSL	Severe VSL	
R5	Operations Planning, Same-Day Operations, Real-time Operations	Medium	The responsible entity receiving a data specification in Requirement R3 or R4 satisfied the obligations in the data specification but did not meet one of the criteria shown in Requirement R5 (Parts 5.1 – 5.3).	The responsible entity receiving a data specification in Requirement R3 or R4 satisfied the obligations in the data specification but did not meet two of the criteria shown in Requirement R5 (Parts 5.1 – 5.3).	The responsible entity receiving a data specification in Requirement R3 or R4 satisfied the obligations in the data specification but did not meet three of the criteria shown in Requirement R5 (Parts 5.1 – 5.3).	The responsible entity receiving a data specification in Requirement R3 or R4 did not satisfy the obligations of the documented specifications for data.	

# **D. Regional Variances**

None.

**E.** Interpretations

None.

# F. Associated Documents

None.

# **Version History**

Version	Date	Action	Change Tracking
0	April 1, 2005	Effective Date	New
0	August 8, 2005	Removed "Proposed" from Effective Date	Errata
1		Modified R1.2 Modified M1 Replaced Levels of Non-compliance with the Feb 28, BOT approved Violation Severity Levels (VSLs)	Revised
1	October 17, 2008	Adopted by NERC Board of Trustees	
1	March 17, 2011	Order issued by FERC approving TOP- 003-1 (approval effective 5/23/11)	
2	May 6, 2012	Revised under Project 2007-03	Revised
2	May 9, 2012	Adopted by Board of Trustees	Revised
3	April 2014	Changes pursuant to Project 2014-03	Revised
3	November 13, 2014	Adopted by Board of Trustees	Revisions under Project 2014-03
3	November 19, 2015	FERC approved TOP-003-3. Docket No. RM15-16-000, Order No. 817	
4	February 6, 2020	Adopted by NERC Board of Trustees	Revisions under Project 2017-07
4	June 11, 2021	Board approved	Project 2019-06 Cold Weather

4	August 24, 2021	FERC approved TOP –003-5 Docket No. RD21-5-000, Order	
4	August 24, 2021	Effective Date	4/1/2023

This appendix establishes specific provisions for the application of the standard in Québec. Provisions of the standard and of this appendix must be read together jointly for comprehension and interpretation purposes. Where the standard and appendix differ, the appendix shall prevail.

## A. Introduction

- 1. Title: No specific provision.
- **2. Number:** No specific provision.
- **3. Purpose:** No specific provision.
- 4. Applicability:

### **Functional Entities**

No specific provision.

### Facilities

This standard applies to the facilities of the Main Transmission System (RTP) and, for the requirements R1 and R2, to the facilities designated under this requirement.

### 5. Effective Date:

5.1.	Adoption of the standard by the Régie de l'énergie:	March 30, 2023
5.2.	Adoption of the appendix by the Régie de l'énergie:	March 30, 2023
5.3.	Effective date of the standard and of its appendix in Québec:	October 1, 2024

### **B.** Requirements and Measures

**Specific provisions applicable to requirement R1 (1.1):** The expression "non BES" is replaced by "non RTP".

**Specific provisions applicable to requirements R1 & R2 (1.3 and 2.3):** The expression "BES" is replaced by "RTP".

### C. Compliance

### 1. Compliance Monitoring Process

### 1.1. Compliance Monitoring Process

In Québec, "Compliance Enforcement Authority" means the Régie de l'énergie in its roles of monitoring and enforcing compliance with respect to the Reliability Standard and to this appendix.

### **1.2.** Evidence Retention

No specific provision

### 1.3. Compliance Monitoring and Enforcement Program

The Régie de l'énergie establishes the monitoring processes used to evaluate data or information for the purpose of determining compliance or non-compliance with the Reliability Standard and with this appendix.

### **Violation Severity Levels**

No specific provision.

## **D.** Regional Variances

No specific provision.

## E. Interpretations

No specific provision.

## F. Associated Documents

No specific provision.

## Version history

Version	Date	Action	Change Tracking
1	March 30, 2023	New appendix as per decision D-2023-040.	New