

**Registre des entités visées par les normes de
fiabilité en suivi de la décision D-2024-010 en
suivi des modifications
(version anglaise)**



Reliability Coordinator in Québec

Register of Entities Subject to Reliability Standards

Filed ~~December 19, 2023~~ February 27, 2024



Table of Contents

1. PURPOSE OF REGISTER	3
2. ENTITIES SUBJECT TO RELIABILITY STANDARDS	3
3. IDENTIFICATION OF MAIN TRANSMISSION SYSTEM ELEMENTS	5
APPENDIX A – ENTITIES	7
APPENDIX B – TRANSMISSION FACILITIES	13
APPENDIX C – GENERATING FACILITIES	27
APPENDIX D – APPLICATION OF THE CIP STANDARDS (VERSION 5)	30
APPENDIX E – RAS	31
VERSION HISTORY	33



1. PURPOSE OF REGISTER

The Register of Entities Subject to Reliability Standards (the Register) identifies the entities subject to Reliability Standards adopted by the Régie de l'énergie (the Régie).¹

In accordance with Régie decisions, the Register also identifies the NERC Reliability Functional Model functions these entities perform in order to establish the Reliability Standards to which they are subject. In addition, the Register identifies facilities that these entities own or operate, as well as other characteristics relevant to the application of the Reliability Standards.²

2. ENTITIES SUBJECT TO RELIABILITY STANDARDS

The applicability of the Reliability Standards and their Québec appendices are based upon the NERC functional model and on the identification of the facilities of the Main Transmission System (RTP). The functions are defined in the Glossary of Terms and Acronyms used in Reliability Standards adopted by the Régie. The following list gives the functions relevant to the Reliability Standards and Québec appendices adopted by the Régie and additional details regarding their scope in Québec:

- **Reliability Coordinator (RC):** The entity responsible for maintaining system reliability in Real Time within its area (i.e., the Québec Interconnection). The reliability coordinator in Québec is designated by the Régie in accordance with section 85.5 of the Act.
- **Balancing Authority (BA):** The entity responsible for maintaining generation/Load balance, and thus ensuring frequency stability, within the entire Québec Interconnection. In Québec, the BA area matches the RC and TOP areas; the three functions are performed by a single entity.
- **Transmission Operator (TOP):** The entity responsible for the Reliable Operation of the Transmission facilities within its area. In Québec, the TOP area matches the RC and BA areas; the three functions are performed by a single entity.
- **Transmission Owner (TO):** In Québec, the owner of an RTP Transmission facility.
- **Generator Operator (GOP):** In Québec, the operator of an RTP generating facility.
- **Generator Owner (GO):** In Québec, the owner of an RTP generating facility.

¹ *Act respecting the Régie de l'énergie* (R.S.Q., c R-6.01), section 85.13. (1) "The reliability coordinator must submit to the Régie, for approval, a register identifying the entities that are subject to the reliability standards adopted by the Régie; ..."

² Decision D-2011-068, p. 43, par. 175.



Reliability Coordinator in Québec

- **Planning Authority (PA) or Planning Coordinator (PC):** The entity responsible for Transmission System planning for the entire Québec Interconnection.
- **Transmission Planner (TP):** In Québec, the PA and TP functions are performed by the same entity; the TP area is the same as the PA area and the responsibilities for the two functions are basically the same.
- **Transmission Service Provider (TSP):** Entity that provides an OATT-type Transmission service.
- **Resource Planner (RP):** The entity responsible for developing a long-term supply plan designed to meet the total power Demand of the Québec Interconnection.
- **Load-Serving Entity (LSE):** In Québec, only one entity performs LSE functions.
- **Distribution Provider (DP):** A distributor with a peak capacity of over 75 MW, whose facilities are connected to an electric power Transmission System, regardless of its nature (i.e., main or regional transmission system).
 - **UFLS-Only Distribution Provider (UFLS-Only DP):** UFLS-Only DP is a Distribution Provider that is the responsible entity that owns, controls, or operates Underfrequency Load Shedding Protection System(s) needed to implement a required Underfrequency Load Shedding Program designed for the protection of the Bulk Electric System, but that does not meet any of the other criteria for registration as a Distribution Provider. In Québec, no entity meets the registration criteria of a UFLS-Only DP.

In addition, for applicability purposes, the Register identifies the following characteristics for each entity:

- Owner or operator of an RTP facility
- Owner or operator of a Bulk Power System facility
- Owner or operator of power Transmission Lines operated at 200 kV or more
- Owner or operator of a facility or equipment required for System restoration
- Owner or operator of a Remedial Action Scheme (RAS)
- Owner or operator of Undervoltage Load Shedding Program
- Owner or operator of under-frequency load shedding programs
- Owner of generation facilities for industrial use

The Registered Entities subject to Reliability Standards in Québec are identified in Appendix A. Appendix A also specifies the functions and other characteristics useful for specifying the scope and application of the Reliability Standards to Registered Entities. The other appendices identify facilities and other characteristics necessary for the application of the Reliability Standards in effect in Québec.



Reliability Coordinator in Québec

3. IDENTIFICATION OF MAIN TRANSMISSION SYSTEM ELEMENTS

In its Decision D-2023-128, the Régie issued a positive decision regarding the Main Transmission System Identification Methodology (the “RTP Methodology”).

The implementation of the RTP Methodology is done in multiple steps, which are detailed in the RTP Methodology Implementation Plan available at the following link:

<https://www.hydroquebec.com/data/transenergie/pdf/implementation-plan-rtp-en.pdf>

Code de champ modifié

The Coordinator shall make available to Registered Entities the documentation related to the RTP Methodology on its website at the following webpage:

<https://www.hydroquebec.com/reliability-coordinator/documentation/main-transmission-system.html>

Code de champ modifié

APPENDIX A – ENTITIES

Entity	Acronym	Address	Functions													The entity owns and/or operates					Notes	
			RC	BA	TOP	TO	GOP	GO	PA	TP	TSP	RP	LSE	DP	Facilities classified as RTP	Facilities classified as Bulk Transmission Lines operated at 200 kV or above	Facility/equipment required for system restoration ³	RAS ^{3,4}	Undervoltage Load Shedding Program (DST) (owns/operates) ³	Underfrequency load shedding program (DSF) (owns/operates) ³		
Innergex Cartier Énergie S.E.C. L'Anse-à-Valleau wind farm	AAV	1225 Saint-Charles Ouest, 10e étage, Longueuil, Qc, J4K 0B9					GOP	GO							Y	N	N	<i>n</i>	<i>n</i>	<i>n/n</i>	<i>n/n</i>	
Innergex Inc. Baie-des-Sables wind farm	BDS	1225 Saint-Charles Ouest, 10e étage, Longueuil, Qc, J4K 0B9					GOP	GO							Y	N	N	<i>n</i>	<i>n</i>	<i>n/n</i>	<i>n/n</i>	

a mis en forme : Exposant
a mis en forme : Exposant
a mis en forme le tableau

³ The data in this column is presented for informational purposes only and is not to be used in determining the applicability of Reliability Standards or the monitoring of these standards. To differentiate this column from the other columns, which are normative, the background color is grayish, and the information is in lowercase italics.

a mis en forme : Anglais (Canada)

⁴ In its decision D-2020-118, the Régie adopted a new definition of the term RAS which removes the distinction between RAS classes I, II and III, as defined by NPCC. As of this decision, certain Type III RAS as well as RAS that are not categorized by NPCC are subject to the NERC Reliability Standards adopted and enforced by the Régie since they are part of the new definition of the term RAS. In particular, standard PRC-012-2, adopted in decision D-2020-167, stipulates that any TO, GO or DP can own a RAS, and standards PRC-005-6 and PRC-012-2 require owners of these RAS to identify their RAS. It remains, however, the Registered Entity's responsibility to demonstrate whether or not it owns a RAS. Consequently, the data in this column is presented for informational purposes only and is not to be used in determining the applicability of standards or the monitoring of standards. To differentiate this column from the other columns, which are normative, the background color has been altered and the information is in lowercase italics.

a mis en forme : Anglais (Canada)

Reliability Coordinator in Québec

Entity	Acronym	Address	Functions													The entity owns and/or operates				Notes	
			R C	BA	TO P	TO	GO P	G O	PA	T P	TS P	R P	LSE	DP	Facilities classified as RTP	Facilities classified as Bulk Transmission Lines operated at 200 kV or above	Facility/equipment required for system restoration ¹	RAS ^{3,4}	Undervoltage Load Shedding Program (DST) (owns/operates) ³		Underfrequency load shedding program (DSF) (owns/operates) ³
Innergex Cartier Énergie S.E.C. Carleton wind farm	CAR	1225 Saint-Charles Ouest, 10e étage, Longueuil, Qc, J4K 0B9					GO P	GO							Y	N	N	N	n	N n/n	N n/n
Innergex Cartier Énergie S.E.C. Gros-Morne wind farm	GM	1225 Saint-Charles Ouest, 10e étage, Longueuil, Qc, J4K 0B9					GO P	GO							Y	N	N	N	n	N n/n	N n/n
Des Moulins Wind (Énergie éolienne Des Moulins S.E.C.)	MOU	989, Huppe, Thedford Mines, QC, G6G 6H8					GO P	GO							Y	N	N	N	n	N n/n	N n/n
EEN CA Lac Alfred S.E.C. and Enbridge Lac Alfred Wind Project S.E.C.(EDF EN Canada Inc.)	LA	1134, rue Ste-Catherine ouest, bur. 910, Montréal, QC, H3B 1H4					GO P	GO							Y	N	N	N	n	N n/n	N n/n
EEN CA Massif-Du-Sud S.E.C. and Enbridge Massif-Du-Sud Wind Project S.E.C. (EDF EN Canada Inc.)	MDS	1134, rue Ste-Catherine ouest, bur. 910, Montréal, QC, H3B 1H4					GO P	GO							Y	N	N	N	n	N n/n	N n/n
EEN CA Mont-Rothery S.E.C. (EDF EN Canada Inc.)	ROT	1134, rue Ste-Catherine ouest, bur. 910, Montréal, QC, H3B 1H4					GO P	GO							Y	N	N	N	n	N n/n	N n/n

a mis en forme : Expositant

a mis en forme : Expositant

Reliability Coordinator in Québec

Entity	Acronym	Address	Functions													The entity owns and/or operates					Notes
			R C	BA	TO P	TO	GO P	G O	PA	T P	TS P	R P	LSE	DP	Facilities classified as RTP	Facilities classified as Bulk Transmission Lines operated at 200 kV or above	Facility/equipment required for system restoration ¹	RAS ^{3,4}	Undervoltage Load Shedding Program (DST) (owns/operates) ³	Underfrequency load shedding program (DSF) (owns/operates) ³	
EEN CA Rivière-du-Moulin S.E.C. and Éolien DIM S.E.C. (EDF EN Canada Inc.)	RDM	1134, rue Ste-Catherine ouest, bur. 910, Montréal, QC, H3B 1H4					GO P	GO							Y	N	N	N	n	N N	N N
EEN CA Hermine Saint-Robert-Bellarmin S.E.C. and Enbridge Saint-Robert-Bellarmin Wind Project S.E.C. (EDF EN Canada Inc.)	SRB	1134, rue Ste-Catherine ouest, bur. 910, Montréal, QC, H3B 1H4					GO P	GO							Y	N	N	N	n	N N	N N
Énergie éolienne Le Plateau S.E.C. (Le Plateau I Wind)	ÉLP	42, rang de l'Église Nord, L'ascension-de-Patapédia, QC, G0J 1R0					GO P	GO							Y	N	N	N	n	N N	N N
Énergie éolienne Vents du Kempt S.E.C.	VDK	1850, avenue Panama #501, Brossard, QC, J4W 3C6					GO P	GO							Y	N	N	N	n	N N	N N
Énergie Renouvelable Brookfield (Énergie La Lièvre s.e.c.)	ÉLL	2, chemin Montréal ouest, Gatineau, QC, J8M 2E1				TO	GO P	GO					DP	Y	N	Y	N	n	N N	N N	
Éoliennes de l'Érable S.E.C.	EER	2075, rue Université, bureau 1105, Montréal, QC, H3A 2L1					GO P	GO							Y	N		N	n	N N	N N

a mis en forme : Expositant

a mis en forme : Expositant



Reliability Coordinator in Québec

Entity	Acronym	Address	Functions													The entity owns and/or operates				Notes			
			RC	BA	TOP	TO	GO P	GO	PA	TP	TSP	RP	LSE	DP	Facilities classified as RTP	Facilities classified as Bulk Transmission Lines operated at 200 kV or above	Facility/equipment required for system restoration ¹	RAS ^{3,4}	Undervoltage Load Shedding Program (DST) (owns/operates) ³		Underfrequency load shedding program (DSF) (owns/operates) ³		
Hydro-Québec, Coordonnateur de la fiabilité au Québec ⁵	HQCF	Complexe Desjardins C.P. 10000, 13 ^e étage, Montréal, QC, H5B 1H7	RC	BA	TOP										Y	Y	Y	N	y	N / N / N	N / N / N		
Hydro-Québec	HQ	75, boul. René-Lévesque Ouest, 20 ^e étage, Montréal, QC, H2Z 1A4				TO		GOP	GO	PA	TP	TSP	RP	LSE	DP	Y	Y	Y	N	y	N / N / N	N / N / N	Entity owns synchronous condensers
Kruger Énergie Montérégie S.E.C.	MON	202, boul. St-Rémi, St-Rémi, QC, J0L 1L0						GOP	GO							Y	N	N	N	n	N / N / N	N / N / N	
Northland Power Inc.	NLP	30 St Clair Ave W Toronto, ON, M4V 3A1						GOP	GO							Y	N	N	N	n	N / N / N	N / N / N	
Parcs éoliens de la Seigneurie de Beaupré	SDB	36 rue Lajeunesse Kingsey Falls, QC, J0A 1B0						GOP	GO							Y	N	N	N	n	N / N / N	N / N / N	

a mis en forme : Exposant

a mis en forme : Exposant

a mis en forme : Police :Italique

a mis en forme : Police :Italique

⁵ Per its decision D-2021-064, the Régie designated the Direction Principale – Contrôle des mouvements d’énergie et exploitation du réseau de Hydro-Québec (DPCMÉER) as the reliability coordinator in Québec.

Reliability Coordinator in Québec

Entity	Acronym	Address	Functions													The entity owns and/or operates				Notes		
			R C	BA	TO P	TO	GO P	G O	PA	T P	TS P	R P	LSE	DP	Facilities classified as RTP	Facilities classified as Bulk Transmission Lines operated at 200 kV or above	Facility/equipment required for system restoration ¹	RAS ^{3,4}	Undervoltage Load Shedding Program (DST) (owns/operates) ³		Underfrequency load shedding program (DSF) (owns/operates) ³	
Parc éolien Mesgîg Uguj's'n S.E.C.	MEU	2 Riverside West Listuguj, QC, G0C 2R0					GO P	GO							Y	N	N	n	n	n/n	n/n	
Parc éolien Mont Sainte-Marguerite S.E.C.	MSM	226, rue de l'église Saint-Séverin, QC, G0N 1V0					GO P	GO							Y	N	N	n	n	n/n	n/n	
Parc éolien Nicolas-Riou S.E.C.	NRI	1010 rue de la Gauchetière Ouest, bureau 2000, Montréal, QC, H3B 2N2					GO P	GO							Y	N	N	n	n	n/n	n/n	
Parcs éoliens Témiscouata	TEM	36 rue Lajeunesse Kingsey Falls, QC, J0A 1B0					GO P	GO							Y	N	N	n	n	n/n	n/n	
Rio Tinto Alcan	RTA	1955 boul. Mellon, édifice 100A, Saguenay, QC, G7S 4L2				TO	GO P	GO					DP	Y	N	Y	n	n	n/n	n/n	Generation facilities for industrial use	
Société de transmission électrique de Cedars Rapids Limitée	CRT	944, rue Principale, Rivière-Baudette, QC, J0P 1R0				TO						TSP		Y	N	N	n	n	n/n	n/n		

a mis en forme : Exposit

a mis en forme : Exposit

Reliability Coordinator in Québec

Entity	Acronym	Address	Functions													The entity owns and/or operates					Notes	
			R C	BA	TO P	TO	GO P	G O	PA	T P	TS P	R P	LSE	DP	Facilities classified as RTP	Facilities classified as Bulk	Transmission Lines operated at 200 kV or above	Facility/equipment required for system restoration ¹	RAS ^{3,4}	Undervoltage Load Shedding Program (DST) (owns/operates) ³		Underfrequency load shedding program (DSF) (owns/operates) ³
Société en Commandite Hydroélectrique Manicouagan	SCHM	3860, boul. Lafleche, C.P. 6056 Baie-Comeau, QC, G5C 0B7					GO P	GO						DP	Y	N	N	N	n	N N	N N	
TransCanada Québec Inc.	TCQ	7005, boul. Raoul Duchesne Becancour, QC, TG9H 4X6					GO P	GO							Y	N	N	N	n	N N	N N	
Ville de Saguenay (Hydro-Jonquière)	JON	1710, Rue Ste. Famille, C.P. 2000, Saguenay, QC, G7X 7W7												DP	N	N	N	N	n	N N	N N	
Ville de Sherbrooke (Hydro-Sherbrooke)	SHER	1800, rue Roy, C.P. 610 Sherbrooke, QC, J1H 5H9												DP	N	N	N	N	n	N N	N N	

a mis en forme : Exposant

a mis en forme : Exposant

APPENDIX B – TRANSMISSION FACILITIES

Entity	Type	Name	RTP Applicable Voltage Levels (kV)	Bulk Applicable Voltage Levels (kV)	Line operated at 200 kV or more?	Specificities
CRT	Line	CD11	120	None	N	Only the portion in Québec is covered.
CRT	Line	CD22	120	None	N	Only the portion in Québec is covered.
ÉLL	Line	D5A	230	None	Y	Only the portion in Québec is covered.
ÉLL	Line	HF1	120	None	N	Registration to the Register effective July 1, 2025.
ÉLL	Line	HF2	120	None	N	Registration to the Register effective July 1, 2025.
ÉLL	Substation	Masson Nord	120	None	-	
ÉLL	Substation	Masson Sud	230- 120	None	-	
HQ	Line	A41T	230	None	Y	Only the portion in Québec is covered.
HQ	Line	A42T	230	None	Y	Only the portion in Québec is covered.
HQ	Line	B31L	230	None	Y	Only the portion in Québec is covered.
HQ	Line	B5D	230	None	Y	Only the portion in Québec is covered.
HQ	Line	D4Z	120	None	N	Only the portion in Québec is covered.
HQ	Line	H4Z	120	None	N	Only the portion in Québec is covered.
HQ	Line	L0440	450 (DC)	450 (DC)	Y	
HQ	Line	L0450	450 (DC)	450 (DC)	Y	Registration to the Register effective July 1, 2025
HQ	Line	L0451	450 (DC)	450 (DC)	Y	Only the portion in Québec is covered.
HQ	Line	L0452	450 (DC)	450 (DC)	Y	Only the portion in Québec is covered.
HQ	Line	L0460	450 (DC)	450 (DC)	Y	Only the portion in Québec is covered.
HQ	Line	L0470	450 (DC)	450 (DC)	Y	
HQ	Line	L1108	120	None	N	
HQ	Line	L1114	120	None	N	
HQ	Line	L1256	120	120	N	



Reliability Coordinator in Québec

Entity	Type	Name	RTP Applicable Voltage Levels (kV)	Bulk Applicable Voltage Levels (kV)	Line operated at 200 kV or more?	Specificities
HQ	Line	L1257	120	120	N	
HQ	Line	L1261	120	120	N	
HQ	Line	L1291	120	120	N	
HQ	Line	L1292	120	120	N	
HQ	Line	L1325	120	None	N	Registration to the Register effective July 1, 2025.
HQ	Line	L1332	120	None	N	
HQ	Line	L1333	120	None	N	
HQ	Line	L1338	120	None	N	Registration to the Register effective July 1, 2025
HQ	Line	L1362	120	120	N	
HQ	Line	L1363	120	120	N	
HQ	Line	L1398	120	120	N	
HQ	Line	L1399	120	120	N	
HQ	Line	L1400	120	None	N	Only the portion in Québec is covered.
HQ	Line	L1429	120	None	N	Only the portion in Québec is covered.
HQ	Line	L1470	120	None	N	
HQ	Line	L1472	120	120	N	
HQ	Line	L1540	120	None	N	
HQ	Line	L1541	120	None	N	
HQ	Line	L2101	230	None	Y	Only the portion in Québec is covered.
HQ	Line	L2102	230	None	Y	Only the portion in Québec is covered.
HQ	Line	L2304	None	None	Y	
HQ	Line	L2305	None	None	Y	
HQ	Line	L2310	230	230	Y	
HQ	Line	L2317	None	None	Y	
HQ	Line	L2318	None	None	Y	
HQ	Line	L2319	230	230	Y	
HQ	Line	L2320	None	None	Y	
HQ	Line	L2324	230	230	Y	
HQ	Line	L2326	None	None	Y	
HQ	Line	L2330	None	None	Y	
HQ	Line	L2331	None	None	Y	



Reliability Coordinator in Québec

Entity	Type	Name	RTP Applicable Voltage Levels (kV)	Bulk Applicable Voltage Levels (kV)	Line operated at 200 kV or more?	Specificities
HQ	Line	L2334	None	None	Y	
HQ	Line	L2340	None	None	Y	
HQ	Line	L2341	None	None	Y	
HQ	Line	L2342	None	None	Y	
HQ	Line	L2343	None	None	Y	
HQ	Line	L2344	None	None	Y	
HQ	Line	L2345	None	None	Y	
HQ	Line	L2349	None	None	Y	
HQ	Line	L2350	None	None	Y	
HQ	Line	L2351	None	None	Y	
HQ	Line	L2352	None	None	Y	
HQ	Line	L2354	None	None	Y	
HQ	Line	L2355	None	None	Y	
HQ	Line	L2357	None	None	Y	
HQ	Line	L2358	None	None	Y	
HQ	Line	L2365	None	None	Y	
HQ	Line	L2367	None	None	Y	
HQ	Line	L2370	None	None	Y	
HQ	Line	L2371	None	None	Y	
HQ	Line	L2373	None	None	Y	
HQ	Line	L2374	None	None	Y	
HQ	Line	L2378	None	None	Y	
HQ	Line	L2380	None	None	Y	
HQ	Line	L2384	None	None	Y	
HQ	Line	L2387	None	None	Y	
HQ	Line	L2388	None	None	Y	
HQ	Line	L2389	None	None	Y	
HQ	Line	L2392	None	None	Y	
HQ	Line	L2393	None	None	Y	
HQ	Line	L2396	None	None	Y	
HQ	Line	L2397	None	None	Y	
HQ	Line	L2398	None	None	Y	
HQ	Line	L2401	None	None	Y	
HQ	Line	L2402	None	None	Y	
HQ	Line	L2404	None	None	Y	
HQ	Line	L2405	None	None	Y	



Reliability Coordinator in Québec

Entity	Type	Name	RTP Applicable Voltage Levels (kV)	Bulk Applicable Voltage Levels (kV)	Line operated at 200 kV or more?	Specificities
HQ	Line	L2407	None	None	Y	
HQ	Line	L2408	None	None	Y	
HQ	Line	L2409	None	None	Y	
HQ	Line	L3001	315	315	Y	
HQ	Line	L3002	315	315	Y	
HQ	Line	L3003	315	315	Y	
HQ	Line	L3004	315	315	Y	
HQ	Line	L3005	315	None	Y	
HQ	Line	L3007	315	315	Y	
HQ	Line	L3008	315	315	Y	
HQ	Line	L3009	315	None	Y	
HQ	Line	L3010	315	315	Y	
HQ	Line	L3011	315	None	Y	
HQ	Line	L3012	315	None	Y	
HQ	Line	L3013	315	315	Y	
HQ	Line	L3014	315	315	Y	
HQ	Line	L3015	315	None	Y	
HQ	Line	L3020	315	None	Y	
HQ	Line	L3021	315	315	Y	
HQ	Line	L3022	315	315	Y	
HQ	Line	L3023	315	315	Y	
HQ	Line	L3024	315	315	Y	
HQ	Line	L3026	315	None	Y	
HQ	Line	L3027	315	315	Y	
HQ	Line	L3028	315	315	Y	
HQ	Line	L3029	315	315	Y	
HQ	Line	L3030	315	315	Y	
HQ	Line	L3031	315	315	Y	
HQ	Line	L3032	315	315	Y	
HQ	Line	L3033	315	315	Y	
HQ	Line	L3034	315	315	Y	
HQ	Line	L3035	315	315	Y	
HQ	Line	L3036	315	315	Y	
HQ	Line	L3040	315	315	Y	
HQ	Line	L3041	315	None	Y	
HQ	Line	L3042	None	None	Y	



Reliability Coordinator in Québec

Entity	Type	Name	RTP Applicable Voltage Levels (kV)	Bulk Applicable Voltage Levels (kV)	Line operated at 200 kV or more?	Specificities
HQ	Line	L3043	None	None	Y	
HQ	Line	L3049	315	315	Y	
HQ	Line	L3052	315	315	Y	
HQ	Line	L3053	315	315	Y	
HQ	Line	L3054	315	315	Y	
HQ	Line	L3055	315	315	Y	
HQ	Line	L3056	315	315	Y	
HQ	Line	L3057	315	315	Y	
HQ	Line	L3062	315	315	Y	
HQ	Line	L3063	315	315	Y	
HQ	Line	L3067	315	315	Y	
HQ	Line	L3069	315	315	Y	
HQ	Line	L3070	315	315	Y	
HQ	Line	L3071	315	315	Y	
HQ	Line	L3072	None	None	Y	
HQ	Line	L3073	None	None	Y	
HQ	Line	L3074	None	None	Y	
HQ	Line	L3075	None	None	Y	
HQ	Line	L3076	None	None	Y	
HQ	Line	L3078	315	315	Y	
HQ	Line	L3079	315	315	Y	
HQ	Line	L3080	315	315	Y	
HQ	Line	L3081	315	315	Y	
HQ	Line	L3082	315	None	Y	
HQ	Line	L3083	315	None	Y	
HQ	Line	L3084	315	None	Y	
HQ	Line	L3085	315	None	Y	
HQ	Line	L3086	315	315	Y	
HQ	Line	L3087	315	315	Y	
HQ	Line	L3088	None	None	Y	
HQ	Line	L3089	315	None	Y	
HQ	Line	L3090	315	None	Y	
HQ	Line	L3091	315	315	Y	
HQ	Line	L3092	315	315	Y	
HQ	Line	L3095	345	345	Y	
HQ	Line	L3100	315	315	Y	



Reliability Coordinator in Québec

Entity	Type	Name	RTP Applicable Voltage Levels (kV)	Bulk Applicable Voltage Levels (kV)	Line operated at 200 kV or more?	Specificities
HQ	Line	L3101	315	None	Y	
HQ	Line	L3102	315	None	Y	
HQ	Line	L3104	315	315	Y	
HQ	Line	L3105	315	315	Y	
HQ	Line	L3106	315	315	Y	
HQ	Line	L3107	315	None	Y	
HQ	Line	L3108	None	None	Y	
HQ	Line	L3109	None	None	Y	
HQ	Line	L3110	315	315	Y	
HQ	Line	L3114	345	None	Y	Only the portion in Québec is covered.
HQ	Line	L3115	315	315	Y	
HQ	Line	L3116	315	315	Y	
HQ	Line	L3117	315	None	Y	
HQ	Line	L3118	315	None	Y	
HQ	Line	L3121	315	315	Y	
HQ	Line	L3122	315	315	Y	
HQ	Line	L3123	315	315	Y	
HQ	Line	L3127	315	None	Y	
HQ	Line	L3128	315	None	Y	
HQ	Line	L3129	315	315	Y	
HQ	Line	L3130	315	None	Y	
HQ	Line	L3131	315	None	Y	
HQ	Line	L3133	315	None	Y	
HQ	Line	L3145	None	None	Y	
HQ	Line	L3152	315	315	Y	
HQ	Line	L3153	315	315	Y	
HQ	Line	L3154	None	None	Y	
HQ	Line	L3155	None	None	Y	
HQ	Line	L3162	315	315	Y	
HQ	Line	L3163	315	315	Y	
HQ	Line	L3166	315	None	Y	
HQ	Line	L3167	315	None	Y	
HQ	Line	L3168	315	None	Y	
HQ	Line	L3169	315	None	Y	
HQ	Line	L3170	315	None	Y	



Reliability Coordinator in Québec

Entity	Type	Name	RTP Applicable Voltage Levels (kV)	Bulk Applicable Voltage Levels (kV)	Line operated at 200 kV or more?	Specificities
HQ	Line	L3171	315	None	Y	
HQ	Line	L3172	315	315	Y	
HQ	Line	L3173	315	315	Y	
HQ	Line	L3176	315	315	Y	
HQ	Line	L3177	315	315	Y	
HQ	Line	L3186	315	315	Y	
HQ	Line	L3187	315	None	Y	
HQ	Line	L3188	315	None	Y	
HQ	Line	L3189	315	None	Y	
HQ	Line	L3190	315	None	Y	
HQ	Line	L3191	315	None	Y	
HQ	Line	L3192	315	315	Y	
HQ	Line	L3198	None	None	Y	
HQ	Line	L3199	None	None	Y	
HQ	Line	L3209	315	None	Y	
HQ	Line	L3210	None	None	Y	
HQ	Line	L3211	None	None	Y	
HQ	Line	L4003	450 (DC)	450 (DC)	Y	
HQ	Line	L4004	450 (DC)	450 (DC)	Y	
HQ	Line	L4005	450 (DC)	None	Y	
HQ	Line	L4006	450 (DC)	None	Y	
HQ	Line	L4007	450 (DC)	450 (DC)	Y	
HQ	Line	L4008	450 (DC)	450 (DC)	Y	
HQ	Line	L4009	450 (DC)	450 (DC)	Y	
HQ	Line	L4010	450 (DC)	450 (DC)	Y	
HQ	Line	L7002	735	735	Y	
HQ	Line	L7004	735	735	Y	
HQ	Line	L7005	735	735	Y	
HQ	Line	L7006	735	735	Y	
HQ	Line	L7007	735	735	Y	
HQ	Line	L7008	735	735	Y	
HQ	Line	L7009	735	735	Y	
HQ	Line	L7010	735	735	Y	
HQ	Line	L7011	735	735	Y	
HQ	Line	L7014	735	735	Y	
HQ	Line	L7016	735	735	Y	



Reliability Coordinator in Québec

Entity	Type	Name	RTP Applicable Voltage Levels (kV)	Bulk Applicable Voltage Levels (kV)	Line operated at 200 kV or more?	Specificities
HQ	Line	L7017	735	735	Y	
HQ	Line	L7018	735	735	Y	
HQ	Line	L7019	735	735	Y	
HQ	Line	L7020	735	735	Y	
HQ	Line	L7023	735	735	Y	
HQ	Line	L7024	735	735	Y	
HQ	Line	L7025	735	735	Y	
HQ	Line	L7026	735	735	Y	
HQ	Line	L7027	735	735	Y	
HQ	Line	L7028	735	735	Y	
HQ	Line	L7029	735	735	Y	
HQ	Line	L7031	735	735	Y	
HQ	Line	L7032	735	735	Y	
HQ	Line	L7033	735	735	Y	
HQ	Line	L7034	735	735	Y	
HQ	Line	L7035	735	735	Y	
HQ	Line	L7036	735	735	Y	
HQ	Line	L7038	735	735	Y	
HQ	Line	L7040	765	765	Y	Only the portion in Québec is covered.
HQ	Line	L7042	735	735	Y	
HQ	Line	L7044	735	735	Y	
HQ	Line	L7045	735	735	Y	
HQ	Line	L7046	735	735	Y	
HQ	Line	L7047	735	735	Y	
HQ	Line	L7048	735	735	Y	
HQ	Line	L7049	735	735	Y	
HQ	Line	L7051	735	735	Y	Only the portion in Québec is covered.
HQ	Line	L7052	735	735	Y	Only the portion in Québec is covered.
HQ	Line	L7053	735	735	Y	Only the portion in Québec is covered.
HQ	Line	L7054	735	735	Y	
HQ	Line	L7055	735	735	Y	
HQ	Line	L7056	735	735	Y	
HQ	Line	L7057	735	735	Y	
HQ	Line	L7059	735	735	Y	



Reliability Coordinator in Québec

Entity	Type	Name	RTP Applicable Voltage Levels (kV)	Bulk Applicable Voltage Levels (kV)	Line operated at 200 kV or more?	Specificities
HQ	Line	L7060	735	735	Y	Sakami-1 blocking capacitor is included in the RTP.
HQ	Line	L7061	735	735	Y	Opinaca-1 blocking capacitor is included in the RTP.
HQ	Line	L7062	735	735	Y	Opinaca-2 blocking capacitor is included in the RTP.
HQ	Line	L7063	735	735	Y	Opinaca-3 blocking capacitor is included in the RTP.
HQ	Line	L7066	735	735	Y	
HQ	Line	L7067	735	735	Y	
HQ	Line	L7068	735	735	Y	
HQ	Line	L7069	735	735	Y	
HQ	Line	L7070	735	735	Y	
HQ	Line	L7071	735	735	Y	
HQ	Line	L7072	735	735	Y	
HQ	Line	L7073	735	735	Y	
HQ	Line	L7076	735	735	Y	
HQ	Line	L7077	735	735	Y	
HQ	Line	L7078	735	735	Y	
HQ	Line	L7079	735	735	Y	
HQ	Line	L7080	735	735	Y	
HQ	Line	L7081	735	735	Y	
HQ	Line	L7082	735	735	Y	
HQ	Line	L7084	735	735	Y	
HQ	Line	L7085	735	735	Y	
HQ	Line	L7086	735	735	Y	
HQ	Line	L7088	735	735	Y	
HQ	Line	L7089	735	735	Y	
HQ	Line	L7090	735	735	Y	
HQ	Line	L7092	735	735	Y	
HQ	Line	L7093	735	735	Y	
HQ	Line	L7094	735	735	Y	
HQ	Line	L7095	735	735	Y	
HQ	Line	L7096	735	735	Y	
HQ	Line	L7097	735	735	Y	



Reliability Coordinator in Québec

Entity	Type	Name	RTP Applicable Voltage Levels (kV)	Bulk Applicable Voltage Levels (kV)	Line operated at 200 kV or more?	Specificities
HQ	Line	L7100	735	735	Y	
HQ	Line	L7101	735	735	Y	
HQ	Line	L7102	735	735	Y	
HQ	Line	L7103	735	735	Y	
HQ	Line	L7108	735	735	Y	
HQ	Line	P33C	230	None	Y	Only the portion in Québec is covered.
HQ	Line	Q4C	230	None	Y	Only the portion in Québec is covered.
HQ	Line	X2Y	120	None	N	Only the portion in Québec is covered.
HQ	Substation	Abitibi	735 - 315 - 16	735 - 315	-	
HQ	Substation	Alain-Grandbois	315	None	-	
HQ	Substation	Albanel	735 - 22	735	-	
HQ	Substation	Appalaches	735 - 230	735 - 230	-	
HQ	Substation	Arnaud	735 - 315 - 161	735 - 315 - 161	-	
HQ	Substation	Baie St-Paul	315	None	-	
HQ	Substation	Beauharnois 230 kV	230 - 120	None	-	
HQ	Substation	Beaupré	315	None	-	
HQ	Substation	Bedford	120	None	-	
HQ	Substation	Bergeronnes	735	None	-	
HQ	Substation	Blainville	315	None	-	
HQ	Substation	Boucherville	735 - 315 - 230	735 - 315 - 230	-	
HQ	Substation	Bout-de-l'Île	735 - 315 - 25	735 - 315	-	
HQ	Substation	Cadieux	120	None	-	
HQ	Substation	Cantons	735 - 230 - 450 (DC)	735 - 230	-	
HQ	Substation	Cantons (230-120 kV)	230	230	-	
HQ	Substation	Carignan	735 - 230	735 - 230	-	
HQ	Substation	Chamouchouane	735 - 16	735	-	
HQ	Substation	Charlevoix	315	None	-	
HQ	Substation	Châteauguay	765 - 735 - 315 - 120 - 13.7 - 60 (DC)	765 - 735 - 315 - 120	-	
HQ	Substation	Chénier	735 - 315 - 23	735 - 315	-	

Entity	Type	Name	RTP Applicable Voltage Levels (kV)	Bulk Applicable Voltage Levels (kV)	Line operated at 200 kV or more?	Specificities
HQ	Substation	Chibougamau	735 - 120 - 16	735	-	Registration to the Register of 120 kV RTP voltage level effective July 1, 2025.
HQ	Substation	Chissibi	735	735	-	
HQ	Substation	Chomedey	315	None	-	
HQ	Substation	Deschambault	315	None	-	
HQ	Substation	Duvernay	735 - 315 - 16	735 - 315	-	
HQ	Substation	Électrode-des-Cantons	450 (DC)	None	-	
HQ	Substation	Électrode-Duncan	450 (DC)	None	-	
HQ	Substation	Grand-Brûlé	735 - 120	735	-	Registration to the Register of 120 kV RTP voltage level effective July 1, 2025.
HQ	Substation	Grondines	450 DC	None	-	
HQ	Substation	Hauterive	315	None	-	
HQ	Substation	Hertel	735 - 315	735 - 315	-	
HQ	Substation	Jacques-Cartier	735 - 315	735 - 315	-	
HQ	Substation	Judith-Jasmin	735 - 120	735 - 120	-	Registration to the Register of 120 kV RTP voltage level effective July 1, 2025.
HQ	Substation	Kamouraska	315	None	-	
HQ	Substation	Kipawa	120	None	-	
HQ	Substation	La Prairie	315	None	-	
HQ	Substation	La Vérendrye	735 - 16	735	-	
HQ	Substation	Lanaudière	315	None	-	
HQ	Substation	Langlois	730 V - 17 - 315 - 120	None	-	
HQ	Substation	Laurentides	735 - 315 - 230 - 39	735 - 315 - 230	-	
HQ	Substation	Le Moyne	735	735	-	
HQ	Substation	Lefrançois	315	None	-	
HQ	Substation	Leneuf	315	None	-	
HQ	Substation	Léry	315	None	-	
HQ	Substation	Les Basques	315	None	-	
HQ	Substation	Lévis	735 - 315 - 230 - 16	735 - 315 - 230	-	
HQ	Substation	Lévis 230-25 kV	230	230	-	



Reliability Coordinator in Québec

Entity	Type	Name	RTP Applicable Voltage Levels (kV)	Bulk Applicable Voltage Levels (kV)	Line operated at 200 kV or more?	Specificities
HQ	Substation	Lévis Déglaceur	315 - 43 - 20	315	-	
HQ	Substation	Lorrainville	120	None	-	
HQ	Substation	Lotbinière	450 (DC)	None	-	
HQ	Substation	Madawaska	345 - 315 - 131 (DC)	None	-	
HQ	Substation	Manicouagan	735 - 315 - 16	735 - 315	-	
HQ	Substation	Matapédia	315 - 230	None	-	
HQ	Substation	Mauricie	315 - 230	None	-	
HQ	Substation	Micoua	735 - 315	735 - 315	-	
HQ	Substation	Montagnais	735 - 315	735 - 315	-	
HQ	Substation	Montérégie	735 - 120	735 - 120	-	
HQ	Substation	Nemiscau	735 - 315 - 22	735 - 315	-	
HQ	Substation	Nicolet	735 - 230	735 - 230	-	
HQ	Substation	Nicolet c.c.	450 (DC) - 230	450 (DC) - 230	-	
HQ	Substation	Nikamo	315	None	-	
HQ	Substation	Notre-Dame	315	None	-	
HQ	Substation	Outaouais	315 - 240 - 75 (DC)	None	-	
HQ	Substation	Outardes	735	735	-	
HQ	Substation	Périgny	735	None	-	
HQ	Substation	Petite-Nation	315	None	-	Registration to the Register of 315 kV RTP voltage level effective July 1, 2025.
HQ	Substation	Quyon	230 - 120	None	-	
HQ	Substation	Radisson	735 - 315	735 - 315	-	
HQ	Substation	Radisson c.c.	450 (DC) - 315	450 (DC) - 315	-	
HQ	Substation	Rimouski	315 - 230	None	-	
HQ	Substation	Rivière-du-Loup	315 - 230	None	-	
HQ	Substation	Romaine-2 (substation)	315	None	-	
HQ	Substation	Saguenay	735 - 161	735 - 161	-	
HQ	Substation	Saint-Césaire	230 - 120	None	-	
HQ	Substation	Tilly	735 - 315	735 - 315	-	
HQ	Substation	Vignan	315	None	-	
RTA	Line	L61	345	None	Y	Registration to the RTP effective July 1, 2025.



Reliability Coordinator in Québec

Entity	Type	Name	RTP Applicable Voltage Levels (kV)	Bulk Applicable Voltage Levels (kV)	Line operated at 200 kV or more?	Specificities
RTA	Line	L62	345	None	Y	Registration to the RTP effective July 1, 2025.
RTA	Substation	Delisle	345	None	-	Registration to the RTP effective July 1, 2025, except the L3095 line feeder.

APPENDIX C – GENERATING FACILITIES

Entity	Name	Type	Facility classified as RTP?	Installed Capacity (MVA)	Connected to RTP?	At least one unit can be synchronized with a neighboring system?	Specificities
AAV	Anse-à-Valleau	Wind	Y	100.5 MW	N	N	
BDS	Baie-des-Sables	Wind	Y	109.5 MW	N	N	
CAR	Carleton	Wind	Y	109.5 MW	N	N	
EER	L'Érable	Wind	Y	100 MW	N	N	
ÉLL	High Falls	Hydro	Y	124	N	Y	
ÉLL	Masson	Hydro	Y	112	Y	Y	
ÉLP	Plateau	Wind	Y	255.8 MW	Y	N	
GM	Gros-Morne	Wind	Y	211.5 MW	N	N	
HQ	Beauharnois	Hydro	Y	2,277.82	Y	Y	
HQ	Beaumont	Hydro	Y	300	N	N	
HQ	Bécancour	Thermal (TAG)	Y	456.8	N	N	
HQ	Bersimis-1	Hydro	Y	1,240	Y	N	
HQ	Bersimis-2	Hydro	Y	889	Y	N	
HQ	Brisay	Hydro	Y	494	Y	N	
HQ	Bryson	Hydro	Y	70	Y	Y	
HQ	Carillon	Hydro	Y	885.5	N	N	
HQ	Cèdres	Hydro	Y	148.6	Y	Y	
HQ	Chelsea	Hydro	Y	190	Y	Y	
HQ	Eastmain-1	Hydro	Y	534	Y	N	
HQ	Eastmain-1-A	Hydro	Y	921	Y	N	
HQ	Jean-Lesage	Hydro	Y	1,366	Y	N	
HQ	La Gabelle	Hydro	Y	175	N	N	
HQ	La Grande-1	Hydro	Y	1,512	Y	N	
HQ	La Grande-2-A	Hydro	Y	2,340	Y	N	
HQ	La Grande-3	Hydro	Y	2,544	Y	N	
HQ	La Grande-4	Hydro	Y	2,925	Y	N	
HQ	La Tuque	Hydro	Y	327	N	N	
HQ	Laforge-1	Hydro	Y	924	Y	N	
HQ	Laforge-2	Hydro	Y	336	Y	N	
HQ	Manic-1	Hydro	Y	205	Y	N	
HQ	Manic-5	Hydro	Y	1,680	Y	N	
HQ	Manic-5-PA	Hydro	Y	1,120	Y	N	
HQ	Outardes-2	Hydro	Y	615	Y	N	
HQ	Outardes-3	Hydro	Y	1,080	Y	N	
HQ	Outardes-4	Hydro	Y	872	Y	N	
HQ	Paugan	Hydro	Y	251.5	Y	Y	
HQ	Péribonka	Hydro	Y	450.45	N	N	
HQ	Première-Chute	Hydro	Y	145	Y	Y	
HQ	Rapide-2	Hydro	Y	76	N	Y	
HQ	Rapide-7	Hydro	Y	76	N	Y	
HQ	Rapide-Blanc	Hydro	Y	245	N	N	

Reliability Coordinator in Québec

Entity	Name	Type	Facility classified as RTP?	Installed Capacity (MVA)	Connected to RTP?	At least one unit can be synchronized with a neighboring system?	Specificities
HQ	Rapide-des-Quinze	Hydro	Y	136.2	Y	Y	
HQ	Rapides-des-Cœurs	Hydro	Y	96	N	N	
HQ	Rapides-des-Îles	Hydro	Y	195.36	Y	Y	
HQ	Rapides-Farmers	Hydro	Y	127.5	Y	Y	
HQ	René-Lévesque	Hydro	Y	1,560	Y	N	
HQ	Robert-Bourassa	Hydro	Y	6,240	Y	N	
HQ	Rocher-de-Grand-Mère	Hydro	Y	264	N	N	
HQ	Romaine-1	Hydro	Y	320	Y	N	
HQ	Romaine-2	Hydro	Y	772	Y	N	
HQ	Romaine-3	Hydro	Y	490	Y	N	
HQ	Romaine-4	Hydro	Y	302	Y	N	
HQ	Sainte-Marguerite-3	Hydro	Y	930	Y	N	
HQ	Sarcelle	Hydro	Y	177	Y	N	
HQ	Shawinigan-2	Hydro	Y	243	N	N	
HQ	Shawinigan-3	Hydro	Y	228	N	N	
HQ	Toulnostouc	Hydro	Y	584	Y	N	
HQ	Trenche	Hydro	Y	336	N	N	
LA	Lac-Alfred and La Mitis	Wind	Y	324.6 MW	Y	N	
MDS	Massif-du-Sud	Wind	Y	150 MW	N	N	
MEU	Rivière-Nouvelle (MU)	Wind	Y	149.3 MW	N	N	
MON	Montérégie	Wind	Y	101.2 MW	N	N	
MOU	Moulins	Wind	Y	135.7 MW	N	N	
MSM	Mont Sainte-Marguerite	Wind	Y	147.2 MW	N	N	
NLP	Mont-Louis	Wind	Y	100.5 MW	N	N	
NLP	St-Ulric/St-Léandre	Wind	Y	127.5 MW	N	N	
NRI	Nicolas-Riou	Éolien	Y	224.4 MW	Y	N	
RDM	Rivière-du-Moulin	Wind	Y	350 MW	Y	N	
ROT	Mont-Rothery	Wind	Y	75.85 MW	N	N	
RTA	Chute-à-Caron	Hydro	Y	180	N	N	
RTA	Chute-à-la-Savane	Hydro	Y	300	N	N	
RTA	Chute-des-Passes	Hydro	Y	950	Y	N	
RTA	Chute-du-Diable	Hydro	Y	300	N	N	
RTA	Isle-Maligne	Hydro	Y	488	N	N	
RTA	Shipshaw	Hydro	Y	1,076	N	N	
RTA	Shipshaw 13	Hydro	Y	250	N	N	
SCHM	McCormick	Hydro	Y	454	O	N	



Reliability Coordinator in Québec

Entity	Name	Type	Facility classified as RTP?	Installed Capacity (MVA)	Connected to RTP?	At least one unit can be synchronized with a neighboring system?	Specificities
SDB	Seigneurie-de-Beaupré	Wind	Y	363.2 MW	O	N	
SRB	St-Robert-Bellarmin and du Granit	Wind	Y	104.6 MW	N	N	
TEM	Témiscouata	Wind	Y	73.5 MW	N	N	
TCQ	TransCanada Energy (Cogeneration of Bécancour)	Thermal (Co-generation)	Y	748	N	N	Operations suspended, except in winter (maximum 300 hours per winter and a maximum of 2 appeals per day starting June 1, 2016).
VDK	Vents-du-Kempt	Wind	Y	101.05 MW	N	N	



APPENDIX D – APPLICATION OF THE CIP STANDARDS (VERSION 5)

In decision D-2016-119, the Régie established different effective dates for entity compliance with version 5 of the CIP standards based on whether the entities were identified in the Register of entities in effect at the time of the decision as having assets classified as critical for CIP Standards version.

Entities that were identified in the Register of entities in effect at the time of the decision as having assets classified as critical for CIP Standards version 1 were:

- Hydro-Québec, Coordonnateur de la fiabilité au Québec
- Hydro-Québec

All other Registered Entities were not identified in the Register in effect at the time of the decision as having assets classified as critical for CIP Standards version 1.



APPENDIX E – RAS⁶

NPCC No.	Nature of the RAS
SPS #41/45	System separation/Generation rejection
SPS #114	Load shedding
SPS #124	Generation rejection
SPS #134	Generation rejection and Load shedding
SPS #151	System separation
SPS #160	Load shedding
SPS #226	Generation rejection

⁶ The PRC-005-6 and PRC-012-2 standards require owners of a RAS to identify their RAS. The RAS' indicated in this Appendix are therefore included for informational purposes only and are not intended to specify applicability of the Reliability Standards.

VERSION HISTORY

Decision (Date)	Changes
D-2015-098 (June 23, 2015)	Original version.
D-2015-195 (December 4, 2015)	Deleted PSE and IA functions.
D-2015-213 (December 21, 2015)	Modified Grand-Mère generation facility installed power and generating unit specifications. Added Appendix G – List of facilities for which the Régie suspends the application of the Reliability Standards.
D-2016-109 (July 15, 2016)	Modifications in connection with the appendix of the decision D-2016-109. Addition of the facility “Siemens Canada Limitée” to Appendix G.
D-2017-031 (March 21, 2017)	Modifications following decision D-2017-031: <ul style="list-style-type: none"> • Removal of all information regarding critical assets from each Registered Entity’s page (Appendix A) • Removal of the “Critical Asset” column of Transmission Facilities, Generation Facilities, Telecommunication Facilities and Control Centers (appendices B, C, D and F) • Addition of a new appendix to specify facilities designated by the Planning Coordinator, Transmission Planner or Reliability Coordinator further to criteria 2.3, 2.6, 2.7 or 2.9 of Attachment 1 of CIP-002-5.1
D-2018-149 (October 23, 2018)	Removal of appendices A, D, F and G. Moved Section 2.2 “Identification of Entities Subject to Reliability Standards” to Appendix A “Entities”. Moved Appendix H “List of Facilities designated under certain CIP-002-5.1 criteria” to Appendix F. Removal of entities in Appendix A. Removal and modification of substations in Appendix B. Addition, removal and modification of lines in Appendix B.



Reliability Coordinator in Québec

	<p>Removal and modification of generation facilities in Appendix C.</p> <p>Addition of Appendix D.</p> <p>Modifications to Appendix E.</p> <p>Addition of Appendix G to identify the additions stemming from decision D-2018-149.</p> <p>Removal of information not relevant to the application of Reliability Standards in Québec.</p>
<p>D-2019-142 (November 12, 2019)</p>	<p>2019 statutory update (per decision D-2018-149)</p> <p>System as of April 1, 2019 (with the addition of line 7103)</p> <p>Summary of modifications (in French only) (R-4095-2019, B-0005)</p> <p>Redline to previous version (R-4095-2019, B-0024)</p> <p>Temporary suspension of the application of Reliability Standards to entity Venterre NRG Inc. and to the New Richmond generation facility.</p>
<p>D-2019-150 (November 15, 2019)</p>	<p>Modification of the effective date from January 1, 2020, to July 1, 2020 to certain facilities in Appendix B.</p>
<p>D-2020-052 (May 14, 2020)</p>	<p>Temporary suspension of Énergie éolienne Le Plateau S.E.C. (Le Plateau I Wind) as a TO for its substation Plateau.</p>
<p>D-2020-062 (May 28, 2020)</p>	<p>Temporary suspension of the inclusion to the Register of lines in Appendix B.</p>
<p>D-2020-065 (June 2, 2020)</p>	<p>Suspension from the Register of Venterre NRG Inc. and its generation facility New Richmond without power limitation.</p>
<p>D-2020-088 (July 13, 2020)</p>	<p>Removal from the Register of Venterre NRG Inc. and its generation facility New Richmond.</p>
<p>D-2020-134 (October 16, 2020)</p>	<p>Added footnote to Appendices A and E to remove the distinctions between types of RAS.</p>
<p>D-2020-167 (December 11, 2020)</p>	<p>Modification of the footnote in Appendix A regarding identification of RAS owning Registered Entities.</p>

Code de champ modifié

Code de champ modifié



Reliability Coordinator in Québec

	<p>Identification of Registered Entities that may own a RAS.</p> <p>Removal of the distinctions between types of RAS in Appendix E.</p>
<p>D-2021-050 (April 21, 2021)</p>	<p>Removal of 56 “partially Bulk” lines in Appendix B following the revision of NPCC criteria A-10.</p>
<p>D-2021-110 (August 27, 2021)</p>	<p>2020 statutory update (per decision D-2018-149)</p> <p>System as of February 1, 2021</p> <p>Summary of modifications (in French only) (R-4154-2021, B-0018)</p> <p>Redline to previous version (R-4154-2021, B-0020)</p>
<p>D-2022-085 (June 28, 2022)</p>	<p>Added UFLS-Only DP entity to Chapter 2.</p>
<p>D-2022-146 (December 6, 2022)</p>	<p>2021 annual statutory update (per decision D-2018-149)</p> <p>System as of October 1, 2021</p> <p>Redline summary of modifications (in French only) (R-4179-2021, B-0035)</p> <p>Redline to previous version (R-4179-2021, B-0044)</p> <p>On February 28, 2022, a new organizational structure came into effect at Hydro-Québec. The three Hydro-Québec divisions (Hydro-Québec Distribution (HQD), Hydro-Québec Production (HQP) and Hydro-Québec TransÉnergie (HQT)) were abolished and have not been replaced with new structures. With respect to the Register, a single entity named Hydro-Québec (HQ) now encompasses the three divisions mentioned above, including their reliability functions.</p> <p>In addition, the entity Hydro-Québec – Contrôle des mouvements d’énergie (a branch of HQT) is now called Hydro-Québec, Coordonnateur de la fiabilité au Québec (HQCF).</p>
<p>D-2023-106 (September 14, 2023)</p>	<p>2022 annual statutory update (per decision D-2018-149)</p> <p>System as of October 1, 2022</p> <p>Summary of modifications (in French only) (R-4224-2023, B-0006)</p> <p>Redline to previous version (R-4224-2023, B-0018)</p>

Code de champ modifié

Code de champ modifié

Code de champ modifié

Code de champ modifié

Code de champ modifié

Code de champ modifié



Reliability Coordinator in Québec

D-2023-128 (November 6, 2023)	Modification to the Main Transmission System definition Redline to previous version (R-4190-2022, B-0083)
D-2024-010 (February 13, 2024)	<u>Addition of a footnote to Appendix A to clarify that the columns on system restoration, the Undervoltage Load Shedding Program (DST) and the Underfrequency load shedding program (DSF) are for informational purposes only.</u> <u>Modification of the background color in Appendix A for the columns on system restoration, the Undervoltage Load Shedding Program (DST) and the Underfrequency load shedding program (DSF).</u>

Code de champ modifié

a mis en forme : Police :(Par défaut) Arial, 11 pt

a mis en forme : Police :(Par défaut) Arial, 11 pt

a mis en forme : Police :(Par défaut) Arial, 11 pt

a mis en forme : Police :(Par défaut) Arial, 11 pt