

**GLOSSAIRE DES TERMES ET ACRONYMES
RELATIFS AUX NORMES DE FIABILITÉ
(VERSION ANGLAISE)**

Glossary of Terms and Acronyms used in Reliability Standards

August 2016

1. INTRODUCTION

This glossary presents, in alphabetical order, the definition of terms and acronyms used in the reliability standards and in the documents produced by the Reliability Coordinator in relation with reliability standards. Most terms come from the NERC Glossary of Terms Used in Reliability Standards, April 20, 2009, adopted by NERC Board of Trustees.

1.1 DEFINED TERMS

Terms in the definitions as well as in the standards and in Appendices for Québec, that refer to terms defined in this glossary are capitalized in the English version and italicized in the French version.

1.2 TERMS IN FRENCH

French translation of terms is shown within parentheses at the end of each definition. In addition, all acronyms and terms in French are identified by the use of bold characters. An index of terms and acronyms in French is presented in Section 3 to facilitate the search within the document.

2. DEFINITIONS AND ACRONYMS

Term	Acronym	Definition
Adequacy		The ability of the electric system to supply the aggregate electrical demand and energy requirements of the end-use customers at all times, taking into account scheduled and reasonably expected unscheduled outages of system elements. (Adéquation) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Adjacent Balancing Authority		A Balancing Authority Area that is interconnected another Balancing Authority Area either directly or via a multi-party agreement or transmission tariff. (Zone d'équilibrage adjacente) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Adverse Reliability Impact		The impact of an event that results in frequency-related instability; unplanned tripping of load or generation; or uncontrolled separation or cascading outages that affects a widespread area of the Interconnection. (Impact négatif sur la fiabilité) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
After the Fact	ATF	A time classification assigned to an RFI when the submittal time is greater than one hour after the start time of the RFI. (Après le fait) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>

Term	Acronym	Definition
Agreement		A contract or arrangement, either written or verbal and sometimes enforceable by law. (Entente) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Altitude Correction Factor		A multiplier applied to specify distances, which adjusts the distances to account for the change in relative air density (RAD) due to altitude from the RAD used to determine the specified distance. Altitude correction factors apply to both minimum worker approach distances and to minimum vegetation clearance distances. (Facteur de correction en fonction de l'altitude) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Ancillary Service		Those services that are necessary to support the transmission of capacity and energy from resources to loads while maintaining reliable operation of the Transmission Service Provider's transmission system in accordance with good utility practice. (From FERC order 888-A.) (Services complémentaires) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Anti-Aliasing Filter		An analog filter installed at a metering point to remove the high frequency components of the signal over the AGC sample period. (Filtre antirepliement) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Area Control Error	ACE	The instantaneous difference between a Balancing Authority's net actual and scheduled interchange, taking into account the effects of Frequency Bias and correction for meter error. (Écart de réglage de la zone) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Area Interchange Methodology		The Area Interchange methodology is characterized by determination of incremental transfer capability via simulation, from which Total Transfer Capability (TTC) can be mathematically derived. Capacity Benefit Margin, Transmission Reliability Margin, and Existing Transmission Commitments are subtracted from the TTC, and Postbacks and counterflows are added, to derive Available Transfer Capability. Under the Area Interchange Methodology, TTC results are generally reported on an area to area basis. (Méthodologie selon les échanges entre zones) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Arranged Interchange		The state where the Interchange Authority has received the Interchange information (initial or revised). (Échange convenu) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>

Term	Acronym	Definition
ATC Path		Any combination of Point of Receipt and Point of Delivery for which ATC is calculated; and any Posted Path ¹ (Chemin ATC) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Automatic Generation Control	AGC	Equipment that automatically adjusts generation in a Balancing Authority Area from a central location to maintain the Balancing Authority's interchange schedule plus Frequency Bias. AGC may also accommodate automatic inadvertent payback and time error correction. (Réglage automatique de la production) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Available Flowgate Capability	AFC	A measure of the flow capability remaining on a Flowgate for further commercial activity over and above already committed uses. It is defined as TFC less Existing Transmission Commitments (ETC), less a Capacity Benefit Margin, less a Transmission Reliability Margin, plus Postbacks, and plus counterflows. (Capacité disponible d'une interface de transit) (Capacité d'interface disponible)² <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Available Transfer Capability	ATC	A measure of the transfer capability remaining in the physical transmission network for further commercial activity over and above already committed uses. It is defined as Total Transfer Capability less Existing Transmission Commitments (including retail customer service), less a Capacity Benefit Margin, less a Transmission Reliability Margin, plus Postbacks, plus counterflows. (Capacité de transfert disponible) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Available Transfer Capability Implementation Document	ATCID	A document that describes the implementation of a methodology for calculating ATC or AFC, and provides information related to a Transmission Service Provider's calculation of ATC or AFC. (Document de mise en oeuvre de la capacité de transfert disponible) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Balancing Authority	BA	The responsible entity that integrates resource plans ahead of time, maintains load-interchange-generation balance within a Balancing Authority Area, and supports Interconnection frequency in real time. (Responsable de l'équilibrage) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>

¹ See 18 CFR 37.6(b)(1)

² Term used in the French version of the document « Tarifs et conditions des services de transport d'Hydro-Québec ».

Term	Acronym	Definition
Balancing Authority Area		<p>The collection of generation, transmission, and loads within the metered boundaries of the Balancing Authority. The Balancing Authority maintains load-resource balance within this area.</p> <p>(Zone d'équilibrage)</p> <p><small>Source : Glossary of Terms Used in NERC Reliability Standards</small></p>
Base Load		<p>The minimum amount of electric power delivered or required over a given period at a constant rate.</p> <p>(Charge de base)</p> <p><small>Source : Glossary of Terms Used in NERC Reliability Standards</small></p>
BES Cyber Asset		<p>A Cyber Asset that if rendered unavailable, degraded, or misused would, within 15 minutes of its required operation, misoperation, or non-operation, adversely impact one or more Facilities, systems, or equipment, which, if destroyed, degraded, or otherwise rendered unavailable when needed, would affect the reliable operation of the Bulk Electric System. Redundancy of affected Facilities, systems, and equipment shall not be considered when determining adverse impact. Each BES Cyber Asset is included in one or more BES Cyber Systems. (A Cyber Asset is not a BES Cyber Asset if, for 30 consecutive calendar days or less, it is directly connected to a network within an ESP, a Cyber Asset within an ESP, or to a BES Cyber Asset, and it is used for data transfer, vulnerability assessment, maintenance, or troubleshooting purposes.)</p> <p>(Actif électronique BES)</p> <p><small>Source : Glossary of Terms Used in NERC Reliability Standards</small></p>
BES Cyber System		<p>One or more BES Cyber Assets logically grouped by a responsible entity to perform one or more reliability tasks for a functional entity.</p> <p>(Système électronique BES)</p> <p><small>Source : Glossary of Terms Used in NERC Reliability Standards</small></p>
BES Cyber System Information		<p>Information about the BES Cyber System that could be used to gain unauthorized access or pose a security threat to the BES Cyber System. BES Cyber System Information does not include individual pieces of information that by themselves do not pose a threat or could not be used to allow unauthorized access to BES Cyber Systems, such as, but not limited to, device names, individual IP addresses without context, ESP names, or policy statements. Examples of BES Cyber System Information may include, but are not limited to, security procedures or security information about BES Cyber Systems, Physical Access Control Systems, and Electronic Access Control or Monitoring Systems that is not publicly available and could be used to allow unauthorized access or unauthorized distribution; collections of network addresses; and network topology of the BES Cyber System.</p> <p>Information de système électronique BES)</p> <p><small>Source : Glossary of Terms Used in NERC Reliability Standards</small></p>

Term	Acronym	Definition
Blackstart Resource		<p>A generating unit(s) and its associated set of equipment which has the ability to be started without support from the System or is designed to remain energized without connection to the remainder of the System, with the ability to energize a bus, meeting the Transmission Operator's restoration plan needs for real and reactive power capability, frequency and voltage control, and that has been included in the Transmission Operator's restoration plan.</p> <p>(Ressource à démarrage autonome)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Block Dispatch		<p>A set of dispatch rules such that given a specific amount of load to serve, an approximate generation dispatch can be determined. To accomplish this, the capacity of a given generator is segmented into loadable "blocks," each of which is grouped and ordered relative to other blocks (based on characteristics including, but not limited to, efficiency, run of river or fuel supply considerations, and/or "must-run" status).</p> <p>(Répartition par blocs)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Bulk Electric System	BES	<p>As defined by the Regional Reliability Organization, the electrical generation resources, transmission lines, interconnections with neighboring systems, and associated equipment, generally operated at voltages of 100 kV or higher. Radial transmission facilities serving only load with one transmission source are generally not included in this definition.</p> <p>(Système de production-transport d'électricité)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Bulk Power System	BPS	<p>The interconnected electrical systems within northeastern North America comprised of system elements on which faults or disturbances can have a significant adverse impact outside of the local area.</p> <p>(Réseau "Bulk")</p> <p>Source : Document A-07 (NPCC Glossary of Terms)</p>
Burden		<p>Operation of the Bulk Electric System that violates or is expected to violate a System Operating Limit or Interconnection Reliability Operating Limit in the Interconnection, or that violates any other NERC, Regional Reliability Organization, or local operating reliability standards or criteria.</p> <p>(Mettre à risque)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Business Practices		<p>Those business rules contained in the Transmission Service Provider's applicable tariff, rules, or procedures; associated Regional Reliability Organization or regional entity business practices; or NAESB Business Practices.</p> <p>(Pratiques commerciales)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>

Term	Acronym	Definition
Capacity Benefit Margin	CBM	<p>The amount of firm transmission transfer capability preserved by the transmission provider for Load-Serving Entities (LSEs), whose loads are located on that Transmission Service Provider's system, to enable access by the LSEs to generation from interconnected systems to meet generation reliability requirements. Preservation of CBM for an LSE allows that entity to reduce its installed generating capacity below that which may otherwise have been necessary without interconnections to meet its generation reliability requirements. The transmission transfer capability preserved as CBM is intended to be used by the LSE only in times of emergency generation deficiencies.</p> <p>(Marge de partage de capacité) (Marge bénéficiaire de capacité)³</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Capacity Benefit Margin Implementation Document	CBMID	<p>A document that describes the implementation of a Capacity Benefit Margin methodology.</p> <p>(Document de mise en œuvre de la marge de partage de capacité)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Capacity Emergency		<p>A capacity emergency exists when a Balancing Authority Area's operating capacity, plus firm purchases from other systems, to the extent available or limited by transfer capability, is inadequate to meet its demand plus its regulating requirements.</p> <p>(Défaillance en puissance)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Cascading		<p>The uncontrolled successive loss of system elements triggered by an incident at any location. Cascading results in widespread electric service interruption that cannot be restrained from sequentially spreading beyond an area predetermined by studies.</p> <p>(Déclenchements en cascade)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
CIP Exceptional Circumstance		<p>A situation that involves or threatens to involve one or more of the following, or similar, conditions that impact safety or BES reliability: a risk of injury or death; a natural disaster; civil unrest; an imminent or existing hardware, software, or equipment failure; a Cyber Security Incident requiring emergency assistance; a response by emergency services; the enactment of a mutual assistance agreement; or an impediment of large scale workforce availability.</p> <p>(Circonstance CIP exceptionnelle)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>

³ Term used in the French version of the document « Tarifs et conditions des services de transport d'Hydro-Québec ».

Term	Acronym	Definition
CIP Senior Manager		A single senior management official with overall authority and responsibility for leading and managing implementation of and continuing adherence to the requirements within the NERC CIP Standards, CIP-002 through CIP-011. (Cadre supérieur CIP) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Clock Hour		The 60-minute period ending at :00. All surveys, measurements, and reports are based on Clock Hour periods unless specifically noted. (Heure civile) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Cogeneration		Production of electricity from steam, heat, or other forms of energy produced as a by-product of another process. (Cogénération) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Compliance Monitor		The entity that monitors, reviews, and ensures compliance of responsible entities with reliability standards. (Responsable de la surveillance de la conformité) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Confirmed Interchange		The state where the Interchange Authority has verified the Arranged Interchange. (Échange confirmé) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Congestion Management Report		A report that the Interchange Distribution Calculator issues when a Reliability Coordinator initiates the Transmission Loading Relief procedure. This report identifies the transactions and native and network load curtailments that must be initiated to achieve the loading relief requested by the initiating Reliability Coordinator. (Rapport de gestion des congestions) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Constrained Facility		A transmission facility (line, transformer, breaker, etc.) that is approaching, is at, or is beyond its System Operating Limit or Interconnection Reliability Operating Limit. (Installation contrainte) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Contingency		The unexpected failure or outage of a system component, such as a generator, transmission line, circuit breaker, switch or other electrical element. (Contingence) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Contingency Reserve		The provision of capacity deployed by the Balancing Authority to meet the Disturbance Control Standard (DCS) and other NERC and Regional Reliability Organization contingency requirements. (Réserve pour contingence) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>

Term	Acronym	Definition
Contract Path		An agreed upon electrical path for the continuous flow of electrical power between the parties of an Interchange Transaction. (Chemin réservé) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Control Center		One or more facilities hosting operating personnel that monitor and control the Bulk Electric System (BES) in real-time to perform the reliability tasks, including their associated data centers, of: 1) a Reliability Coordinator, 2) a Balancing Authority, 3) a Transmission Operator for transmission Facilities at two or more locations, or 4) a Generator Operator for generation Facilities at two or more locations. (Centre de contrôle) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Control Performance Standard	CPS	The reliability standard that sets the limits of a Balancing Authority's Area Control Error over a specified time period. (Norme de performance du réglage) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Control Room		Site where are located systems, terminals or control panel for the monitoring and control of a generating or transmission facility. The control room is located in the same facility it operates and can also be used for the monitoring or control of other facilities on the same site (generating facility's switchyard, adjacent generating facility). (Salle de commande) <small>Source : Direction - Contrôle des mouvements d'énergie</small>
Corrective Action Plan		A list of actions and an associated timetable for implementation to remedy a specific problem. (Plan d'actions correctives) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Cranking Path		A portion of the electric system that can be isolated and then energized to deliver electric power from a generation source to enable the startup of one or more other generating units. (Chemin de démarrage) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Curtailment		A reduction in the scheduled capacity or energy delivery of an Interchange Transaction. (Réduction) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Curtailment Threshold		The minimum Transfer Distribution Factor which, if exceeded, will subject an Interchange Transaction to curtailment to relieve a transmission facility constraint. (Seuil de réduction des transactions) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>

Term	Acronym	Definition
Cyber Assets		<p>Programmable electronic devices and including hardware, software, and data in those devices.</p> <p>(Actifs électroniques)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Cyber Security Incident		<p>A malicious act or suspicious event that :</p> <ul style="list-style-type: none"> • Compromises, or was an attempt to compromise, the Electronic Security Perimeter or Physical Security Perimeter, or, • Disrupts, or was an attempt to disrupt, the operation of a BES Cyber System. <p>(Incident de cybersécurité)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Delayed Fault Clearing		<p>Fault clearing consistent with correct operation of a breaker failure protection system and its associated breakers, or of a backup protection system with an intentional time delay.</p> <p>(Élimination retardée d'un défaut)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Demand		<ol style="list-style-type: none"> 1. The rate at which electric energy is delivered to or by a system or part of a system, generally expressed in kilowatts or megawatts, at a given instant or averaged over any designated interval of time. 2. The rate at which energy is being used by the customer. <p>(Demande)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Demand-Side Management	DSM	<p>The term for all activities or programs undertaken by Load-Serving Entity or its customers to influence the amount or timing of electricity they use.</p> <p>(Gestion de la demande)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Dial-up Connectivity		<p>A data communication link that is established when the communication equipment dials a phone number and negotiates a connection with the equipment on the other end of the link.</p> <p>(Connectivité par lien commuté)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Direct Control Load Management	DCLM	<p>Demand-Side Management that is under the direct control of the system operator. DCLM may control the electric supply to individual appliances or equipment on customer premises. DCLM as defined here does not include Interruptible Demand.</p> <p>(Gestion des charges modulables)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Dispatch Order		<p>A set of dispatch rules such that given a specific amount of load to serve, an approximate generation dispatch can be determined. To accomplish this, each generator is ranked by priority.</p> <p>(Consigne de répartition)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>

Term	Acronym	Definition
Dispersed Load by Substations		Substation load information configured to represent a system for power flow or system dynamics modeling purposes, or both. (Charge répartie par poste) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Distribution Factor	DF	The portion of an Interchange Transaction, typically expressed in per unit that flows across a transmission facility (Flowgate). (Facteur de répartition) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Distribution Provider	DP	Provides and operates the “wires” between the transmission system and the end-use customer. For those end-use customers who are served at transmission voltages, the Transmission Owner also serves as the Distribution Provider. Thus, the Distribution Provider is not defined by a specific voltage, but rather as performing the Distribution function at any voltage. (Distributeur) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Disturbance		<ol style="list-style-type: none"> 1. An unplanned event that produces an abnormal system condition. 2. Any perturbation to the electric system. 3. The unexpected change in ACE that is caused by the sudden failure of generation or interruption of load. (Perturbation) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Disturbance Control Standard	DCS	The reliability standard that sets the time limit following a Disturbance within which a Balancing Authority must return its Area Control Error to within a specified range. (Norme de contrôle en régime perturbé) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Disturbance Monitoring Equipment	DME	Devices capable of monitoring and recording system data pertaining to a Disturbance. Such devices include the following categories of recorders ⁴ <ul style="list-style-type: none"> • Sequence of event recorders which record equipment response to the event • Fault recorders, which record actual waveform data replicating the system primary voltages and currents. This may include protective relays. • Dynamic Disturbance Recorders (DDRs), which record incidents that portray power system behavior during dynamic events such as low-frequency (0.1 Hz – 3 Hz) oscillations and abnormal frequency or voltage excursions (Équipement de surveillance des perturbations) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>

⁴ Phasor Measurement Units and any other equipment that meets the functional requirements of DMEs may qualify as DMEs.

Term	Acronym	Definition
Dynamic Interchange Schedule or Dynamic Schedule		A telemetered reading or value that is updated in real time and used as a schedule in the AGC/ACE equation and the integrated value of which is treated as a schedule for interchange accounting purposes. Commonly used for scheduling jointly owned generation to or from another Balancing Authority Area. (Programme d'échange dynamique)(Programme dynamique) Source : Glossary of Terms Used in NERC Reliability Standards
Dynamic Transfer		The provision of the real-time monitoring, telemetering, computer software, hardware, communications, engineering, energy accounting (including inadvertent interchange), and administration required to electronically move all or a portion of the real energy services associated with a generator or load out of one Balancing Authority Area into another. (Transfert dynamique) Source : Glossary of Terms Used in NERC Reliability Standards
Economic Dispatch		The allocation of demand to individual generating units on line to effect the most economical production of electricity. (Répartition optimale de la production) Source : Glossary of Terms Used in NERC Reliability Standards
Electronic Access Control or Monitoring Systems	EACMS	Cyber Assets that perform electronic access control or electronic access monitoring of the Electronic Security Perimeter(s) or BES Cyber Systems. This includes Intermediate Devices. (Systèmes de contrôle ou de surveillance des accès électroniques) Source : Glossary of Terms Used in NERC Reliability Standards
Electronic Access Point	EAP	A Cyber Asset interface on an Electronic Security Perimeter that allows routable communication between Cyber Assets outside an Electronic Security Perimeter and Cyber Assets inside an Electronic Security Perimeter. (Point d'accès électronique) Source : Glossary of Terms Used in NERC Reliability Standards
Electronic Security Perimeter	ESP	The logical border surrounding a network to which BES Cyber Systems are connected using a routable protocol. (Périmètre de sécurité électronique) Source : Glossary of Terms Used in NERC Reliability Standards
Element		Any electrical device with terminals that may be connected to other electrical devices such as a generator, transformer, circuit breaker, bus section, or transmission line. An element may be comprised of one or more components. (Élément) Source : Glossary of Terms Used in NERC Reliability Standards
Emergency or BES Emergency		Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System. (Urgence) Source : Glossary of Terms Used in NERC Reliability Standards

Term	Acronym	Definition
Emergency Rating		<p>The rating as defined by the equipment owner that specifies the level of electrical loading or output, usually expressed in megawatts (MW) or Mvar or other appropriate units, that a system, facility, or element can support, produce, or withstand for a finite period. The rating assumes acceptable loss of equipment life or other physical or safety limitations for the equipment involved.</p> <p>(Caractéristiques assignées en situation d'urgence)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Emergency Request for Interchange (Emergency RFI)		<p>Request for Interchange to be initiated for Emergency or Energy Emergency conditions.</p> <p>(Demande d'échange d'urgence)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Energy Emergency		<p>A condition when a Load-Serving Entity has exhausted all other options and can no longer provide its customers' expected energy requirements.</p> <p>(Défaillance en énergie)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Equipment Rating		<p>The maximum and minimum voltage, current, frequency, real and reactive power flows on individual equipment under steady state, short-circuit and transient conditions, as permitted or assigned by the equipment owner.</p> <p>(Caractéristiques assignées d'un équipement)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Existing Transmission Commitments	ETC	<p>Committed uses of a Transmission Service Provider's Transmission system considered when determining ATC or AFC.</p> <p>(Engagements de transport en vigueur) (Quantité de services de transport déjà engagés)⁵</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
External Routable Connectivity		<p>The logical border surrounding a network to which BES Cyber Systems are connected using a routable protocol.</p> <p>(Connectivité externe routable)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Facility		<p>A set of electrical equipment that operates as a single Bulk Electric System Element (e.g., a line, a generator, a shunt compensator, transformer, etc.).</p> <p>(Installation)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Facility Rating		<p>The maximum or minimum voltage, current, frequency, or real or reactive power flow through a facility that does not violate the applicable equipment rating of any equipment comprising the facility.</p> <p>(Caractéristiques assignées d'une installation)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>

⁵ Term used in the French version of the document « Tarifs et conditions des services de transport d'Hydro-Québec ».

Term	Acronym	Definition
Fault		An event occurring on an electric system such as a short circuit, a broken wire, or an intermittent connection. (Défaut) Source : Glossary of Terms Used in NERC Reliability Standards
Fire Risk		The likelihood that a fire will ignite or spread in a particular geographic area. (Risque d'incendie) Source : Glossary of Terms Used in NERC Reliability Standards
Firm Demand		That portion of the Demand that a power supplier is obligated to provide except when system reliability is threatened or during emergency conditions. (Demande ferme) Source : Glossary of Terms Used in NERC Reliability Standards
Firm Transmission Service		The highest quality (priority) service offered to customers under a filed rate schedule that anticipates no planned interruption. (Service de transport ferme) Source : Glossary of Terms Used in NERC Reliability Standards
Flashover		An electrical discharge through air around or over the surface of insulation, between objects of different potential, caused by placing a voltage across the air space that results in the ionization of the air space. (Contournement électrique) Source : Glossary of Terms Used in NERC Reliability Standards
Flowgate		1. A portion of the Transmission system through which the Interchange Distribution Calculator calculates the power flow from Interchange Transactions. 2. A mathematical construct, comprised of one or more monitored transmission Facilities and optionally one or more contingency Facilities, used to analyse the impact of power flows upon the Bulk Electric System. (Interface de transit) Source : Glossary of Terms Used in NERC Reliability Standards
Flowgate Methodology		The Flowgate methodology is characterized by identification of key Facilities as Flowgates. Total Flowgate Capabilities are determined based on Facility Ratings and voltage and stability limits. The impacts of Existing Transmission Commitments (ETCs) are determined by simulation. The impacts of ETC, Capacity Benefit Margin (CBM) and Transmission Reliability Margin (TRM) are subtracted from the Total Flowgate Capability, and Postbacks and counterflows are added, to determine the Available Flowgate Capability (AFC) value for that Flowgate. AFCs can be used to determine Available Transfer Capability (ATC). (Méthodologie des interfaces de transit) Source : Glossary of Terms Used in NERC Reliability Standards

Term	Acronym	Definition
Forced Outage		<p>1. The removal from service availability of a generating unit, transmission line, or other facility for emergency reasons.</p> <p>2. The condition in which the equipment is unavailable due to unanticipated failure.</p> <p>(Indisponibilité forcée)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Frequency Bias		<p>A value, usually expressed in megawatts per 0.1 Hertz (MW/0.1 Hz), associated with a Balancing Authority Area that approximates the Balancing Authority Area's response to Interconnection frequency error.</p> <p>(Compensation en fréquence)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Frequency Bias Setting		<p>A value, usually expressed in MW/0.1 Hz, set into a Balancing Authority ACE algorithm that allows the Balancing Authority to contribute its frequency response to the Interconnection.</p> <p>(Réglage de la compensation en fréquence)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Frequency Deviation		<p>A change in Interconnection frequency.</p> <p>(Déviation de fréquence)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Frequency Error		<p>The difference between the actual and scheduled frequency. ($F_A - F_S$)</p> <p>(Écart de fréquence)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Frequency Regulation		<p>The ability of a Balancing Authority to help the Interconnection maintain Scheduled Frequency. This assistance can include both turbine governor response and Automatic Generation Control.</p> <p>(Réglage de la fréquence)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Frequency Response		<p>(Equipment) The ability of a system or elements of the system to react or respond to a change in system frequency.</p> <p>(System) The sum of the change in demand, plus the change in generation, divided by the change in frequency, expressed in megawatts per 0.1 Hertz (MW/0.1 Hz).</p> <p>(Réponse en fréquence)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Generation Capability Import Requirement	GCIR	<p>The amount of generation capability from external sources identified by a Load-Serving Entity (LSE) or Resource Planner (RP) to meet its generation reliability or resource adequacy requirements as an alternative to internal resources.</p> <p>(Capacité de production requise en importation)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>

Term	Acronym	Definition
Generator Operator	GOP	The entity that operates generating unit(s) and performs the functions of supplying energy and Interconnected Operations Services. (Exploitant d'installation de production) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Generator Owner	GO	Entity that owns and maintains generating units. (Propriétaire d'installation de production) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Generator Shift Factor	GSF	A factor to be applied to a generator's expected change in output to determine the amount of flow contribution that change in output will impose on an identified transmission facility or Flowgate. (Facteur de changement de la production) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Generator-to-Load Distribution Factor	GLDF	The algebraic sum of a Generator Shift Factor and a Load Shift Factor to determine the total impact of an Interchange Transaction on an identified transmission facility or Flowgate. (Facteur de répartition production-charge) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Host Balancing Authority		<ol style="list-style-type: none"> 1. A Balancing Authority that confirms and implements Interchange Transactions for a Purchasing Selling Entity that operates generation or serves customers directly within the Balancing Authority's metered boundaries. 2. The Balancing Authority within whose metered boundaries a jointly owned unit is physically located. (Responsable de l'équilibrage - hôte) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Hourly Value		Data measured on a Clock Hour basis. (Donnée horaire) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Implemented Interchange		The state where the Balancing Authority enters the Confirmed Interchange into its Area Control Error equation. (Échange mis en oeuvre) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Inadvertent Interchange		The difference between the Balancing Authority's Net Actual Interchange and Net Scheduled Interchange. $(I_A - I_S)$ (Échange involontaire) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>

Term	Acronym	Definition
Independent Power Producer	IPP	Any entity that owns or operates an electricity generating facility that is not included in an electric utility's rate base. This term includes, but is not limited to, cogenerators and small power producers and all other nonutility electricity producers, such as exempt wholesale generators, who sell electricity. (Producteur indépendant) Source : Glossary of Terms Used in NERC Reliability Standards
Interactive Remote Access		User-initiated access by a person employing a remote access client or other remote access technology using a routable protocol. Remote access originates from a Cyber Asset that is not an Intermediate Device and not located within any of the Responsible Entity's Electronic Security Perimeter(s) or at a defined Electronic Access Point (EAP). Remote access may be initiated from: 1) Cyber Assets used or owned by the Responsible Entity, 2) Cyber Assets used or owned by employees, and 3) Cyber Assets used or owned by vendors, contractors, or consultants. Interactive remote access does not include system-to-system process communications. (Accès distant interactif) Source : Glossary of Terms Used in NERC Reliability Standards
Interchange		Energy transfers that cross Balancing Authority boundaries. (Échange) Source : Glossary of Terms Used in NERC Reliability Standards
Interchange Authority	IA	The responsible entity that authorizes implementation of valid and balanced Interchange Schedules between Balancing Authority Areas, and ensures communication of Interchange information for reliability assessment purposes. (Responsable des échanges) Source : Glossary of Terms Used in NERC Reliability Standards
Interchange Distribution Calculator	IDC	The mechanism used by Reliability Coordinators in the Eastern Interconnection to calculate the distribution of Interchange Transactions over specific Flowgates. It includes a database of all Interchange Transactions and a matrix of the Distribution Factors for the Eastern Interconnection. (Logiciel de calcul de la répartition des échanges) Source : Glossary of Terms Used in NERC Reliability Standards
Interchange Schedule		An agreed-upon Interchange Transaction size (megawatts), start and end time, beginning and ending ramp times and rate, and type required for delivery and receipt of power and energy between the Source and Sink Balancing Authorities involved in the transaction. (Programme d'échange) Source : Glossary of Terms Used in NERC Reliability Standards

Term	Acronym	Definition
Interchange Transaction		An agreement to transfer energy from a seller to a buyer that crosses one or more Balancing Authority Area boundaries. (Transaction d'échange) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Interchange Transaction Tag or Tag		The details of an Interchange Transaction required for its physical implementation. (Étiquette de transaction d'échange)(Étiquette) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Interconnected Operations Service		A service (exclusive of basic energy and transmission services) that is required to support the reliable operation of interconnected Bulk Electric Systems. (Services d'exploitation en réseaux interconnectés) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Interconnection		<ol style="list-style-type: none"> 1. A common transmission line connecting two or more electric systems. Interconnections allow electricity to flow between the two systems, and facilitate the sale of electricity between the two regions served by the systems. 2. The synchronized grids in North America: the Eastern Interconnection, Western Interconnection, ERCOT, and Quebec Interconnection.⁶ (Interconnexion) <small>Source : NERC Reliability Terminology (NERC website)</small>
Interconnection Reliability Operating Limit	IROL	A System Operating Limit that, if violated, could lead to instability, uncontrolled separation, or Cascading Outages that adversely impact the reliability of the Bulk Electric System. (Limite d'exploitation pour la fiabilité de l'Interconnexion) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Interconnection Reliability Operating Limit T _v	IROL T _v	The maximum time that an Interconnection Reliability Operating Limit can be violated before the risk to the interconnection or other Reliability Coordinator Area(s) becomes greater than acceptable. Each Interconnection Reliability Operating Limit's T _v shall be less than or equal to 30 minutes. (T_v de limite d'exploitation pour la fiabilité de l'Interconnexion) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Intermediate Balancing Authority		A Balancing Authority Area that has connecting facilities in the Scheduling Path between the Sending Balancing Authority Area and Receiving Balancing Authority Area and operating agreements that establish the conditions for the use of such facilities. (Zone d'équilibrage intermédiaire) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>

⁶ Note from direction – Contrôle des mouvements d'énergie: When capitalized, means one of the four mentioned grids.

Term	Acronym	Definition
Intermediate System		A Cyber Asset or collection of Cyber Assets performing access control to restrict Interactive Remote Access to only authorized users. The Intermediate System must not be located inside the Electronic Security Perimeter. (Système intermédiaire) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Interruptible Load or Interruptible Demand		Demand that the end-use customer makes available to its Load-Serving Entity via contract or agreement for curtailment. (Charge interruptible)(Demande interruptible) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Joint Control		Automatic Generation Control of jointly owned units by two or more Balancing Authorities. (Réglage conjoint) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Limiting Element		The element that is 1.)Either operating at its appropriate rating, or 2,) Would be following the limiting contingency. Thus, the Limiting Element establishes a system limit. (Élément limiteur) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Load		1. An end-use device or customer that receives power from the electric system. 2. Power consumed by a customer. (see Demand) (Charge) <small>Sources : 1. Glossary of Terms Used in NERC Reliability Standards 2. Direction - Contrôle des mouvements d'énergie</small>
Load Shift Factor	LSF	A factor to be applied to a load's expected change in demand to determine the amount of flow contribution that change in demand will impose on an identified transmission facility or monitored Flowgate. (Facteur de changement de charge) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Load-Serving Entity	LSE	Secures energy and transmission service (and related Interconnected Operations Services) to serve the electrical demand and energy requirements of its end-use customers. (Responsable de l'approvisionnement) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>

Term	Acronym	Definition
Main Transmission System	RTP	<p>The transmission system comprised of equipments and lines generally carrying large quantities of energy and of generating facilities of 50 MVA or more, providing control over reliability parameters:</p> <ul style="list-style-type: none"> • Generation/load balancing • Frequency control • Level of operating reserves • Voltage control of the system and tie lines • Power flows within operating limits • Coordination and monitoring of interchange transactions • Monitoring of special protection systems • System restoration <p>(Réseau de transport principal)</p> <p><small>Source : Direction - Contrôle des mouvements d'énergie</small></p>
Misoperation		<ul style="list-style-type: none"> ▪ Any failure of a Protection System element to operate within the specified time when a fault or abnormal conditions occurs within a zone of protection. ▪ Any operation for a fault not within a zone of protection (other than operation as backup protection for a fault in an adjacent zone that is not cleared within a specified time for the protection for that zone. ▪ Any unintentional Protection System operation when no fault or other abnormal condition has occurred unrelated to on-site maintenance and testing activity. <p>(Fonctionnement incorrect)</p> <p><small>Source : Glossary of Terms Used in NERC Reliability Standards</small></p>
Native Load		<p>The end-use customers that the Load-Serving Entity is obligated to serve.</p> <p>(Charge locale)</p> <p><small>Source : Glossary of Terms Used in NERC Reliability Standards</small></p>
Net Actual Interchange		<p>The algebraic sum of all metered interchange over all interconnections between two physically Adjacent Balancing Authority Areas.</p> <p>(Échange réel net)</p> <p><small>Source : Glossary of Terms Used in NERC Reliability Standards</small></p>
Net Energy for Load	NEL	<p>Net Balancing Authority Area generation, plus energy received from other Balancing Authority Areas, less energy delivered to Balancing Authority Areas through interchange. It includes Balancing Authority Area losses but excludes energy required for storage at energy storage facilities.</p> <p>(Énergie disponible nette)</p> <p><small>Source : Glossary of Terms Used in NERC Reliability Standards</small></p>
Net Interchange Schedule		<p>The algebraic sum of all Interchange Schedules with each Adjacent Balancing Authority.</p> <p>(Programme d'échange net)</p> <p><small>Source : Glossary of Terms Used in NERC Reliability Standards</small></p>

Term	Acronym	Definition
Net Scheduled Interchange		<p>The algebraic sum of all Interchange Schedules across a given path or between Balancing Authorities for a given period or instant in time.</p> <p>(Échange programmé net)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Network Integration Transmission Service		<p>Service that allows an electric transmission customer to integrate, plan, economically dispatch and regulate its network reserves in a manner comparable to that in which the Transmission Owner serves Native Load customers.</p> <p>(Service de transport en réseau intégré)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Non-Firm Transmission Service		<p>Transmission service that is reserved on an as-available basis and is subject to curtailment or interruption.</p> <p>(Service de transport non ferme)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Non-Spinning Reserve		<ol style="list-style-type: none"> 1. That generating reserve not connected to the system but capable of serving demand within a specified time. 2. Interruptible load that can be removed from the system in a specified time. <p>(Réserve arrêtée)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Normal Clearing		<p>A protection system operates as designed and the fault is cleared in the time normally expected with proper functioning of the installed protection systems.</p> <p>(Élimination normale d'un défaut)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Normal Rating		<p>The rating as defined by the equipment owner that specifies the level of electrical loading, usually expressed in megawatts (MW) or other appropriate units that a system, facility, or element can support or withstand through the daily demand cycles without loss of equipment life.</p> <p>(Caractéristiques assignées en situation normale)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Nuclear Plant Generator Operator	NUC OP	<p>Any Generator Operator or Generator Owner that is a Nuclear Plant Licensee responsible for operation of a nuclear facility licensed to produce commercial power.</p> <p>(Exploitant de centrale nucléaire)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Nuclear Plant Interface Requirements	NPIRs	<p>The requirements based on NPLRs and Bulk Electric System requirements that have been mutually agreed to by the Nuclear Plant Generator Operator and the applicable Transmission Entities.</p> <p>(Exigences relatives à l'interface de centrale nucléaire)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>

Term	Acronym	Definition
Nuclear Plant Licensing Requirements	NPLRs	<p>Requirements included in the design basis of the nuclear plant and statutorily mandated for the operation of the plant, including nuclear power plant licensing requirements for:</p> <ol style="list-style-type: none"> 1) Off-site power supply to enable safe shutdown of the plant during an electric system or plant event; and 2) Avoiding preventable challenges to nuclear safety as a result of an electric system disturbance, transient, or condition. <p>(Exigences de délivrance d'un permis de centrale nucléaire)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Nuclear Plant Off-site Power Supply (Off-site Power)		<p>The electric power supply provided from the electric system to the nuclear power plant distribution system as required per the nuclear power plant license.</p> <p>(Alimentation électrique externe de centrale nucléaire)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Off-Peak		<p>Those hours or other periods defined by NAESB business practices, contract, agreements, or guides as periods of lower electrical demand.</p> <p>(Hors pointe)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
On-Peak		<p>Those hours or other periods defined by NAESB business practices, contract, agreements, or guides as periods of higher electrical demand.</p> <p>(En pointe)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Open Access Same Time Information Service	OASIS	<p>An electronic posting system that the Transmission Service Provider maintains for transmission access data and that allows all transmission customers to view the data simultaneously.</p> <p>(Système d'information et de réservation des capacités de transport)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Open Access Transmission Tariff	OATT	<p>Electronic transmission tariff accepted by the U.S. Federal Energy Regulatory Commission requiring the Transmission Service Provider to furnish to all shippers with non-discriminating service comparable to that provided by Transmission Owners to themselves.</p> <p>(Tarifs et conditions des services de transport)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Operating Plan		<p>A document that identifies a group of activities that may be used to achieve some goal. An Operating Plan may contain Operating Procedures and Operating Processes. A company-specific system restoration plan that includes an Operating Procedure for black-starting units, Operating Processes for communicating restoration progress with other entities, etc., is an example of an Operating Plan.</p> <p>(Plan d'exploitation)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>

Term	Acronym	Definition
Operating Procedure		<p>A document that identifies specific steps or tasks that should be taken by one or more specific operating positions to achieve specific operating goal(s). The steps in an Operating Procedure should be followed in the order in which they are presented, and should be performed by the position(s) identified. A document that lists the specific steps for a system operator to take in removing a specific transmission line from service is an example of an Operating Procedure.</p> <p>(Procédure d'exploitation)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Operating Process		<p>A document that identifies general steps for achieving a generic operating goal. An Operating Process includes steps with options that may be selected depending upon Real-time conditions. A guideline for controlling high voltage is an example of an Operating Process.</p> <p>(Processus d'exploitation)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Operating Reserve		<p>That capability above firm system demand required to provide for regulation, load forecasting error, equipment forced and scheduled outages and local area protection. It consists of spinning and non-spinning reserve.</p> <p>(Réserve d'exploitation)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Operating Reserve – Spinning		<p>The portion of Operating Reserve consisting of:</p> <ul style="list-style-type: none"> • Generation synchronized to the system and fully available to serve load within the Disturbance Recovery Period following the contingency event; or • Load fully removable from the system within the Disturbance Recovery Period following the contingency event. <p>(Réserve d'exploitation synchronisée)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Operating Reserve – Supplemental		<p>The portion of Operating Reserve consisting of:</p> <ul style="list-style-type: none"> • Generation (synchronized or capable of being synchronized to the system) that is fully available to serve load within the Disturbance Recovery Period following the contingency event; or • Load fully removable from the system within the Disturbance Recovery Period following the contingency event. <p>(Réserve d'exploitation supplémentaire)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>

Term	Acronym	Definition
Operating Voltage		<p>The voltage level by which an electrical system is designated and to which certain operating characteristics of the system are related; also, the effective (root-mean-square) potential difference between any two conductors or between a conductor and the ground. The actual voltage of the circuit may vary somewhat above or below this value.</p> <p>(Tension d'exploitation)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Operational Planning Analysis		<p>An analysis of the expected system conditions for the next day's operation. (That analysis may be performed either a day ahead or as much as 12 months ahead.) Expected system conditions include things such as load forecast(s), generation output levels, and known system constraints (transmission facility outages, generator outages, equipment limitations, etc.).</p> <p>(Analyse de planification opérationnelle)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Outage Transfer Distribution Factor	OTDF	<p>In the post-contingency configuration of a system under study, the electric Power Transfer Distribution Factor (PTDF) with one or more system Facilities removed from service (outaged).</p> <p>(Facteur de répartition en cas de panne)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Overlap Regulation Service		<p>A method of providing regulation service in which the Balancing Authority providing the regulation service incorporates another Balancing Authority's actual interchange, frequency response, and schedules into providing Balancing Authority's AGC/ACE equation.</p> <p>(Service étendu de régulation)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Participation Factors		<p>A set of dispatch rules such that given a specific amount of load to serve, an approximate generation dispatch can be determined. To accomplish this, generators are assigned a percentage that they will contribute to serve load.</p> <p>(Facteurs de participation)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Peak Demand		<ol style="list-style-type: none"> 1. The highest hourly integrated Net Energy For Load within a Balancing Authority Area occurring within a given period (e.g., day, month, season, or year). 2. The highest instantaneous demand within the Balancing Authority Area. <p>(Demande de pointe)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Performance-Reset Period		<p>The time period that the entity being assessed must operate without any violations to reset the level of non compliance to zero.</p> <p>(Délai de rétablissement de l'état de conformité)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>

Term	Acronym	Definition
Physical Access Control Systems	PACS	Cyber Assets that control, alert, or log access to the Physical Security Perimeter(s), exclusive of locally mounted hardware or devices at the Physical Security Perimeter such as motion sensors, electronic lock control mechanisms, and badge readers. (Systèmes de contrôle des accès physiques) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Physical Security Perimeter	PSP	The physical border surrounding locations in which BES Cyber Assets, BES Cyber Systems, or Electronic Access Control or Monitoring Systems reside, and for which access is controlled. (Périmètre de sécurité physique) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Planning Authority	PA	The responsible entity that coordinates and integrates transmission facility and service plans, resource plans, and protection systems. (Responsable de la planification) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Planning Coordinator	PC	See Planning Authority. (Coordonnateur de la planification) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Point of Delivery	POD	A location that the Transmission Service Provider specifies on its transmission system where an Interchange Transaction leaves or a Load-Serving Entity receives its energy. (Point de livraison) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Point of Receipt	POR	A location that the Transmission Service Provider specifies on its transmission system where an Interchange Transaction enters or a Generator delivers its output. (Point de réception) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Point to Point Transmission Service	PTP	The reservation and transmission of capacity and energy on either a firm or non-firm basis from the Point(s) of Receipt to the Point(s) of Delivery. (Service de transport de point à point) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Postback		Positive adjustments to ATC or AFC as defined in Business Practices. Such Business Practices may include processing of redirects and unscheduled service. (Capacité réofferte) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>

Term	Acronym	Definition
Power Transfer Distribution Factor	PTDF	In the pre-contingency configuration of a system under study, a measure of the responsiveness or change in electrical loadings on transmission system Facilities due to a change in electric power transfer from one area to another, expressed in percent (up to 100%) of the change in power transfer. (Facteur de répartition de puissance) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Pro Forma Tariff		Usually refers to the standard OATT and/or associated transmission rights mandated by the U.S. Federal Energy Regulatory Commission Order No. 888. (Convention de service de transport type) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Protected Cyber Assets	PCA	One or more Cyber Assets connected using a routable protocol within or on an Electronic Security Perimeter that is not part of the highest impact BES Cyber System within the same Electronic Security Perimeter. The impact rating of Protected Cyber Assets is equal to the highest rated BES Cyber System in the same ESP. A Cyber Asset is not a Protected Cyber Asset if, for 30 consecutive calendar days or less, it is connected either to a Cyber Asset within the ESP or to the network within the ESP, and it is used for data transfer, vulnerability assessment, maintenance, or troubleshooting purposes. (Actifs électroniques protégés) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Protection System		Protective relays, associated communication systems, voltage and current sensing devices, station batteries and DC control circuitry. (Système de protection) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Pseudo-Tie		A telemetered reading or value that is updated in real time and used as a "virtual" tie line flow in the AGC/ACE equation but for which no physical tie or energy metering actually exists. The integrated value is used as a metered MWh value for interchange accounting purposes. (Pseudo-interconnexion) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Purchasing-Selling Entity	PSE	The entity that purchases or sells, and takes title to, energy, capacity, and Interconnected Operations Services. Purchasing-Selling Entities may be affiliated or unaffiliated merchants and may or may not own generating facilities. (Négociant) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>

Term	Acronym	Definition
Ramp Rate or Ramp		(Schedule) The rate, expressed in megawatts per minute, at which the interchange schedule is attained during the ramp period. (Generator) The rate, expressed in megawatts per minute, that a generator changes its output. (Taux de rampe)(Rampe) Source : Glossary of Terms Used in NERC Reliability Standards
Rated Electrical Operating Conditions		The specified or reasonably anticipated conditions under which the electrical system or an individual electrical circuit is intend/ designed to operate. (Conditions d'exploitation électriques assignées) Source : Glossary of Terms Used in NERC Reliability Standards
Rated System Path Methodology		The Rated System Path Methodology is characterized by an initial Total Transfer Capability (TTC), determined via simulation. Capacity Benefit Margin, Transmission Reliability Margin, and Existing Transmission Commitments are subtracted from TTC, and Postbacks and counterflows are added as applicable, to derive Available Transfer Capability. Under the Rated System Path Methodology, TTC results are generally reported as specific transmission path capabilities. (Méthodologie par chemin de transport spécifique) Source : Glossary of Terms Used in NERC Reliability Standards
Rating		The operational limits of a transmission system element under a set of specified conditions. (Caractéristiques assignées) Source : Glossary of Terms Used in NERC Reliability Standards
Reallocation		The total or partial curtailment of Transactions during TLR Level 3a or 5a to allow Transactions using higher priority to be implemented. (Réaffectation) Source : Glossary of Terms Used in NERC Reliability Standards
Real-time		Present time as opposed to future time. (From Interconnection Reliability Operating Limits standard.) (Temps réel) Source : Glossary of Terms Used in NERC Reliability Standards
Real-time Assessment		An examination of existing and expected system conditions, conducted by collecting and reviewing immediately available data. (Évaluation en temps réel) Source : Glossary of Terms Used in NERC Reliability Standards
Receiving Balancing Authority		The Balancing Authority importing the Interchange. (Zone d'équilibrage réceptrice) Source : Glossary of Terms Used in NERC Reliability Standards

Term	Acronym	Definition
Regional Reliability Organization ⁷ (Regional Entity)	RRO	<p>1. An entity that ensures that a defined area of the Bulk Electric System is reliable, adequate and secure.</p> <p>2. A member of the North American Electric Reliability Council. The Regional Reliability Organization can serve as The Compliance Monitor.</p> <p>(Organisation régionale de fiabilité) (Entité régionale)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Regional Reliability Plan	RRP	<p>The plan that specifies the Reliability Coordinators and Balancing Authorities within the Regional Reliability Organization, and explains how reliability coordination will be accomplished.</p> <p>(Plan de fiabilité régional)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Registered entity		<p>Any legal entity listed in the "register identifying the entities that are subject to the reliability standards" approved by the Régie de l'énergie du Québec pursuant to section 85.13 of the Act respecting the Régie de l'énergie.</p> <p>(Entité visée)</p> <p>Source : Direction - Contrôle des mouvements d'énergie</p>
Register of Entities Subject to Reliability Standards (Register of Entities)		<p>Document approved by the Régie de l'énergie identifying the entities subject to reliability standards, their functions and their facilities.</p> <p>(Registre des entités visées par les normes de fiabilité) (Registre des entités visées)</p> <p>Source : Direction - Contrôle des mouvements d'énergie</p>
Regulating Reserve		<p>An amount of reserve responsive to Automatic Generation Control, which is sufficient to provide normal regulating margin.</p> <p>(Réserve réglante)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Regulation Service		<p>The process whereby one Balancing Authority contracts to provide corrective response to all or a portion of the ACE of another Balancing Authority. The Balancing Authority providing the response assumes the obligation of meeting all applicable control criteria as specified by NERC for itself and the Balancing Authority for which it is providing the Regulation Service.</p> <p>(Service de régulation)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Reliability Adjustment RFI		<p>Request to modify an Implemented Interchange Schedule for reliability purposes.</p> <p>(Ajustement d'une demande d'échange pour la fiabilité)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>

⁷ Note from direction – Contrôle des mouvements d'énergie: The Regional Reliability Organization (Regional Entity) for Quebec is the Northeast Power Coordinating Council (NPCC).

Term	Acronym	Definition
Reliability Coordinator	RC	The entity that is the highest level of authority who is responsible for the reliable operation of the Bulk Electric System, has the Wide Area view of the Bulk Electric System, and has the operating tools, processes and procedures, including the authority to prevent or mitigate emergency operating situations in both next-day analysis and real-time operations. The Reliability Coordinator has the purview that is broad enough to enable the calculation of Interconnection Reliability Operating Limits, which may be based on the operating parameters of transmission systems beyond any Transmission Operator's vision. (Coordonnateur de la fiabilité) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Reliability Coordinator Area		The collection of generation, transmission, and loads within the boundaries of the Reliability Coordinator. Its boundary coincides with one or more Balancing Authority Areas. (Zone de fiabilité) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Reliability Coordinator Information System	RCIS	The system that Reliability Coordinators use to post messages and share operating information in real time. (Système d'information des coordonnateurs de la fiabilité) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Remedial Action Scheme	RAS	See "Special Protection System". (Plan de défense) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Reportable Cyber Security Incident		A Cyber Security Incident that has compromised or disrupted one or more reliability tasks of a functional entity. (Incident de cybersécurité à déclarer) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Reportable Disturbance		Any event that causes an ACE change greater than or equal to 80% of a Balancing Authority's or reserve sharing group's most severe contingency. The definition of a reportable disturbance is specified by each Regional Reliability Organization. This definition may not be retroactively adjusted in response to observed performance. (Perturbation à déclarer) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Request for Interchange	RFI	A collection of data as defined in the NAESB RFI Datasheet, to be submitted to the Interchange Authority for the purpose of implementing bilateral Interchange between a Source and Sink Balancing Authority. (Demande d'échange) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>

Term	Acronym	Definition
Reserve Sharing Group		<p>A group whose members consist of two or more Balancing Authorities that collectively maintain, allocate, and supply operating reserves required for each Balancing Authority's use in recovering from contingencies within the group. Scheduling energy from an Adjacent Balancing Authority to aid recovery need not constitute reserve sharing provided the transaction is ramped in over a period the supplying party could reasonably be expected to load generation in (e.g., ten minutes). If the transaction is ramped in quicker (e.g., between zero and ten minutes) then, for the purposes of Disturbance Control Performance, the Areas become a Reserve Sharing Group.</p> <p>(Groupe de partage des réserves)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Resource Planner	RP	<p>The entity that develops a long-term (generally one year and beyond) plan for the resource adequacy of specific loads (customer demand and energy requirements) within a Planning Authority Area.</p> <p>(Planificateur des ressources)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Response Rate		<p>The Ramp Rate that a generating unit can achieve under normal operating conditions expressed in megawatts per minute (MW/Min).</p> <p>(Taux de réponse)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Right-of-Way	ROW	<p>A corridor of land on which electric lines may be located. The Transmission Owner may own the land in fee, own an easement, or have certain franchise, prescription, or license rights to construct and maintain lines.</p> <p>(Emprise)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Sabotage		<p>Malevolent act perpetrated in order to disturb operations or to interrupt them.</p> <p>(Sabotage)</p> <p>Source : Direction - Contrôle des mouvements d'énergie</p>
Scenario		<p>Possible event.</p> <p>(Scénario)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Schedule		<p>(Verb) To set up a plan or arrangement for an Interchange Transaction.</p> <p>(Noun) An Interchange Schedule.</p> <p>(Programmer)(Programme)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Scheduled Frequency		<p>60.0 Hertz, except during a time correction.</p> <p>(Fréquence programmée)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>

Term	Acronym	Definition
Scheduling Entity		An entity responsible for approving and implementing Interchange Schedules. (Entité responsable de la programmation) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Scheduling Path		The Point to Point Transmission Service arrangements reserved by the Purchasing-Selling Entity for a Transaction. (Chemin programmé) <small>Source : Adapted by Direction – Contrôle des mouvements d'énergie from the Glossary of Terms Used in NERC Reliability Standards</small>
Sending Balancing Authority		The Balancing Authority exporting the Interchange. (Zone d'équilibrage expéditrice) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Sink Balancing Authority		The Balancing Authority in which the load (sink) is located for an Interchange Transaction. (This will also be a Receiving Balancing Authority for the resulting Interchange Schedule.) (Zone d'équilibrage consommatrice) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Source Balancing Authority		The Balancing Authority in which the generation (source) is located for an Interchange Transaction. (This will also be a Sending Balancing Authority for the resulting Interchange Schedule.) (Zone d'équilibrage productrice) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Special Protection System (Remedial Action Scheme)	SPS	An automatic protection system designed to detect abnormal or predetermined system conditions, and take corrective actions other than and/or in addition to the isolation of faulted components to maintain system reliability. Such action may include changes in demand, generation (MW and Mvar), or system configuration to maintain system stability, acceptable voltage, or power flows. An SPS does not include (a) underfrequency or undervoltage load shedding or (b) fault conditions that must be isolated or (c) out-of-step relaying (not designed as an integral part of an SPS). Also called Remedial Action Scheme. (Automatisme de réseau) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Special Protection System Type I		A Special Protection System which recognizes or anticipates abnormal system conditions resulting from design and operating criteria contingencies, and whose misoperation or failure to operate would have a significant adverse impact outside of the local area. The corrective action taken by the Special Protection System along with the actions taken by other protection systems are intended to return power system parameters to a stable and recoverable state (Automatisme de réseau type I) <small>Source : NPCC Regional Reliability Reference Directory #7 Special Protection Systems</small>

Term	Acronym	Definition
Special Protection System Type II		<p>A Special Protection System which recognizes or anticipates abnormal system conditions resulting from extreme contingencies or other extreme causes, and whose misoperation or failure to operate would have a significant adverse impact outside of the local area.</p> <p>(Automatisme de réseau type II)</p> <p>Source : NPCC Regional Reliability Reference Directory #7 Special Protection Systems</p>
Spinning Reserve		<p>Unloaded generation that is synchronized and ready to serve additional demand.</p> <p>(Réserve tournante)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Stability		<p>The ability of an electric system to maintain a state of equilibrium during normal and abnormal conditions or disturbances.</p> <p>(Stabilité)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Stability Limit		<p>The maximum power flow possible through some particular point in the system while maintaining stability in the entire system or the part of the system to which the stability limit refers.</p> <p>(Limite de stabilité)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Supervisory Control and Data Acquisition	SCADA	<p>A system of remote control and telemetry used to monitor and control the transmission system.</p> <p>(Télésurveillance et acquisition de données)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Supplemental Regulation Service		<p>A method of providing regulation service in which the Balancing Authority providing the regulation service receives a signal representing all or a portion of the other Balancing Authority's ACE.</p> <p>(Service supplémentaire de régulation)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Surge		<p>A transient variation of current, voltage, or power flow in an electric circuit or across an electric system.</p> <p>(Variation transitoire)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Sustained Outage		<p>The deenergized condition of a transmission line resulting from a fault or disturbance following an unsuccessful automatic reclosing sequence and/or unsuccessful manual reclosing procedure.</p> <p>(Déclenchement définitif)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
System		<p>A combination of generation, transmission, and distribution components.</p> <p>(Réseau)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>

Term	Acronym	Definition
System Operating Limit	SOL	<p>The value (such as MW, MVar, Amperes, Frequency or Volts) that satisfies the most limiting of the prescribed operating criteria for a specified system configuration to ensure operation within acceptable reliability criteria. System Operating Limits are based upon certain operating criteria. These include, but are not limited to:</p> <ul style="list-style-type: none"> • Facility Ratings (Applicable pre- and post-Contingency equipment or facility ratings) • Transient Stability Rating (Applicable pre- and post-Contingency Stability Limits) • Voltage Stability Ratings (Applicable pre- and post-Contingency Voltage Stability) • System Voltage Limits (Applicable pre- and post-Contingency Voltage Limits) <p>(Limite d'exploitation du réseau)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
System Operator		<p>An individual at a control center (Balancing Authority, Transmission Operator, Generator Operator, Reliability Coordinator) whose responsibility it is to monitor and control that electric system in real time.</p> <p>(Répartiteur)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Telemetering		<p>The process by which measurable electrical quantities from substations and generating stations are instantaneously transmitted to the control center, and by which operating commands from the control center are transmitted to the substations and generating stations.</p> <p>(Télémesure)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Thermal Rating		<p>The maximum amount of electrical current that a transmission line or electrical facility can conduct over a specified time period before it sustains permanent damage by overheating or before it sags to the point that it violates public safety requirements.</p> <p>(Courant thermique assigné)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Tie Line		<p>A circuit connecting two Balancing Authority Areas.</p> <p>(Ligne d'interconnexion)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Tie Line Bias		<p>A mode of Automatic Generation Control that allows the Balancing Authority to 1.) maintain its Interchange Schedule and 2.) respond to Interconnection frequency error.</p> <p>(Conditionnement par ligne d'interconnexion)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>

Term	Acronym	Definition
Time Error		<p>The difference between the Interconnection time measured at the Balancing Authority(ies) and the time specified by the National Institute of Standards and Technology. Time error is caused by the accumulation of Frequency Error over a given period.</p> <p>(Écart de temps)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Time Error Correction		<p>An offset to the Interconnection's scheduled frequency to return the Interconnection's Time Error to a predetermined value.</p> <p>(Correction de l'écart de temps)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
TLR Log		<p>Report required to be filed after every TLR Level 2 or higher in a specified format. The NERC IDC prepares the report for review by the issuing Reliability Coordinator. After approval by the issuing Reliability Coordinator, the report is electronically filed in a public area of the NERC Web site.</p> <p>(Registre TLR)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Total Flowgate Capability	TFC	<p>The maximum flow capability on a Flowgate, is not to exceed its thermal rating, or in the case of a flowgate used to represent a specific operating constraint (such as a voltage or stability limit), is not to exceed the associated System Operating Limit.</p> <p>(Capacité totale d'une interface de transit)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Total Transfer Capability	TTC	<p>The amount of electric power that can be moved or transferred reliably from one area to another area of the interconnected transmission systems by way of all transmission lines (or paths) between those areas under specified system conditions.</p> <p>(Capacité totale de transfert) (Capacité de transfert totale)⁸</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Transaction		<p>See Interchange Transaction.</p> <p>(Transaction)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>
Transfer Capability		<p>The measure of the ability of interconnected electric systems to move or transfer power in a reliable manner from one area to another over all transmission lines (or paths) between those areas under specified system conditions. The units of transfer capability are in terms of electric power, generally expressed in megawatts (MW). The transfer capability from "Area A" to "Area B" is not generally equal to the transfer capability from "Area B" to "Area A."</p> <p>(Capacité de transfert)</p> <p>Source : Glossary of Terms Used in NERC Reliability Standards</p>

⁸ Term used in the French version of the document « Tarifs et conditions des services de transport d'Hydro-Québec ».

Term	Acronym	Definition
Transfer Distribution Factor		See Distribution Factor. (Facteur de répartition du transport) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Transmission		An interconnected group of lines and associated equipment for the movement or transfer of electric energy between points of supply and points at which it is transformed for delivery to customers or is delivered to other electric systems. (Transport) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Transmission Constraint		A limitation on one or more transmission elements that may be reached during normal or contingency system operations. (Contrainte de transport) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Transmission Customer		1. Any eligible customer (or its designated agent) that can or does execute a transmission service agreement or can or does receive transmission service. 2. Any of the following responsible entities: Generator Owner, Load-Serving Entity, or Purchasing-Selling Entity. (Client d'un service de transport) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Transmission Line		A system of structures, wires, insulators and associated hardware that carry electric energy from one point to another in an electric power system. Lines are operated at relatively high voltages varying from 69 kV up to 765 kV, and are capable of transmitting large quantities of electricity over long distances. (Ligne de transport) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Transmission Operator	TOP	The entity responsible for the reliability of its "local" transmission system, and that operates or directs the operations of the transmission facilities. (Exploitant de réseau de transport) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Transmission Operator Area		The collection of Transmission assets over which the Transmission Operator is responsible for operating. (Zone de l'exploitant de réseau de transport) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Transmission Owner	TO	The entity that owns and maintains transmission facilities. (Propriétaire d'installation de transport) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Transmission Planner	TP	The entity that develops a long-term (generally one year and beyond) plan for the reliability (adequacy) of the interconnected bulk electric transmission systems within its portion of the Planning Authority Area. (Planificateur de réseau de transport) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>

Term	Acronym	Definition
Transmission Reliability Margin	TRM	The amount of transmission transfer capability necessary to provide reasonable assurance that the interconnected transmission network will be secure. TRM accounts for the inherent uncertainty in system conditions and the need for operating flexibility to ensure reliable system operation as system conditions change (Marge de fiabilité de transport) (Marge de fiabilité du réseau)⁹ <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Transmission Reliability Margin Implementation Document	TRMID	A document that describes the implementation of a Transmission Reliability Margin methodology, and provides information related to a Transmission Operator's calculation of TRM. (Document de mise en oeuvre de la marge de fiabilité de transport) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Transmission Service		Services provided to the Transmission Customer by the Transmission Service Provider to move energy from a Point of Receipt to a Point of Delivery. (Service de transport) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Transmission Service Provider	TSP	The entity that administers the transmission tariff and provides Transmission Service to Transmission Customers under applicable transmission service agreements. (Fournisseur de service de transport) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Vegetation		All plant material, growing or not, living or dead. (Végétation) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>
Vegetation Inspection		The systematic examination of a transmission corridor to document vegetation conditions. (Contrôle de la végétation) <small>Source : Glossaire des termes en usage dans les normes de fiabilité (NERC)</small>
Wide Area		The entire Reliability Coordinator Area as well as the critical flow and status information from adjacent Reliability Coordinator Areas as determined by detailed system studies to allow the calculation of Interconnected Reliability Operating Limits. (Zone étendue) <small>Source : Glossary of Terms Used in NERC Reliability Standards</small>

⁹ Term used in the French version of the document « Tarifs et conditions des services de transport d'Hydro-Québec ».

3. INDEX OF FRENCH TERMS AND ACRONYMS

A

Accès distant interactif.....	17
Actif électronique BES	5
Actifs électroniques	10
Actifs électroniques protégés	26
Ajustement d'une demande d'échange pour la fiabilité	28
Alimentation électrique externe de centrale nucléaire.....	22
Analyse de planification opérationnelle	24
Après le fait.....	2
Automatisme de réseau.....	31
Automatisme de réseau type I.....	31
Automatisme de réseau type II.....	32

C

Cadre supérieur CIP.....	8
Capacité d'interface disponible.....	4
Capacité de production requise en importation..	15
Capacité de transfert	34
Capacité de transfert disponible.....	4
Capacité de transfert totale	34
Capacité disponible d'une interface de transit.....	4
Capacité réofferte	25
Capacité totale d'une interface de transit	34
Capacité totale de transfert	34
Caractéristiques assignées	27
Caractéristiques assignées d'un équipement.....	13
Caractéristiques assignées d'une installation ...	13
Caractéristiques assignées en situation d'urgence	13
Caractéristiques assignées en situation normale	21
Centre de contrôle	9
Charge	19
Charge de base	5
Charge interruptible	19
Charge locale.....	20
Charge répartie par poste.....	11
Chemin ATC	4
Chemin de démarrage.....	9
Chemin programmé.....	31
Chemin réservé	9
Circonstance CIP exceptionnelle.....	7
Client d'un service de transport.....	35

Cogénération	8
Compensation en fréquence.....	15
Conditionnement par ligne d'interconnexion	33
Conditions d'exploitation électriques assignées	27
Connectivité externe routable	13
Connectivité par lien commuté	10
Consigne de répartition.....	10
Contingence.....	8
Contournement électrique	14
Contrainte de transport	35
Contrôle de la végétation.....	36
Convention de service de transport type	26
Coordonnateur de la fiabilité.....	29
Coordonnateur de la planification	25
Correction de l'écart de temps.....	34
Courant thermique assigné.....	33

D

Déclenchement définitif	32
Déclenchements en cascade.....	7
Défaillance en énergie	13
Défaillance en puissance.....	7
Défaut	14
Délai de rétablissement de l'état de conformité.	24
Demande	10
Demande d'échange.....	29
Demande d'échange d'urgence.....	13
Demande de pointe.....	24
Demande ferme	14
Demande interruptible	19
Déviation de fréquence	15
Distributeur.....	11
Document de mise en oeuvre de la capacité de transfert disponible	4
Document de mise en oeuvre de la marge de fiabilité de transport	36
Document de mise en oeuvre de la marge de partage de capacité	7
Donnée horaire	16

E

Écart de fréquence.....	15
Écart de réglage de la zone.....	3
Écart de temps.....	34
Échange.....	17
Échange confirmé.....	8

Échange convenu.....	3
Échange involontaire.....	16
Échange mis en oeuvre.....	16
Échange programmé net.....	21
Échange réel net.....	20
Élément.....	12
Élément limiteur.....	19
Élimination normale d'un défaut.....	21
Élimination retardée d'un défaut.....	10
Emprise.....	30
En pointe.....	22
Énergie disponible nette.....	20
Engagements de transport en vigueur.....	13
Entente.....	3
Entité régionale.....	28
Entité responsable de la programmation.....	31
Entité visée.....	28
Équipement de surveillance des perturbations ..	11
Étiquette.....	18
Étiquette de transaction d'échange.....	18
Évaluation en temps réel.....	27
Exigences de délivrance d'un permis de centrale nucléaire.....	22
Exigences relatives à l'interface de centrale nucléaire.....	21
Exploitant d'installation de production.....	16
Exploitant de centrale nucléaire.....	21
Exploitant de réseau de transport.....	35

F

Facteur de changement de charge.....	19
Facteur de changement de la production.....	16
Facteur de correction en fonction de l'altitude.....	3
Facteur de répartition.....	11
Facteur de répartition de puissance.....	26
Facteur de répartition du transport.....	35
Facteur de répartition en cas de panne.....	24
Facteur de répartition production-charge.....	16
Facteurs de participation.....	24
Filtre antirepliement.....	3
Fonctionnement incorrect.....	20
Fournisseur de service de transport.....	36
Fréquence programmée.....	30

G

Gestion de la demande.....	10
Gestion des charges modulables.....	10
Groupe de partage des réserves.....	30

H

Heure civile.....	8
Hors pointe.....	22

I

Impact négatif sur la fiabilité.....	2
Incident de cybersécurité.....	10
Incident de cybersécurité à déclarer.....	29
Indisponibilité forcée.....	15
Information de système électronique BES.....	5
Installation.....	13
Installation contrainte.....	8
Interconnexion.....	18
Interface de transit.....	14

L

Ligne d'interconnexion.....	33
Ligne de transport.....	35
Limite d'exploitation du réseau.....	33
Limite d'exploitation pour la fiabilité de l'Interconnexion.....	18
Limite de stabilité.....	32
Logiciel de calcul de la répartition des échanges.....	17

M

Marge bénéficiaire de capacité.....	7
Marge de fiabilité de transport.....	36
Marge de fiabilité du réseau.....	36
Marge de partage de capacité.....	7
Méthodologie des interfaces de transit.....	14
Méthodologie par chemin de transport spécifique.....	27
Méthodologie selon les échanges entre zones ...	3
Mettre à risque.....	6

N

Négociant.....	26
Norme de contrôle en régime perturbé.....	11
Norme de performance du réglage.....	9

O

Organisation régionale de fiabilité28

P

Périmètre de sécurité électronique..... 12
 Périmètre de sécurité physique.....25
 Perturbation 11
 Perturbation à déclarer29
 Plan d'actions correctives.....9
 Plan d'exploitation.....22
 Plan de défense.....29
 Plan de fiabilité régional28
 Planificateur de réseau de transport35
 Planificateur des ressources30
 Point d'accès électronique.....12
 Point de livraison25
 Point de réception.....25
 Pratiques commerciales 6
 Procédure d'exploitation23
 Processus d'exploitation.....23
 Producteur indépendant 17
 Programme30
 Programme d'échange 17
 Programme d'échange dynamique.....12
 Programme d'échange net20
 Programme dynamique 12
 Programmer.....30
 Propriétaire d'installation de production 16
 Propriétaire d'installation de transport.....35
 Pseudo-interconnexion.....26

Q

Quantité de services de transport déjà engagés 13

R

Rampe27
 Rapport de gestion des congestions 8
 Réaffectation.....27
 Réduction.....9
 Registre des entités visées.....28
 Registre des entités visées par les normes de fiabilité28
 Registre TLR.....34
 Réglage automatique de la production.....4
 Réglage conjoint.....19
 Réglage de la compensation en fréquence 15

Réglage de la fréquence..... 15
 Répartiteur 33
 Répartition optimale de la production 12
 Répartition par blocs..... 6
 Réponse en fréquence 15
 Réseau.....32
 Réseau "Bulk" 6
 Réseau de transport principal..... 20
 Réserve arrêtée 21
 Réserve d'exploitation 23
 Réserve d'exploitation supplémentaire..... 23
 Réserve d'exploitation synchronisée 23
 Réserve pour contingence..... 8
 Réserve réglante.....28
 Réserve tournante 32
 Responsable de l'approvisionnement..... 19
 Responsable de l'équilibrage..... 4
 Responsable de l'équilibrage - hôte 16
 Responsable de la planification 25
 Responsable de la surveillance de la conformité 8
 Responsable des échanges 17
 Ressource à démarrage autonome 6
 Risque d'incendie..... 14

S

Sabotage..... 30
 Salle de commande 9
 Scénario..... 30
 Service de régulation 28
 Service de transport..... 36
 Service de transport de point à point..... 25
 Service de transport en réseau intégré 21
 Service de transport ferme 14
 Service de transport non ferme 21
 Service étendu de régulation 24
 Service supplémentaire de régulation 32
 Services complémentaires..... 3
 Services d'exploitation en réseaux interconnectés 18
 Seuil de réduction des transactions..... 9
 Stabilité 32
 Système d'information des coordonnateurs de la fiabilité..... 29
 Système d'information et de réservation des capacités de transport 22
 Système de production-transport d'électricité 6
 Système de protection 26
 Système électronique BES 5
 Système intermédiaire 19
 Systèmes de contrôle des accès physiques..... 25

Systèmes de contrôle ou de surveillance des accès électronique 12

T

Tarifs et conditions des services de transport22
 Taux de rampe.....27
 Taux de réponse.....30
 Télémessure33
 Télésurveillance et acquisition de données.....32
 Temps réel.....27
 Tension d'exploitation24
 Transaction34
 Transaction d'échange 18
 Transfert dynamique.....12
 Transport35
 T_v de limite d'exploitation pour la fiabilité de l'Interconnexion 18

U

Urgence 12

V

Variation transitoire 32
 Végétation..... 36

Z

Zone d'équilibrage 5
 Zone d'équilibrage adjacente..... 2
 Zone d'équilibrage consommatrice..... 31
 Zone d'équilibrage expéditrice 31
 Zone d'équilibrage intermédiaire 18
 Zone d'équilibrage productrice 31
 Zone d'équilibrage réceptrice 27
 Zone de fiabilité..... 29
 Zone de l'exploitant de réseau de transport 35
 Zone étendue..... 36

4. VERSION HISTORY

Date	Action / Modifications	Decision
June 23, 2015	Initial adoption	D-2015-098
December 9, 2015	Retirement of the definition "Blackstart Capability Plan" Replacement of the definition "Blackstart Resource" in the French version	D-2015-198
July 29, 2015	<p>Added 15 new definitions :</p> <ul style="list-style-type: none"> • "BES Cyber Asset" • "BES Cyber System" • "BES Cyber System Information" • "CIP Exceptional Circumstance" • "CIP Senior Manager" • "Control Center" • "Dial-up Connectivity" • "Electronic Access Control or Monitoring Systems" • "Electronic Access Point" • "External Routable Connectivity" • "Interactive Remote Access" • "Intermediate System" • "Physical Access Control Systems" • "Protected Cyber Assets" • "Reportable Cyber Security Incident" <p>Modified four definitions:</p> <ul style="list-style-type: none"> • "Cyber Asset" • "Cyber Security Incident" • "Electronic Security Parameters" • "Physical Security Perimeter" <p>Retired two definitions :</p> <ul style="list-style-type: none"> • "Critical Asset" • "Critical Cyber Asset" 	D-2016-119