# A. Introduction

## 1. Title: Reliability Coordination — Transmission Loading Relief (TLR)

- 2. Number: IRO-006-5
- **3. Purpose:** To ensure coordinated action between Interconnections when implementing Interconnection-wide transmission loading relief procedures to prevent or manage potential or actual SOL and IROL exceedances to maintain reliability of the bulk electric system.

## 4. Applicability:

4.1. Reliability Coordinator.

**4.2.** Balancing Authority.

**5. Proposed Effective Date:** First day of the first calendar quarter following the date this standard is approved by applicable regulatory authorities, or in those jurisdictions where regulatory approval is not required; the standard becomes effective on the first day of the first calendar quarter after the date this standard is approved by the NERC Board of Trustees.

## **B.** Requirements

**R1.** Each Reliability Coordinator and Balancing Authority that receives a request pursuant to an Interconnection-wide transmission loading relief procedure (such as Eastern Interconnection TLR, WECC Unscheduled Flow Mitigation, or congestion management procedures from the ERCOT Protocols) from any Reliability Coordinator, Balancing Authority, or Transmission Operator in another Interconnection to curtail an Interchange Transaction that crosses an Interconnection boundary shall comply with the request, unless it provides a reliability reason to the requestor why it cannot comply with the request. [*Violation Risk Factor: High*] [*Time Horizon: Real-time Operations*]

## C. Measures

**M1.** Each Reliability Coordinator and Balancing Authority shall provide evidence (such as dated logs, voice recordings, Tag histories, and studies, in electronic or hard copy format) that, when a request to curtail an Interchange Transaction crossing an Interconnection boundary pursuant to an Interconnection-wide transmission loading relief procedure was made from another Reliability Coordinator, Balancing Authority, or Transmission Operator in that other Interconnection, it complied with the request or provided a reliability reason why it could not comply with the request (R1).

## D. Compliance

## 1. Compliance Monitoring Process

## **1.1. Compliance Enforcement Authority**

Regional Entity.

# **1.2. Compliance Monitoring and Enforcement Processes:**

The following processes may be used:

**Compliance** Audits

Self-Certifications

Spot Checking

**Compliance Violation Investigations** 

Self-Reporting

Complaints

## 1.3. Data Retention

The Reliability Coordinator and Balancing Authority shall each keep data or evidence to show compliance as identified below unless directed by its Compliance Enforcement Authority to retain specific evidence for a longer period of time as part of an investigation:

- The Reliability Coordinator and Balancing Authority shall maintain evidence to show compliance with R1 for the most recent twelve calendar months plus the current month.
- If a Reliability Coordinator or Balancing Authority is found non-compliant, it shall keep information related to the non-compliance until found compliant or for the duration specified above, whichever is longer.

The Compliance Enforcement Authority shall keep the last audit records and all requested and submitted subsequent audit records.

## **1.4.** Additional Compliance Information

None.

# Violation Severity Levels

<b>R</b> #	Lower VSL	Moderate VSL	High VSL	Severe VSL
R1				The responsible entity received a request to curtail an Interchange Transaction crossing an Interconnection boundary pursuant to an Interconnection-wide transmission loading relief procedure from a Reliability Coordinator, Balancing Authority, or Transmission Operator, but the entity neither complied with the request, nor provided a reliability reason why it could not comply with the request.

# E. Variances

None.

# F. Associated Documents

None.

# G. Version History

Version	Date	Action	Change Tracking
0	April 1, 2005	Effective Date	New
0	August 8, 2005	Removed "Proposed" from Effective Date	Errata
1	August 8, 2005	Revised Attachment 1	Revision
3	February 26, 2007	Revised Purpose and Attachment 1 related to NERC NAESB split of the TLR procedure	Revision
4	October 23, 2007	Completed NERC/NAESB split	Revision
5	TBD	Removed Attachment 1 and made into a new standard, eliminated unnecessary requirements.	Revision
5	November 4, 2010	Approved by the Board of Trustees	
5	April 21, 2011	FERC Order issued approving IRO-006- 5 (approval effective June 27, 2011)	

## Standard IRO-006-5 — Reliability Coordination – Transmission Loading Relief (TLR)

### Appendix QC-IRO-006-5 Provisions specific to the standard IRO-006-5 applicable in Québec

This appendix establishes specific provisions for the application of the standard in Québec. Provisions of the standard and of its appendix must be read together for the purposes of understanding and interpretation. Where the standard and appendix differ, the appendix shall prevail.

## A. Introduction

- 1. Title: Reliability Coordination Transmission Loading Relief (TLR)
- **2. Number:** IRO-006-5
- **3. Purpose:** No specific provision
- 4. Applicability: No specific provision
- 5. Effective Date:
  - 5.1. Adoption of the standard by the Régie de l'énergie: May 4, 2015
  - **5.2.** Adoption of the appendix by the Régie de l'énergie: May 4, 2015
  - 5.3. Effective date of the standard and its appendix in Québec: January 1, 2016

#### **B.** Requirements

No specific provision

### C. Measures

No specific provision

#### D. Compliance

#### **1.** Compliance Monitoring Process

#### **1.1.** Compliance Enforcement Authority

The Régie de l'énergie is responsible, in Québec, for compliance enforcement with respect to the reliability standard and its appendix that it adopts.

#### **1.2.** Compliance Monitoring and Enforcement Processes

No specific provision

#### 1.3. Data Retention

No specific provision

### **1.4.** Additional Compliance Information

No specific provision

#### 2. Violation Severity Levels

No specific provision

#### E. Variances

No specific provision

#### F. Associated Documents

No specific provision

## Appendix QC-IRO-006-5 Provisions specific to the standard IRO-006-5 applicable in Québec

# **Revision History**

Revision	Adoption Date	Action	Change Tracking
0	May 4, 2015	New appendix	New